



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

734

Docket No. 50-309

AUG 20 1979

Maine Yankee Atomic Power Company
ATTN: Mr. Robert H. Groce
Licensing Engineer
20 Turnpike Road
Westborough, Massachusetts 01581

Gentlemen:

Enclosed is IE Bulletin No. 79-02, Revision 1, Supplement No. 1, which clarifies NRC positions on actions requested with regard to your power reactor facility(ies) with an operating license.

Should you have any questions regarding this Bulletin or the actions required by you, please contact this office.

Sincerely,

Boyce H. Grier
for Boyce H. Grier
Director

Enclosures:

1. IE Bulletin No. 79-02, Revision No. 1
(Supplement No. 1)
2. List of IE Bulletins Issued in Last Six
Months

cc w/encls:

E. Wood, Plant Superintendent
E. W. Thurlow, President

921277

7909070493

ENCLOSURE 1

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

IE Bulletin No. 79-02
Revision No. 1
(Supplement No. 1)
Date: August 20, 1979
Page 1 of 2

PIPE SUPPORT BASE PLATE DESIGNS USING CONCRETE EXPANSION ANCHOR BOLTS

Description of Circumstances:

The supplement to IE Bulletin No. 79-02 is intended to establish criteria for the evaluation of interim acceptability of plant operation with less than the design factors of safety for piping supports due to as-built problems, under design, base plate flexibility, or anchor bolt deficiencies.

In the reviews for system operability of the Duane Arnold and Crystal River facilities, criteria have been developed by the NRC staff that define pipe support operability. The criteria have been applied in lieu of other analysis or evaluation. Specifically, the licensees identified problems with pipe supports in which the original design factors of safety were not met but some lesser margin was available. The design margins of four or five are intended to be final design and installation objectives but systems may be classed as operable on an interim basis with some lesser margin providing a program of restoration to at least the Bulletin factors of safety has been developed. Facilities which fall outside the operability criteria are considered to probably require a Technical Specification exception and will require review on a case by case basis.

Action to be Taken by Licensees:

For the following two cases, plant operation may continue or may begin:

- a. For the support as a unit, the factor of safety compared to ultimate strengths is less than the original design but equal to or greater than two.
- b. For the anchor bolts the factor of safety is equal to or greater than two and for the support steel the original design factor of safety compared to ultimate strengths is met.

The above criteria may be applied provided graded to design margins of safety expedite supports and by the next refueling for non is as defined in Bulletin No. 79-14 where those areas of the plant which can be ente

DUPLICATE DOCUMENT

921278

Entire document previously entered into system under:

ANO 7908150164

No. of pages: 7