



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket No. 50-320

August 21, 1979

MEMORANDUM FOR: John Barton, GPU
Waste Management Activities

FROM: John T. Collins, Deputy Director
TMI-2 Support

SUBJECT: ENVIRONMENTAL BARRIER WALL

In response to your request we have reviewed the design criteria for the environmental barrier wall between the fuel handling areas for Unit 1 and Unit 2 and our comments are attached. We have not approved the design criteria pending resolution of our comments.

A handwritten signature in cursive script that reads "John T. Collins".

John T. Collins, Deputy Director
TMI-2 Support

Attachment:
Comments

cc: R. Vollmer
R. Weller

1001 256
7909240 535

PROCEDURE COMMENT SHEET

Procedure No./Title Design Criteria Environmental Barrier Wall
 Review Group NRC - IE (OPS/HP)
 Name/Date R.J. Cinte 8/13/79 C. L. Tripp - SRC

Para.	Comment	Resolution
Ref 1 + 6.3	These appear to be in conflict. Para 6.3 talks of 40 year service implying permanent structure but Ref 1 says it's temporary.	
General	No QA documentation requirement set forth. For design procurement and construction of wall	
7.0	Interface Requirement should address effect on air flow balance in Aux/ T.H.B. Ventilation System. What will be an acceptable disturbance , if any.	

POOR ORIGINAL

1001 257