

NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

IN THE MATTER OF:

SUBCOMMITTEE MEETING

on

FLUID DYNAMICS

Place - Los Angeles, California

Date - Thursday, 13 September 1979

Pages 1 - 223

Telephone:
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D.C. 20001

1030 273

NATIONWIDE COVERAGE - DAILY

7909260316

CR6841

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Thursday, 13 September 1979

The contents of this stenographic transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards (ACRS), as reported herein, is an uncorrected record of the discussions recorded at the meeting held on the above date.

No member of the ACRS Staff and no participant at this meeting accepts any responsibility for errors or inaccuracies of statement or data contained in this transcript.

1030 279

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4
5

6 SUBCOMMITTEE MEETING
7

8 on

9 FLUID DYNAMICS
10

11 Century IV Room
12 Airport Quality Inn
13 Los Angeles, California

14 Thursday, 13 September 1979

15 The ACRS Subcommittee on Fluid Dynamics met, pursuant to
16 notice, at 8:40 a.m., Dr. Milton Plesset, chairman of the
17 subcommittee, presiding.

18 PRESENT:

19 DR. MILTON PLESSET, Chairman of the Subcommittee

20 DR. J. CARSON MARK, Member

21 MR. WILLIAM MATHIS, Member
22
23
24
25

R6841

BWH

P R O C E E D I N G S

DR. PLESSET: The meeting will now come to order.

This is a meeting of the Advisory Committee on Reactor Safeguards Subcommittee on Fluid Dynamics. I am Milton Plesset, Subcommittee chairman. Other ACRS members present are William Mathis and Carson Mark; and our consultants. I will go around in this order: Dr. Catton, Dr. Wu, who has just stepped out for a moment, Dr. Yao, Dr. Zudans, Frank Zaloudex, Spence Bush. Have I left anybody out?

The purpose of this meeting is to discuss the NRC staff progress in the review of Mark I and Mark II boiling water reactor containment load definitions and acceptance criteria.

The meeting is conducted in accordance with the provisions of the Federal Advisory Committee Act and the Government in the Sunshine Act. Dr. Andrew Bates, on my left, is the designated federal employee for the meeting. The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal Register on August 29, 1979. A transcript of the meeting is being kept and will be made available, as stated in the Federal Register notice. It is requested — and this is underlined, so I am now using italics — that each speaker first identify himself and

BWH

1 speak with sufficient clarity and volume that he can be
2 readily heard.

3 We have received no written comments or requests
4 for time to make oral statements, from members of the
5 public.

6 We will proceed with the meeting, and I will now
7 call on Mr. Cliff Anderson, of the NRC staff.

8 DR. HANAUER: Let the record show, Mr. Chairman,
9 that Ace-Federal Reporters has saved the day.

10 (Court reporter provides electric extension cord
11 to subcommittee.)

12 MR. ANDERSON: I am Cliff Anderson, task manager
13 of the NRC's containment review program for Mark II dynamic
14 loads. This is a task A-8.

15 I want to make one request later on in the day.
16 We are requesting a closed session to have some discussion
17 on some of the foreign testing when that comes up. It is on
18 the agenda. It is the item -- it is one of the last items
19 on the agenda. This information is considered proprietary
20 at this point. This is proprietary to NRC.

21 DR. PLESSET: It will be about a half hour,
22 Carsor..

23 MR. ANDERSON: That is the only time that we have
24 requested a closed session.

25 DR. PLESSET: We should start by saying that our

BWH

1 session today is all concerned with the Mark II
2 containment.

3 MR. ANDERSON: Yes. The purpose of this meeting,
4 the way we see it today, is to give you an update, status
5 report on where we stand and where the Mark II owners stand
6 in the Mark II program. You might recall that our criteria
7 dealing with loads that the staff finds acceptable were
8 issued for the lead plants in September of 1978, last year.
9 We then documented this in NUREG-0487, where we provided the
10 basis for those loads that we found acceptable. That was
11 issued in October of 1978.

12 We then met with this subcommittee in November of
13 '78, about the middle of November. We had another meeting
14 where we dealt with the implementation of the generic
15 criteria on the first of the Mark II plants, the Zimmer
16 plant, and this was done in February, I believe, of this
17 year. So, this, then, is our first meeting with you since
18 that time.

19 The purpose of the meeting, we see in four major
20 areas, and we will be addressing each one of these areas
21 today. The first item, as we have indicated, we had found
22 certain loads acceptable for the lead-off, for that matter,
23 any of the Mark II plants; and those were documented in
24 NUREG-0487. There were certain of these loads where the
25 lead plants and the other plants had asked for some

BWH

1 consideration by the staff of a revised load specification.

2 Over the past year, we have worked with the Mark
3 II owners to review these other load specifications, and we
4 now have come to a point where we find certain other loads
5 than those currently found acceptable in the NUREG. These
6 other ones, also acceptable. These are just a few in the
7 SRV, and the submerged structure load area, that will be cur
8 first area; and the staff will be doing most of the talking
9 here.

10 And then there will be some discussion in this
11 area, lead plant dwoocomer support. Since the time that we
12 had last talked with you, some concerns have come up with
13 regard to consideration of redesign of the supports for some
14 of the unbraced dwoocomers. This is primarily in the Zimmer
15 and LaSalle facility. Zimmer and the LaSalle people will be
16 giving an update on that to tell you where they stand.

17 The third major area is a long-term program. A
18 lot of work has been done on this in the last couple of
19 years. A lot of progress has been made in this last year.
20 For the major generic tasks and a couple of the plant-unique
21 areas will be discussed, primarily by the Mark II owners.

22 And then the proprietary section that we had
23 requested would be this last major area, and the staff will
24 make a presentation here.

25 (Slide.)

BWH

1 This is a summary agenda, and I notice some
2 changes from the detailed agenda that you have seen before.

3 First of all, with regard to some of the lead
4 plant load areas, you would recall that we had something
5 listed for discussion of the ring vortex model. We now
6 understand, from the Mark II owners, that the lead plants,
7 all of the lead plants, will use the original load
8 specification that we had found acceptable in the NUREG.
9 And this was the one that we discussed last year. In other
10 words, none of the lead plants intend using the ring vortex
11 model at this point; so this has been moved to the long-term
12 program.

13 There had been some discussion about having a
14 presentation of this in the long-term program discussions
15 here. However, the Mark II owners' consultant is not
16 available; and, therefore, we -- there is no plan for a
17 formal presentation to deal with this topic. Should the
18 subcommittee wish to express some concerns or have some
19 informal kind of discussion along this line, we might want
20 to leave that to this point here. Again, I emphasize it is
21 not included as an evaluation methodology for any of the
22 lead plants.

23 DR. PLESSET: We might have some brief informal
24 discussion. I think some of our consultants may be able to
25 make a comment that might be of interest, but we will see

BWH

1 how it goes.

2 MR. ANDERSON: Another thing I might point out is
3 that there are quite a few items here, and we could go for
4 quite a while. We have tried to pare it down to some
5 extent. But what I am going to try to do in this
6 introduction is to give you an overview of each one of these
7 four major areas and in the process of doing that perhaps we
8 can make a determination of which one of the major areas you
9 want to concentrate on.

10 I think that is pretty much it. There was one
11 other item that was dropped, and this is the item with
12 regard to load combinations, the update on SRSS. As we
13 understand, this has been moved to a different subcommittee,
14 and that other subcommittee had taken up this topic in
15 August. So, there are no plans to make any presentations on
16 the load combination methodology for today.

17 Let me move on.

18 (Slide.)

19 This is our latest update on NRC's view of the
20 facilities scheduled for some of the Mark II plants, a
21 couple of things you might want to note on this. First of
22 all, as you are aware, the safety evaluation report was
23 issued for Zimmer. A supplement is planned. I am not sure
24 on the date of that.

25 Another point that you might want to note is that,

BWH

1 as a result of Three Mile Island-related concerns, most of
2 the fuel load dates have been moved something like five, six
3 months, on the average. We know one thing, as we look at
4 this slide, that there appears to be kind of a grouping of a
5 whole bunch of them coming in about the middle to the end of
6 '80 and the early part of '81. So, there is going to be
7 quite a bit of licensing activity.

8 One other point: We do intend to address some of
9 these concerns that have been raised with regard to the
10 potential redesign of the downcomer supports for Zimmer, in
11 a supplement, should ACRS want to discuss that after we have
12 had a chance to look at that.

13 (Slide.)

14 Just a few background slides, and I am not going
15 to go into it in any real detail. I included this for
16 reference sake, more than anything else. A picture of a
17 Mark II facility showing the major structures, the drywell,
18 wetwell, pipes, the pool.

19 (Slide.)

20 And just to give us sort of a road map today,
21 there will be some similar scenario of loads discussed in
22 the Mark I discussions tomorrow. I do present here the
23 chronology of the primary LOCA-related loads. And it might
24 be of some value to just touch on these again. I don't want
25 to agonize on this too much.

BWH

1 Following a posulated LOCA, you have steam, you
2 have steam enter the drywell. That mixture of steam and air
3 pressurizes the drywell, and this results in expulsion of
4 the water that is originally in the downcomer or in the
5 vent. And that results in loads in the basemat. The air
6 from the dry well is carried through the downcomers, forming
7 a bubble at the end of the downcomers. Formation of that
8 bubble also results in some submerged drag load on
9 components.

10 The bubbles coalesce. As the bubbles coalesce
11 into a pancake shape under the pool, the pool moves under
12 the action of that compressed air bubble, expanding
13 compression of the air space above the pool, and then also
14 undern the action of gravity. And we get these types of
15 loads. The air bubble drag loads and impact loads, delta T
16 across the diaphragm -- we have discussed a lot of these
17 things in previous meetings -- and once it reaches the
18 maximum height, as the pool settles back down, we get drag
19 loads associated with the fallback process.

20 And then, following the air clearing process,
21 where you have taken all of the air from the drywell to the
22 wetwell, which occurs within a period of maybe just a
23 relatively few seconds, we then get the steam loads. The
24 steam loads occur on the pool boundary, submerged
25 structures, and also locally on the vents.

BWH

1 We have these loads categorized into areas. One
2 of the high-mass flux loads, that we commonly call
3 "condensation oscillation," and this is a more harmonic type
4 of phenomena, and then as we go through that period and go
5 into a lower mass flux and lower air content, we have the
6 more stochastic phenomena, what was commonly referred to as
7 the "chugging loads" on the pool boundary, and also on the
8 downcomer.

9 Just for reference sake, one thing we will be
10 talking about for alternate loads would be the load on the
11 basemat. And during this vent clearing process, a little
12 bit about some of the drag loads. And we'll be doing
13 evaluation of some additional consideration of the maximum
14 wetwell pressure and maximum height of the pool.

15 There will also be some discussions in some other
16 areas here, as we talk about the long-term program, or
17 rather as the Mark II owners talk about that. Again, just
18 for reference, I am not really going to go into this, this
19 sequence of events, the time that these various phenomena
20 occur, what the phenomena is and the resulting loading
21 condition.

22 (Slide.)

23 The first of the major topic areas, the alternate
24 lead plant loads, we have alternate loads. We will be
25 talking about alternate loads of three areas: LOCA, SRV,

BWH

1 S submerged drag.

2 We have been having discussions with the Mark II
3 owners since the NUREG was issued. The LOCA area, there are
4 three pool swell-related phenomena that were addressed here.

5 The first one is, as I mentioned before, when we
6 clear the vent of the water during the early process of the
7 LOCA, one gets an induced load on the basemat and the pool
8 boundary. The original specification was 33 psi. The new
9 specification that we will be talking about is 24 psi.

10 In this area, pool swell elevation and wetwell air
11 compression methodology that we had in our criteria was to
12 use the pool swell analytical model. There was some
13 additional looking at the 4T data and some other data to put
14 some other restraints on the use of that pool swell model,
15 so that under certain conditions you would use the pool
16 swell model up to a certain point based on this 4T data.

17 And then the last one is the air bubble-related
18 asymmetric pool swell. What we are talking about here is
19 the potential air bubble pressure variations that can occur
20 on the pool containment boundary resulting from potential
21 maldistributions of the steam as it goes into the drywell.

22 In the SRV area, there is only one area we will be
23 talking about, and that is, as you recall, there are five
24 load cases that we asked the Mark II people to evaluate
25 their plants to. These include a single SRV valve release.,

BWH

1 two for an asymmetric case to relief valves, ADS and several
2 all valve sequential and all bubbles in phase.

3 One of these cases appeared to be excessively
4 conservative and this one — and was giving some difficulty
5 in evaluation of piping and things along this line — and
6 this was the load case five, all bubbles in phase, each of
7 the same frequency, covering a range of frequency of four to
8 11 hertz. And we recall at the time we put this, our NUREG,
9 together, the only real data that we had at that time was
10 Ramshead data, so we put together a very conservative
11 specification based on Ramshead load magnitude, recognizing
12 there would be — there was good indication of substantial
13 reduction.

14 What we have effectively done now is that now that
15 the KWU-T quencher data is available and the CAORSO data is
16 available, we have backed off on the magnitude. We think it
17 is appropriate to reduce the magnitude of the load
18 specification. And the submerged structure drag load, there
19 were a number of small criteria here. And a couple of these
20 areas we have done some refinement — like in the standard
21 NUREG, how does one account for interference effect and
22 separate unsteady and oscillating flow — by looking at some
23 specific Mark II considerations and some additional data.
24 Here with the vortex shedding, these are the transverse
25 loads on structures, equipment, and under what conditions

BWH

1 should this be considered.

2 And then finally, structural nodalization. What
3 kind of nodalizations should targets be subjected to in
4 order to get accurate calculations of submerged structures.

5 (Slide.)

6 The next significant area that will be discussed
7 by the lead plants — Zimmer, Shoreham, LaSalle — relates
8 to support of the downcomer. And a few words on this.
9 There are 11 Mark II plants. Of those 11 Mark II plants,
10 there is a variation in the support arrangement for those
11 downcomers. They have — some of them have different types
12 of bracing arrangements. Two of them did not have — were
13 not going to use bracing. Those were Zimmer and LaSalle.
14 Since the time that our criteria had been issued, these
15 criteria have now been folded into the design evaluation of
16 those two facilities, and the determination was made that
17 there was erosion of some of the margins and it would be
18 prudent to consider putting bracing into those plants. That
19 was one of the options. There are several other options
20 that they are investigating, to the best that we understand,
21 with regard to this concern.

22 The concern relates to primarily submerged
23 structure drag loads resulting from condensation oscillation
24 phenomena and SRV air bubbles. In particular, the
25 condensation oscillation load is occurring right about the

BWH

1 natural frequency of the downcomers, and you are having some
2 pretty high dynamic load factors associated with that.

3 Their strategy is to consider some — installing
4 some bracing in those plants, and also considering
5 refinement in the submerged structure drag load, and other
6 considerations to change the natural frequency of the
7 downcomer. They may have some other options.

8 This is something that we only have been involved
9 with in the last couple of months, and we are not currently
10 doing any evaluation of any reports or anything there. They
11 are still doing some work in this.

12 DR. PLESSET: Will the Mark II owners people give
13 us some kind of an informal brief presentation of some of
14 their ideas today?

15 DR. BRINKMAN: Yes, sir. Dr. Crawford is here
16 from Sargent & Lundy, and he will be discussing this.

17 DR. PLESSET: That's good.

18 MR. ANDERSON: There are some complications when
19 one considers putting braces into a plant that was
20 originally designed to not have braces. These are: The
21 plants were originally designed to take those downcomer
22 loads and transmit them up to the diaphragm; the other
23 plants were considering transmitting those loads to the
24 containment, not just up to the diaphragm, but also to the
25 containment walls through the bracing system.

BWH

1 Now, the concern here is that with our current
2 very conservative load specifications for lateral loads,
3 when one comes up with a multiple vent load specification,
4 you can get some pretty significant loads that have to be
5 transmitted to the containment walls. That is one of the
6 things there.

7 (Slide.)

8 A couple of slides here, just to provide a status
9 report on the total generic program.

10 This slide shows that portion of the generic
11 program still to be completed in three areas: generic SRV,
12 LOCA, and some of the miscellaneous items.

13 One of the major things I want to point out here
14 is that with the completion of documentation of Phase 2 and
15 CAORSO test -- that is about the last generic category,
16 related to SRV -- we should be getting that at the end of
17 '79. For the LOCA area, one of the last tasks here in
18 mid-'80 is the documentation associated with the 40
19 condensation oscillation tests.

20 Another point that might be made here is that our
21 current schedule for these two programs -- the lead plant
22 and the long-term -- the lead plant is essentially complete
23 with the exception of our documenting these new alternative
24 criteria and the bases for these criteria. We have found
25 these alternate criteria acceptable. However, we will

BWH

1 document this in a supplement to NUREG-0487 that is
2 currently scheduled for November of this year.

3 : For the long-term program, we have moved a lot of
4 our review efforts from the lead plant to the long-term
5 program efforts, such that we are spending over half of our
6 time now on the review of those other efforts. Our current
7 schedule calls for completion of our review efforts in
8 October 1980. I think you can see here that there could be
9 some difficulties here in our completing all of this,
10 assuming we would only be getting the reports at these
11 stages.

12 One other point one might note is that this looks
13 at the generic programs. It does not look at programs
14 falling outside of the Mark II generic program. There are a
15 number of these, and I will talk about that in a second.

16 (Slide.)

17 The next slide shows you some information with
18 regard to plant-unique programs that the Mark II owners
19 non-lead plant, Mark II owners -- in other words, not
20 Zimmer, LaSalle, and Shorehamn -- have identified. Note
21 that there are also lead plant plant-unique programs such as
22 Zimmer, in-plant tests for safety relief valve loads, the
23 LaSalle in-plant test, and also the KWUT quenchers test,
24 that are not included in this.

25 Just for illustrative purposes, one that we are

BWH

1 talking about here, the WPPSS-2 program, we are going to be
2 talking today, or the Mark II owners, will be talking about
3 a generic program with regard to an improved chug load
4 specification. There is also a plant-unique program unique
5 to WPPSS-2. We will be talking today about the generic 4T
6 condensation oscillation tests. There is a plant-unique
7 counterpart to that to get prototypical data that is
8 specific to Susquehanna. That is the GKN-2 condensation
9 oscillation test that will be discussed briefly today.

10 Many of these plant-unique programs are not that
11 well defined at this point. We are in the process of
12 sending letters to each one of the Mark II plants. The
13 purpose of this letter is, one, to request that they give us
14 a clearer definition, on a plant-unique basis, of all of
15 their programs so that we can plan our necessary resources
16 and see what impact this may have on some of the generic
17 work; and, two, we are also trying to encourage them to do
18 as much grouping as possible to come up with generic or
19 semigeneric approaches.

20 DR. ZUDANS: Are these tests, are these scale
21 tests, or are these to be done in-plant?

22 MR. ANDERSON: These are not all tests. These are
23 a combination of tests, analytical programs, and things like
24 that. We don't know all of what some of these things are,
25 to be very honest. This is a full-scale test of one vent.

BWH

1 There are some other tests that are included in here. I
2 wouldn't try and identify them.

3 DR. ZUDANS: When you say "full scale," you do not
4 mean in-plant tests?

5 MR. ANDERSON: That's right.

6 DR. CATTON: Full-scale plant simulation.

7 DR. ZUDANS: And it is all simulation, whether
8 analytical or theoretical.

9 DR. PLESSET: We will hear more later about the
10 details.

11 DR. ZUDANS: He says he doesn't know.

12 MR. ANDERSON: Some areas I know.

13 DR. PLESSET: Some he does.

14 DR. ZUDANS: Fine.

15 MR. ANDERSON: Other areas, we are just not sure.

16 We recognize that in some areas there is a need,
17 but we are trying to encourage the Mark II owners, where
18 possible, to do some grouping.

19 (Slide.)

20 The third major area is status report that is to
21 be presented by the Mark II owners on some of the primary
22 long-term program tasks, and they have made some significant
23 progress in these tasks. We have had a number of meetings
24 with them, and in just about each one of these generic and
25 plant-unique programs.

1 Looking at this list of programs, there are
2 essentially, I think it is 5 out of the 6 programs are related
3 to improved specifications of the pool boundary load or
4 steam-related load on the containment.

5 One of them is giving you an update on the CAORSO
6 safety relief valve test.

7 Just a word or two on these. You will hear a bit
8 more about this.

9 With regard to the 4T CO test, the purpose of
10 these tests is to address the non-prototypical nature of the
11 4T with regard to vent length. The original 4T plant had a
12 90-foot vent. The typical Mark II plant has a vent length
13 of 40 feet.

14 So this is to look at vent acoustic effects and
15 their effect on CO, the CREARE multivalent test. Recall that
16 the lead plant approach was to develop loads based on a
17 single cell test. These are the 4T tests, the full-scale
18 test.

19 We felt that there was need to confirm the bounding
20 nature of that and also to give us a better handle on the
21 margin associated with using single vent as opposed to
22 multiple vent loads.

23 So that is the purpose of these various multivalent
24 tests. They have completed the first phase of these tests,
25 including tests at 10 scale and 6 scale. They are now in the

1 process of doing their second phase of tests where they will
2 do some more multiple vent tests and some single vent tests
3 at larger size, including quarter scale and 5/12ths scale.

4 Improved chug load. The purpose of this program
5 is to recall — you recall in the lead plant program the
6 approach was to take the loads measured on the 4T wall, take
7 some of the worst loads there and then apply them directly
8 to the plant at the individual plants.

9 We were concerned about identifying some of the FSI
10 related aspects of the 4T facility and how that might affect
11 transmitting those loads to an individual plant.

12 In the process of their looking at that, they
13 tried to come up with a source specification that was free
14 of 4T effects. And they have done a lot of work here
15 (indicating).

16 And last of all, you've got some information on the
17 CAORSO tests at our last meeting. Those tests were in
18 progress at that time. Since that time, the tests have been
19 completed. We do have documentation on the first phase of
20 those tests.

21 The second phase, the multivent tests, the report
22 there is due in at the end of this year. And then as I
23 indicated, in addition to the generic programs, there are some
24 similiar plant unique programs very similar to the 4T CO
25 test, the GKM II CO tests.

1 These are, again, much closer to the Susquehanna
2 conditions, since it is sponsored by them.

3 In the WPPSS-2 improved chug load, again, there are
4 some similarities to the generic improved chug load, a little
5 different way of handling some of the library of test data,
6 statistical treatment of that to come up with a source and
7 some somewhat different analytical models with a lot of
8 similarities in them.

9 (Slide.)

10 The last area related foreign tests. Foreign tests
11 that are being conducted in Japan and in Germany that are
12 related to the Mark II design are in progress now. They have
13 been in progress for some months. There will be a discussion
14 first about these JAERI tests, which are prototypical of the
15 Mark II. They are full scale, they are steam tests with
16 testing programs started in '77 and scheduled to be completed
17 in 1982.

18 The tests represent a 1/16th sector of a full Mark
19 II plant, including 7 vents. Four of the shakedown tests have
20 been completed. They have also completed some of the earlier
21 tests, the regularly scheduled tests. And we have had a
22 chance to look at data from one of these tests, one of the
23 shakedown tests.

24 We have looked at it with regard to these areas,
25 pool swell, and some of the steam modes. With regard to pool

1 swell, again, this is just looking at one test under some
2 nominal conditions. Our observations are that with regard
3 to pool swell, there are no particular surprises. They do
4 establish the nature of the loads that were used for the lead
5 plant.

6 With regard to condensation oscillation, there has
7 been some attention to condensation oscillation loads on the
8 pool boundary. We have not observed any significant CO loads
9 in that particular test.

10 And then with regard to chug load, our primary
11 emphasis here is to look at some of the detailed data with
12 regard to how it might be used as part of the confirmatory
13 process for some of these improved chugging load specifications
14 where they are taking credit for reducing the lead plant
15 load.

16 A couple of observations about this.

17 In general, we would say that the average load that
18 was observed on that facility, even though it has its own
19 unique FSI, fluid/structure interaction, it has about the
20 same average load as we saw in the 4T facility.

21 There are a couple of high localized loads. One
22 of the major things that we are looking at is we are concerned
23 with the potential for a number of large chugs occurring at
24 the same time. The current plans for the improved chug load
25 specification generally assumes that you can use the library of

1 chugs as taken from a single vent test. It assumes that
2 these loads are somewhat random in magnitude. And you can
3 apply any load's magnitude for any vents interchangeably.

4 Some of our preliminary observations indicate to
5 us that there is a potential for having some large chugs
6 occurring at the same time.

7 DR. CATTON: Are you saying that the chug is —
8 random in time and random in amplitude?

9 DR. ANDERSON: The current — the lead plant —
10 excuse me. The plans for the long-term program are to assume
11 that the loads are random in magnitude but occur at the same
12 time.

13 Now, again, we will get into some of this later on.
14 We do see gross pool chugs occurring together. But as far
15 as exact phasing is concerned, we have to look at the data a
16 little more carefully with regard to that.

17 The question that we are looking at here to confirm
18 what the Mark II owners want to do in the long-term is can
19 we confirm that they are random in magnitude?

20 And we have some reason to believe that it is
21 possible you can get some large chugs occurring at the same
22 time, but we have to look at this data very carefully.

23 DR. CATTON: Will we hear more about the JAERI tests?

24 DR. ANDERSON: Yes. We will make a presentation
25 in a closed session. We are getting reports in at this point.

1 We have a report on one of the tests. This
2 information, again, at this point, both the JAERI and the
3 GKSS proprietary to NRC. Then we will make sure that the
4 ACRS does get copies of these reports.

5 We are just getting them now.

6 With regard to GKSS tests, these also are related
7 to Mark II. They are steam tests. They have three large
8 vents. They are not exactly prototypical. Vent length is
9 a little off. The drywell volume is a bit too small. But
10 the test facility was available and we do feel that we can
11 get some good qualitative information out of this.

12 Where they stand is they were going to do four
13 shakedown tests. They have done three of those. They are now
14 in the process of embarking on their regularly scheduled
15 tests. They have something like 12 tests scheduled over the
16 period of the next year and a half. The first of those
17 tests should have been done last week, as far as I understand.
18 And we have some observations on that, too.

19 Again, on the average, even though it has its own
20 PSI, we see on the average the same chug load, average chug
21 load on the pool boundary, as we saw on the 4T.

22 That completes my discussion related to this
23 introduction. And I would like to move now into some of the —

24 DR. PLESSET: Cliff, I think with your concurrence,
25 we will have a break so that we can get some more chairs in

1 here.

2 So — and we will come back to this. So let's have
3 a few minutes break and try to arrange to have a few more
4 chairs in here.

5 So we will have about a five-minute break.

6 (Recess.)

7 DR. PLESSET: Let's reconvene. We have some more
8 chairs, and if we sit down, we will see how many people still
9 have to stand. Hopefully, nobody. I will give them a moment,
10 Cliff, to get settled.

11 MR. ANDERSON: We are moving now into some of the
12 lead plant load areas and some of the work that has been
13 done in these areas.

14 The first topic we will be taking up is the
15 alternate LOCA loads. Following my presentation, Dr.
16 Economus, our consultant from Brookhaven, will talk about the
17 alternate safety relief valve load specification. And then
18 following that, Professor Bienkowski from Princeton, also
19 our consultant, will talk about some of our alternate
20 specifications there.

21 I might make one point before I get into this. The
22 original loads that were proposed for the Mark II plants were
23 documented in the Mark II owners dynamic force and function
24 report. We reviewed that, and as a result of our review,
25 we came out with a NUREG-0487, loads for the lead plants.

1 As I indicated before, we have been working with
2 them to refine some of those loads to come up with alternate
3 loads. :

4 What we mean by "alternate loads" is that we would
5 find either these loads or the original loads conservative
6 and acceptable. We have documented these alternate loads in
7 various letter reports that have been issued over the last
8 year, and you should have those letter reports.

9 I'm not going to try to identify them one by one
10 during this meeting, but if you're interested in the specific
11 ones, let me know and I will mention them.

12 With one exception -- there is one area, the
13 submerged structure drag load area, where there is not a
14 public -- a report out yet. We have a draft of that report
15 and we will be telling the Mark II owners to get that report
16 submitted and documented as a formal report before too long.

17 As I indicated before, we are going to be dealing
18 with three pool swell related loads: the low load on the
19 pool boundary; the maximum pool swell elevation; and the
20 asymmetric pool swell resulting from asymmetric bubble
21 pressure on the pool boundary.

22 I will do several things. First, to give you the
23 origin of the load, the original specification and the
24 basis for that, and then the revised or alternate
25 specification and our basis for accepting that alternate

1 specification.

2 I might point out again that we have concluded that
3 all of these loads we will be talking about are acceptable.

4 (Slide.)

5 The first of these deals with the event clearing
6 load. The origin of this, again, is when you expel the water
7 that is originally in the downcomer and induce pressure on
8 the pool boundary, the original specification included a
9 33 psi overpressure statically applied to the containment on
10 the basemat.

11 This was in their DFFR. The basis for that was the
12 assumption that one had formation of a jet which could
13 penetrate to the basemat and then doing a conservative
14 calculation with a very conservative vent clearing velocity,
15 one came up with 33 psi.

16 We looked at the test data and based on the test
17 data, we felt that this definitely was a conservative
18 specification. We did feel, however, that it should not be
19 limited to the basemat. There should be a specification
20 associated with this induced pressure also on the containment
21 walls.

22 So we extended the specification to be applied to
23 the containment walls.

24 (Slide.)

25 The Mark II owners agreed with us regarding the

1 appropriateness of the specification of a vent clearing
2 induced pressure on the walls. But they felt that the 33 psi,
3 after looking at the 4T data a little harder, was a bit on
4 the conservative side, and a significantly lower load could
5 be justified.

6 It was justified primarily in light of test data
7 instead of doing these conservative calculations. There was
8 good indication that you would not have jet penetration based
9 on looking at these like EPRI data. More like three vent
10 diameters as opposed to a total vent clearance to the basemat
11 of something like 10 feet.

12 So as a result of looking at the 4T data, they
13 came up with a 24 psi pressure to be applied over the
14 hydrostatic pressure on the basemat and on the walls up to
15 the exit of the downcomer and then a linear tenation of zero
16 to surface of the pool.

17 They formed this load specification on the basis
18 of the highest basemat pressure observed during this time
19 period during the 4T test. The highest value they had
20 observed was 20 psi.

21 I should note that on the average, they observed
22 something in the order of magnitude of about 12 psi, 12-1/2
23 psi. However, they did do a little bit of modification of
24 this to reflect the fact that while 4T is a facility that
25 is prototypical of Mark II plants and has been designed so that

1 it would be bounding its parameters pool area to vent area
2 ratio, things like that. It was conservative but there was
3 one area where there was potential non-conservatism for
4 certain plants.

5 This non-conservatism is that the total test matrix
6 did not necessarily go to the maximum drywell pressurization
7 that one would calculate using conservative models for the --
8 some of the Mark II plants.

9 If one looks at the Mark II plants and picks out
10 for the limiting one the maximum drywell pressure at the
11 point of vent clearing, one sees that that can be as high
12 as 4 PSI higher than the maximum value seen in the 4T tests.

13 So they added the 4 psi to the 20 psi. We feel that
14 there is some basis for that methodology coming up with a
15 pool boundary load. But we felt that we might take a little
16 harder look into it.

17 And what we did was our consultants did a least
18 square fit of both the 4T points and also some Marviken data,
19 where our consultants did a least square fit of the
20 overpressure, induced overpressure with these parameters, the
21 one we thought would be important, ones related to
22 pressurization.

23 In other words, the energy flux submergence, and
24 then indirectly to the pool-area-to-vent-area ratio.

25 We concluded the 24 psi specification was



1 conservative and a 99-99 non-exceedence competence limit,
2 as long as one did not exceed a value of this parameter of
3 55.

4 But I think that none of the domestic Mark II
5 plants exceed that parameter of 55.

6 So we find that 24 psi is acceptable.

7 The next area, I don't want to go over too much of
8 previous ground that was covered in this particular load
9 specification, but I think there is a little bit here — the
10 next one refers to the specification relating to the maximum
11 pool swell height and the associated maximum wet well
12 compression.

13 (Slide.)

14 There are two things with regard to pool swell
15 methodology. One, they used a pool swell model that had been
16 benchmarked against a number of tests to calculate velocities
17 in individual plants. They used that — this was in their
18 original dynamic forcing function report methodology. They
19 used that up to the point of maximum velocity and then they
20 kept a constant maximum velocity up to 1-1/2 times
21 submergence where breakthrough was assumed to occur, and then
22 the pool would settle back.

23 In our evaluation of that originally, we had found
24 that in a few cases, primarily for low submergence, those
25 plants with maybe 9-foot vents, you could exceed that 1-1/2

1 times vent submergence criteria.

2 And in addition, we had some concern with regard
3 to the method they used for calculating or backing out the
4 elevation. They backed it out kind of indirectly based on
5 the observed well pressures in the test.

6 So as a result of that, we had specified last year,
7 discussed with you in the NUREG specification for velocity
8 and pool elevation, maximum elevation based strictly on the
9 pool swell model with a little bit of fooling around with
10 the model.

11 We did basically two things. To account for some
12 uncertainties in the velocity measurements, we increased the
13 velocity by 10 percent. But that is not a problem really here

14 The other thing we had done is we felt they should
15 use the exponent of 1.2, and when our consultants had taken
16 the pool swell model and used it, and used it in predicting
17 4T tests, they concluded that the pool swell model bounded
18 all velocity measurements and in addition, provided a
19 4-foot margin on all measurements of pool swell elevation,
20 including froth.

21 DR. BUSH: That figure isn't in your presentation,
22 incidentally.

23 DR. MARK: We had a different version earlier.

24 DR. ANDERSON: I have three of these and I will check
25 with you later on and see which ones. If there is something

1 missing, I will try to get it to you after the meeting.

2 I just might mention what has happened in the
3 interim. Most of the Mark II owners have been able to
4 accommodate this load specification without any real problem.
5 A few had some little areas up at the higher elevations and
6 they have agreed with the use of the pool swell model, but with
7 a couple of constraints based on the 4T data.

8 This is the last slide.

9 Again, they would use the pool swell model up to
10 the point that, based on 4-T data, you could get some maximum
11 wetwell pressurization. And that maximum wetwell
12 pressurization would determine, based on the maximum upload
13 on the diaphragm, this is the differential between the wet-
14 well space and the drywell and we have a criterion for that
15 and the associated drywell pressure. And you combine those
16 two and come up with a maximum wetwell pressure.

17 So you run the pool swell model until you get
18 that maximum wetwell pressure and you would not run it
19 higher than that.

20 There would be one other constraint that they put
21 on this. That is that you would not use a lower termination
22 height than 1-1/2 times the vent submergence.

23 (Slide.)

24 We requested that they check that methodology
25 against selected Phase 1 and 2 4T tests. We picked out the

1 ones where we thought that they would have the most difficulty
2 in calculating using that methodology and we concluded after
3 they did that comparison that the methodology was, in fact,
4 conservative.

5 We should point out one thing: That in one case
6 for saturated vapor run no. 35, the measurement did exceed
7 the calculation, methodology calculation by about 6 inches.

8 However, in light of other conservatisms, we still
9 felt that the pool swell that revised alternate criteria
10 was acceptable. Those other conservatisms included
11 conservatisms in the 4T tests, conservatisms in the methodology
12 for calculating the drywell pressurization when you use the
13 model according to this NEDM-10320 prescription, when you
14 use that on an individual plant.

15 In addition, one should point out that the
16 measurements do bound also the froth measurements, not just
17 when the pool is as a solid ligament. And you do not really
18 get any substantial loads at that point. And that froth
19 region is the order of magnitude of maybe about a foot.

20 One other point is that, typically, design breaks
21 are saturated liquid breaks where you have much more
22 conservatism in the methodology.

23 Run no. 35 happened to be a saturated vapor run.
24 One limitation on the whole thing is that there is some
25 freedom that the Mark II owners have in how they would do their

1 drywell pressurization calculation as an input to the pool
2 swell model.

3 We had checked this methodology by checking the
4 two together with the conservatisms of NEDM-10320. Should
5 something else be used, that does not have these types
6 of conservatisms in it. Then they should take that
7 combined drywell pressurization models with the pool swell
8 model and do the same type of check.

9 But if they use this methodology, we find it
10 acceptable.

11 (Slide.)

12 Just for background purposes, this is the test data
13 that was used for that comparison of the methodology,
14 comparing that methodology, the measured height against the
15 calculated height for Phase I 4T test. And you know that
16 this shows two points that are above the specification.

17 However, one should recall that they have resized
18 the model to say that you will not be less than 1-1/2 times
19 submergence. This is 11-foot submergence. You go over here
20 and it does bound all of this one point, which is just a
21 little bit above. And one sees that for the Phase II test,
22 again, that the methodology is conservative.

23 (Slide.)

24 And then the last of the pool swell related area is
25 the asymmetric pool boundary load. This is the bubble pressure

1 related pool boundary load that could potentially result in
2 circumferential variations and steam as it goes in the
3 drywell and then into the vents.

4 There was not originally any specification in the
5 DFFR. We felt that it should be addressed. We came up with
6 an excessively conservatively specification based on some
7 of the earlier proposals for the Mark III.

8 And what we had ended up specifying was that all of
9 the air would be vented on one-half of the containment, all
10 of the steam on the other. And that would result in
11 maximum bubble pressure from all of the air on one side as
12 calculated by the pool swell model at the time of vent
13 clearing on one side, and then assuming complete condensation
14 of steam on the other, zero pressure on the other side.

15 We recognize that this was a very conservative
16 specification.

17 (Slide.)

18 A revised specification was proposed, and as a
19 result of our review of that, we concluded that 20 percent
20 of that maximum calculated bubble pressure vent clearing would
21 be acceptable.

22 That is 20 percent of the bubble pressure on one
23 side and nothing on the other. And the basis for that are
24 some calculations that were done, and also some qualitative
25 arguments. The calculations were based on a simple two-vent

1 model where one assumed a break that occurred close to one
2 of those vents.

3 The steam exiting from that break would undergo
4 homogenous mixing with the air. That homogenous mixture
5 would go -- would enter the first of the air, initially
6 air-filled vents.

7 Immediately, it would move at a speed such that in
8 4/10ths of a second, the second vent would be supplied with
9 that homogenous steam-air mixture and be supplying compressed
10 air to the far vent up to the 4/10ths of a second.

11 At 4/10ths of a second, it was inferred from a
12 couple of things. The maximum distance between two vents for
13 a Mark II facility and the velocity of propagation of the
14 steam front was inferred from some PWR 1/64th scale tests
15 where they had similar shock velocities. And they estimated
16 the velocity of the --

17 DR. YAO: How do you determine the 4 seconds?

18 DR. ANDERSON: That came from two areas. It came
19 from looking at the Battell tests, the 64th scale Battell
20 tests. One can infer what the steam front velocity was.
21 And then you can pick out what the worst distance is between
22 two vents.

23 And they came up with 4/10ths of a second.
24
25

BWH

1 You mean two tenths?

2 DR. ANDERSON: That gave us a good idea of what
3 the steam front velocity would be, the Battelle test.

4 DR. YAO: What is the scale?

5 DR. ANDERSON: 1/64th.

6 DR. YAO: You are talking about a time constant,
7 actually, uniform for all of the scales, scaled down test.

8 DR. ANDERSON: What they did was they looked at
9 the shock wave velocity for the two facilities, for a
10 prototypical Mark II and also for that facility.

11 DR. ZUDANS: But the .4 would be significantly
12 long time for this process anyway, so it probably wouldn't
13 matter how much longer.

14 DR. ANDERSON: This model had a number of other
15 conservatisms in it. It is kind of a difficult thing to get
16 a handle on. And we felt we should make some attempt to
17 upper bound this thing, so that is what they did.

18 DR. YAO: It is a conservative estimate.

19 DR. ANDERSON: Yes.

20 DR. YAO: Thank you.

21 DR. ANDERSON: Actually, in their calculations
22 they came up with no more than 10 percent of the maximum air
23 bubble pressure as this asymmetry. We tried to reproduce
24 that using the pool swell analytical model and our
25 consultants weren't able to come up with exactly the same

BWH

1 number. They came up a little bit higher. And rather than
2 spend a lot of time on this the Mark II owners did agree to
3 the use of the 20 percent because they could accommodate
4 this without any major problem. That was the basis for
5 that.

6 There are some other qualitative arguments, as I
7 indicated, for our not having substantial maldistribution of
8 the steam air that would give this bounding, instead of the
9 specification we had before including if we had a break it
10 would be turbulent flow and some good mixing. In addition
11 there are enough structures so that you would -- that would
12 aid in the mixing process. And they took a look at the
13 Marciken data. It is hard to infer much from this but they
14 did not see any major pressure variations within the
15 Marviken multivent test.

16 That concludes my presentation on the alternate
17 LOCA loads. Now I will turn it over to Dr. Economus from
18 Brookhaven.

19 DR. ZUDANS: Could I ask a question?

20 DR. PLESSET: Before we let you go, let's see if
21 there are any questions.

22 DR. ZUDANS: All of this reasoning, really, in
23 bounding the asymmetric boundary loads was based on
24 non-uniform -- let's say time lag in feeding one of these
25 two vents. What about the aspects that would be subsequent

1030 317

BWH

1 to this type of deal, where you have variable submergence at
2 the same time?

3 DR. ANDERSON: Recognize that we did talk about
4 potentials for variable submergence. If you want to talk
5 about that some more I guess we could. There are various
6 things that can result in asymmetries. There is an
7 asymmetric chugging load. There is an asymmetric safety
8 relief valve load. This one, we believe that that was taken
9 care of. All of the other ones were taken care of. This
10 one just deals with an asymmetric bubble load because of
11 different steam content in different parts of the
12 containment.

13 DR. ZUDANS: Because of time lag, but let's say if
14 you reduced the asymmetric pool swell itself. That
15 situation would reinforce the asymmetry because you would
16 not -- you would have the vents at a different level.

17 DR. ANDERSON: But you can get into a number of
18 different arguments that if you have low submergence and you
19 are going to have a quicker clearing time. And this is the
20 one that we concern ourselves with. We did not impose --
21 what is the mechanism for the variable submergence?

22 DR. ZUDANS: Thank you.

23 DR. MARK: Just a matter of semantics. You take
24 the pressure going back to your first item here, at the
25 downcomer level at 24 pounds and extrapolate it to zero at

BWH

1 the pool service. Is that the original pool service or the
2 service that the pool might get to after you empty the
3 downcomers? What is the basis for saying the original is an
4 adequate fixed number there?

5 DR. KUDRICK: When you are talking about this you
6 are talking about very early, at the time of vent clearing.
7 You don't have much motion at that time.

8 DR. MARK: This is a phenonena that you are
9 worried about before there has been any actual fluid
10 displacement.

11 DR. KUDRICK: That's correct.

12 DR. ANDERSON: Any other questions?

13 DR. PLESSET: Any other questions? Thank you.

14 DR. ECONOMUS: I am from Brookhaven national
15 laboratories. In the area of alternate load for SRV the
16 only open issue is the so-called load case five. And I
17 would like to give a little bit of background on what that
18 is.

19 In NUREG-0487, each of the applicants was required
20 to do design evaluation for a series of load cases. There
21 was the single valve and so on, and load case five required
22 that the evaluation be done for an all-valve case where all
23 of the bubbles are assumed to enter simultaneously and
24 oscillate in-phase. In addition, pressure loads would be
25 computed using the Ramshead model. The amplitudes would be

BWH

1 combined from the various valves using absolute sum and a
2 range of bubble frequency would be considered.

3 Now, as Cliff indicated earlier, this NUREG
4 specification was developed prior to any information
5 regarding the actual performance of the T quencher, which
6 would be utilized by the lead plants. And so the use of
7 Ramshead model for estimating the bubble pressure, bubble
8 amplitude. We recognized that was conservative but in the
9 absence of any definite information as to the performance of
10 the actual device that would be used, this was the only
11 alternative we had.

12 (Slide.)

13 The lead plant had done evaluation for all valve
14 load cases. However, phasing was -- there was phasing
15 permitted in these all-valve load cases that came from
16 mechanistic considerations taking into account different set
17 points, line volumes and so forth. The results of those
18 design evaluations showed that the containment was
19 adequate.

20 The lead plant applicants felt that the use of the
21 Ramshead loads combined with this simultaneous in-phase
22 oscillation was excessively conservative and they proposed
23 an alternative which consisted essentially of satisfying the
24 criteria of NUREG-0487 for load case five in terms of the
25 simultaneousness of the bubble and the in-phase oscillation.

BWH

1 that replacing the pressure loads with something that more
2 realistically represents the performance of the T quencher.

3 (Slide.)

4 I think you all know that the lead plants have
5 committed to the use of this so-called KWU T quencher, and
6 our evaluation of this alternative is that it does comply
7 with all aspects of the criteria with the exception of the
8 use of the pressure amplitude basemat and the T quencher
9 load, T quencher results which were obtained experimentally,
10 and again, the frequency range which bounded all of the
11 frequencies that had been observed. And 329 more correctly
12 represents what was observed with the T quencher.

13 DR. CATTON: What about plants other than the lead
14 plants?

15 DR. ECONOMUS: Yes.

16 DR. KUDRICK: WPPSS-2 has the GE X-quencher, which
17 is supported by the CAORSO test program.

18 DR. PLESSET: Is that the only one?

19 DR. KUDRICK: That we are aware of.

20 DR. ZUDANS: It is not Ramshead. It is quencher.
21 The question was with respect to Ramshead.

22 DR. ECONOMUS: Anyway, if the alternative proposal
23 is acceptable the pressure amplitudes that are utilized,
24 that they propose to use in the design evaluation, are
25 supported by the results of the KWU tests and similarly the

BWH

1 frequency range which is proposed to be used for design
2 evaluation is also supported by the results observed at KWU.

3 (Slide.)

4 The current status as far as the design evaluation
5 is concerned, the lead plant applicants have taken this new
6 T quencher load specification and have done design
7 evaluation for piping, particularly for critical piping
8 systems, those in the frequency range of the particular T
9 quencher device, and have found that the design is
10 adequate. Shoreham has documented the evaluation formally.
11 The LaSalle and Zimmer plants made a presentation at a July
12 meeting and we expect that documentation for the piping
13 systems evaluation will come in by the third quarter.

14 All of the lead plants are currently making their
15 evaluation of the — of their equipment. They indicate to
16 us that the design is adequate and we are not too certain at
17 this point when that evaluation will be in a document, but
18 it should be in the not-too-distant future.

19 DR. ZUDANS: Just one question. In terms of this
20 frequency from three to nine cycles, that has been now
21 observed based on KWU tests, are there any structures
22 sitting in that pool that would have natural frequencies in
23 that range?

24 DR. ECONOMUS: There may be, but they indicate
25 that their structures are capable of taking these —

BWH

1 DR. ZUDANS: That is not the question. The
2 question is, are there any structures where there is reason
3 to believe that —

4 DR. ANDERSON: The downcomers currently are
5 somewhere below the 7 hertz.

6 DR. ZUDANS: They are in that range.

7 DR. ANDERSON: Yes, I believe so. I am not
8 familiar with other ones. There may be some other ones.

9 DR. ZUDANS: There is not much else there,
10 anyway.

11 DR. ANDERSON: Right.

12 DR. ZUDANS: Thank you.

13 DR. ECONOMUS: If there are no other questions, I
14 will turn it over to Professor Bienkowski of Princeton, who
15 is going to update you on alternate submerged structure drag
16 loads.

17 DR. PLESSET: We may want to hear from the owners
18 groups about this natural frequency question.

19 DR. ZUDANS: And associated questions.

20 DR. PLESSET: Later.

21 DR. ANDERSON: I believe in the discussions of the
22 downcomer design, we will be hearing some discussion with
23 regard to the natural frequency.

24 DR. PLESSET: That's good.

25 DR. BIENKOWSKI: I guess I wasn't informed that I

1030 323

JBWH

1 was supposed to have copies of the slides for everybody, so
2 I am afraid I didn't bring any. Maybe we can try to get
3 some later today and give them to the committee later.

4 DR. BATES: If you get them to me I will
5 distribute them to people.

6 DR. BIENKOWSKI: I am sorry about that.

7 (Slide.)

8 I would like to talk about an update on the
9 submerged structure loads. The first slide just sort of
10 gives an outline of the format that I would like to use.
11 The first thing I would just bring you up to — to remind
12 you of what the origin of the loads is. I will go over them
13 rather quickly because we presented that in November. I
14 have a slide showing the history of the load specification,
15 which essentially corresponds to the next four items, which
16 is the initial owners' methodology, what the NRC acceptance
17 criteria were, what the owners' response on some of those
18 issues were where they did not wish to accept the criteria
19 directly, and finally as to what the supplement to
20 acceptance criteria will show.

21 I have additional slides in more detailed
22 technical basis for these various things and I will only
23 show those if there are specific questions on those issues
24 where somebody has a specific question as to the basis.

25 (Slide.)

BWH

1 This one, I would like to go over very quickly.
2 This is a slide I had in November and you have already seen
3 the origin of the loads for other LOCA earlier on
4 SRV-related loads. These are really the same. There is a
5 vent clearing phase where a jet comes out of the vent.
6 There is an air bubble formation phase where LOCA, where
7 bubbles of entry coalesce and pool swell for SRV, where
8 bubbles which separate and oscillate and rise up, and all of
9 these can induce submerged structure loads.

10 And finally, there is a steam condensation
11 oscillation chugging loads. These were left in the
12 acceptance criteria to be plant-unique, and I believe they
13 still are; however, the owners have indicated more or less
14 the direction in which they are going from these loads, so
15 when the occasion arises, I will just indicate a little bit
16 about that although we have nothing informal that we have
17 been able to evaluate on that.

18 (Slide.)

19 This slide is mainly to show you where the
20 information is that indicates the history of the load
21 specification submerged structures. The initial proposed
22 methodology was essentially based initially on the DFFR and
23 at least at the time of the writing of the NUREG-0487 an
24 applications memo which give specific ways of calculating
25 submerged structure loads, I believe was later incorporated

BWH

1 in supplement three to DFFR.

2 The NRC acceptance criteria essentially accepted
3 the major procedures of the owners' proposed methodology but
4 had a fair number of small exceptions and changes to
5 guarantee conservatism in application of these. These
6 essentially involved jet loads, the computation of the
7 induced pressure arising at the jet front and acceleration
8 drags that could be produced from this in front of the jet.

9 The second issue which was a fairly major one had
10 to do with what are the appropriate standard drag
11 coefficients and the issue there was essentially one of not
12 wishing the owners to use only data from steady flow, but
13 rather using drag coefficients from flows which were more
14 like the flows induced by LOCA or SRV, either oscillating or
15 accelerating flows, the result of the issue of interference
16 effects between structures which were sufficiently close to
17 each other.

18 And finally, there was an issue -- the owners
19 propose to use the velocity calculated, the geometric center
20 of the structure, as an equivalent uniform flow for
21 computing drag on structures. The NUREG criteria said, it
22 is not always conservative, certainly if the structure is
23 very large, and it has some flow which is substantially
24 higher over portions of it in the geometric center and the
25 proposal was to use the highest velocity rather than the

BWH

1 geometric center. This produced, apparently, quite a lot of
2 difficulty in terms of the implementation for the owners
3 because there are many sources and it is sometimes difficult
4 to find exactly where the highest velocity would exist in a
5 structure. And so they wanted to — they proposed an
6 alternative way of showing how small a segment they had to
7 divide the structures to still be able to use the geometric
8 centers. So that is why we are calling this nodalization
9 now.

10 All of the acceptance criteria, of course, are in
11 NUREG-0487. Now, the owners' response has been more or less
12 in a direction of some of the issues that we have raised in
13 the acceptance criteria. They have just accepted directly.
14 Others, they have addressed the concerns but have chosen to
15 do it in a somewhat different way than the way that was done
16 in the acceptance criteria.

17 And the main information for this is in a draft
18 report that Cliff Anderson mentioned. That is not yet, I
19 believe, in formal form. We have a draft report on submerged
20 structure methodology.

21 DR. CATTON: Are you going to tell us what areas
22 they have an alternative formulation for?

23 DR. BIENKOWSKI: Yes, I will discuss that.

24 (Slide.)

25 What I think I will do is I had some more slides

BWH

1 reviewing the — what the owners' original methodology and
2 acceptance criteria were, but I think what I will do instead
3 now is go through the water jet loads, bubble loads,
4 condensation loads one by one and highlight only those areas
5 where there has been some difference, where there is some
6 alternative methodology that the owners are proposing.

7 (Slide.)

8 In this particular case, things have been changing
9 rapidly, so since I made this slide there has already been
10 — some of what I am saying is not quite accurate.

11 The original NRC acceptance criteria for LOCA
12 water jet loads was, as I mentioned, primarily to modify the
13 strictly one-dimensional model which was in the owners'
14 methodology to include induced flow at the jet front. It
15 was a pressure induced by the accelerating water out in
16 front of the jet. And to include the acceleration drag as
17 well as the steady drag for SRV jet loads — we felt that
18 these were not going to be a very important point and we
19 proposed a sphere of influence around the quencher arm where
20 if no structure was in the sphere of influence, or did not
21 have to consider jet loads — the owners' response, I
22 understand, now for all lead plants is for the LOCA jet
23 loads they will essentially follow the NRC acceptance
24 criteria.

25 So there is — there was at one time talk of one

BWH

1 plant following a plant-unique path of using the ring vortex
2 model. This, I believe is in the long-term program. The
3 owners did propose in the SRV quencher jet load to modify
4 the sphere of influence, rather a cylinder of influence
5 around the quenchers to a five-foot cylinder.

6 We have examined this, based on test data, and
7 found this acceptable.

8 (Slide.)

9 DR. PLESSET: Has the staff looked at this vortex
10 analysis?

11 DR. ANDERSON: We have done some preliminary
12 review of it. We have not received any reports dealing with
13 how the methodology would be applied to plants, but just a
14 basic description of it. Perhaps Professor Bienkowski might
15 want to say something about preliminary observations. Would
16 you want to hear that?

17 DR. PLESSET: Sure.

18 DR. BIENKOWSKI: I think —

19 DR. PLESSET: I think the owners group may talk
20 about this, too.

21 DR. ANDERSON: They have no formal presentation.
22 Only in response, I think, to your questions.

23 DR. PLESSET: Fine.

24 DR. BIENKOWSKI: I have examined some formal
25 reports on the ring vortex model and on the basis of that,

PBWH

1 not the issue of how it would be applied to actual plants,
2 the phenomenological influence of what is going on, it
3 appears that the comparison to EPRI data seems good,
4 including things like pressure time histories on the floor.

5 The difficulty, as I saw it, with that and how it
6 would be applied to plants that the methodology is
7 essentially formerly rigorously valid only up to the time of
8 vent clearing. And therefore it cannot say much more to --
9 it leaves sort of a space between when do you go from the
10 jet model to the air bubble model and the time of vent
11 clearing is not the time of maximum pressures necessarily,
12 maximum accelerations in the pools.

13 So the issue there was, how would it be applied to
14 plants in a conservative way to take care of the transition
15 from the jet model to the air bubble model. As I said, this
16 is all based on a relatively brief informal report at this
17 stage.

18 DR. CATTON: I noticed in looking through, in
19 Chu's model and all of his predictions, they were never
20 carried to the peak pressure that was measured.

21 DR. BIENKOWSKI: Because that occurs after vent
22 clearing in his model, he is not capable of directly in the
23 model of taking -- when all of the water has come out of the
24 vent and air is now entering into the jet and mixing with
25 the jet, he is not capable of carrying that calculation

BWH

1 within his model. He cannot have two-phase flow.

2 DR. CATTON: Then the model doesn't really help
3 you a whole lot, if you are interested in the peak load.

4 DR. BIENKOWSKI: That is the issue I was referring
5 to about the transition. If you really ask yourself, what
6 is the transition, when do you go from a jet to the air
7 bubble, there is always a problem in any one of these
8 models.

9 DR. CATTON: I guess I would have to say that I am
10 not convinced that the peak load occurs after the air bubble
11 begins to grow.

12 DR. BIENKOWSKI: In all of the data analysis with
13 EPRI the peak load occurred after vent clearing, and indeed
14 all of the comparisons of Chu's models carried only as far
15 as air clearing. He has some — that part I have not
16 heard. He has some ways of trying to take account after
17 vent clearing and predict what the pressure is, and I have
18 seen some slides which I would hate to stake my reputation
19 on, because I have just seen some slides showing the
20 continuation beyond the up-to-peak pressure and so bounding
21 the peak pressure as well, but that is something that I have
22 not seen the details.

23 Up to vent clearing, all of his pressures have
24 been not only bounded the EPRI tests, but have actually
25 followed the trends very well.

BWH

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

DR. PLESSET: Peak loads where? Which peak loads
are you talking about?

2-3

O

BWH

1 DR. BIENKOWSKI: Take loads off the pressure on
2 the bottom, the basemat.

3 DR. PLESSET: Other comments?

4 DR. WU: Is there any preliminary -- any follow up
5 work after the -- my question is, has there been any follow
6 up work right after the vent clearance, followed by the
7 bubble expansion into the lower plenum?

8 DR. BIENKOWSKI: Maybe the Mark II owners can
9 respond to that better than I can.

10 DR. PLESSET: That is a good point. We will let
11 them talk about that when they make their presentation. We
12 don't need to --

13 MR. KUDRICK: They have no presentation on the
14 point.

15 DR. PLESSET: But they are willing to talk, I
16 guess, when they get their turn.

17 DR. CATTON: I have one more comment. The report
18 by GE, "Analytical Model for Liquid Jet Properties for
19 Predicting Forces on Rigid Submerged Structures," discusses
20 the particular process of transient formation of a jet.

21 DR. BIENKOWSKI: That is the one dimensional
22 model.

23 DR. CATTON: They refer to data or observations
24 which indicate a physical process that is somewhat unlike
25 what is modeled in Chu's paper. I am wondering if there are

CBWH

1 any attempts to bring the two closer together. One is on
2 one extreme, and I think the other is on the other extreme.

3 DR. BIENKOWSKI: The NRC acceptance criteria
4 attempted to do that. The NRC acceptance criteria, we have
5 said you can use the model for the jet within the major
6 portion of the jet, but the front in this one dimensional
7 model has an infinite extent and is infinitely thin, because
8 when you do the conservation momentum, you get a shock front
9 at the front of the model where the particles catch up. So
10 you have said they must somehow model the front differently
11 by saying that you take whatever was in the mass at front
12 and create something like a hemispherical or spherical cap,
13 which propagates with a shock front and induces the flow in
14 front of it.

15 The idea was to allow for objects which are not
16 directly impinged by the jet, but still in front of the jet,
17 to feel some pressure, because this one dimensional model
18 would show no forces on an object until the jet had actually
19 impinged.

20 DR. PLESSET: But you are using the words "shock
21 front."

22 DR. BIENKOWSKI: It is used in there.

23 DR. PLESSET: That's good. I'm glad. But I would
24 think that some calculation like Chu's might be quite a bit
25 better than that until the vent is clear. What do my

GWH

1 experts say?

2 DR. CATTON: I would agree that this is at one
3 extreme.

4 (Laughter.)

5 DR. PLESSET: You don't disagree with it?

6 DR. BIENKOWSKI: I think in most instances this is
7 more conservative than Chu's model. I would say that the
8 physical phenomena after vent clearing is certainly better
9 represented by Chu's model.

10 DR. PLESSET: I think that is a good place to
11 leave it, until the owners group might want to make a few
12 comments.

13 DR. CATTON: I am not sure that Chu's work was on
14 the conservative side. If I had to make a guess, I would
15 say that it probably falls on the other side, and I am not
16 sure why. I am sure there is a great deal of numerical
17 confusion, so he is essentially looking at a — and his
18 model, even though he is attempting to model with this —

19 DR. BIENKOWSKI: The comparisons I have seen of
20 the propagation of the ring vortex, both forward and to the
21 side, comparisons with EPRI tests have looked quite good.

22 DR. CATTON: The EPRI tests are small diameter.

23 DR. BIENKOWSKI: I don't think the Reynolds'
24 number — I think it is high enough. I don't think real
25 viscosity — numerical viscosity is a separate issue. I

BWH

1 don't think real viscosity plays a very significant role.

2 DR. CATTON: The issue was not real viscosity but
3 numerical.

4 DR. BIENKOWSKI: The EPRI test did not have
5 numerical viscosity.

6 DR. WU: Is it proper to say that the Chu model is
7 almost on the best estimate, intended in that direction, and
8 the other is more conservative.

9 DR. BIENKOWSKI: That is what I was implying. I
10 think it represents the physical phenomena much more
11 closely, and the issue of how to guarantee that it is
12 conservative is what I was leaving to the issue of if and
13 when the Mark II owners want to use the model, and they want
14 to say how do you provide conservatisms into that to make
15 sure that all of the data is bounded. That is the issue of
16 what kind of a source terms — how you can provide
17 conservatism with a faster velocity with water-air
18 interface, and I think there clearly would be questions
19 answered as to just what numbers do you put in to provide
20 conservatism.

21 All I was really referring to is I think the basic
22 phenomena, in terms of what is going on, in terms of the
23 shape of the cloud, the time at which it happens including
24 the pressures on the floor, the phenomena seem to very well
25 model experiments up to that clearing.

BWH

1 DR. PLESSET: The analysis seems to be much better
2 in the sense that people call mechanistic. In other words,
3 it uses a real physical description, but there are these
4 points that Professor Bienkowski mentions.

5 DR. CATTON: I would agree with that, and the Mark
6 II owners, if they don't use it, it is academic.

7 DR. PLESSET: Yes, in a way it is.

8 DR. CATTON: An interesting academic problem.

9 DR. YAO: I have one comment. We generally know
10 the vortex type calculations, that it is unstable,
11 numerically unstable. But I think it has been demonstrated,
12 if you introduced a small numerical viscosity, you can get a
13 stable result and a result quite accurate.

14 DR. BIENKOWSKI: I think I will accept the comment
15 without additional comment.

16 (Laughter.)

17 DR. PLESSET: Why don't you go on?

18 (Slide.)

19 DR. BIENKOWSKI: I spent all of that time on what
20 I was not prepared to talk about.

21 (Laughter.)

22 On the LOCA air bubble which presumably occurs
23 sometime after vent clearing and is based on essentially a
24 spherical bubble, the original -- there were a number of
25 issues that we were -- addressed in the acceptance criteria,

BWH

1 and a couple of them were found acceptable by the owners,
2 and I will not discuss them again because I already
3 mentioned them in November.

4 We wanted to provide additional conservatisms
5 associated with the bubble asymmetry, since the model is
6 based on a symmetric bubble, and the data indicates they are
7 not that symmetric. Another was the blockage effects in the
8 pool swell portion. These are sort of typical wind tunnels
9 which you have for drag due to the fact that the flow is
10 constrained to flow between -- in tighter quarters.

11 These they found acceptable. I will not discuss
12 more about that.

13 The main three issues which not only refer to LOCA
14 but also SRV quencher air bubbles and condensation loads, I
15 will discuss all together instead of separating, because
16 they are essentially the same issue. What is the use of the
17 standard drag coefficient?

18 The Mark II owners proposed use of a steady flow
19 drag coefficient for the standard drag was not acceptable
20 because of data that indicated there are unsteady conditions
21 in certain situations. These drag coefficients could be
22 substantially higher than the steady flow coefficients. The
23 owner's response essentially has been -- and so we
24 propose -- I step back. We proposed essentially, based on
25 the data that we had available, that the owners either could

BWH

1 do more detailed study of this and produce, justify the drag
2 coefficients, or they could use what we considered
3 conservative upper bounds on these coefficients, which were
4 essentially like three, three times the standard drag
5 coefficient, which was bounding all of the data we had
6 available at the time.

7 The owners have essentially proposed to do this
8 differently for LOCA and for SRV. The reason is actually
9 quite sound. A LOCA situation is essentially a uniform
10 accelerating flow where the flow direction and the
11 acceleration are in the same direction, and, in deed in
12 both of those instances, the drag coefficient, if anything,
13 is slightly lower than higher for such an accelerating
14 flow. So they want to use the data for such a uniform and
15 impulsive flows for the standard drag coefficient, and that
16 brings them back to using the steady flow drag coefficient.

17 However, for SRV bubbles and for condensation
18 oscillation loads where the flow actually oscillates back
19 and forth, there is a flow reversal. The appropriate data
20 is data from oscillating flows. And in those situations,
21 that is where the upper bound factor of the three came
22 from. They will, indeed, use the relevant data so that they
23 will use the drag coefficient appropriate for the particular
24 period parameter. This is a function of the period
25 parameter, which is nothing else but the velocity times the

BWH

1 period divided by the diameter of the body.

2 And, indeed, it makes sense to do that, because
3 for many of the larger structures, this parameter is quite
4 low, and the drag coefficient of three times the steady flow
5 coefficient would have been ultraconservative in those
6 situations. It turns out that to some extent for many
7 structures it is a non-issue, because for large structures
8 it is acceleration drag that is important, not the standard
9 drag.

10 So you are talking about worrying about a factor
11 of three on something that is only ten percent of the total
12 load.

13 The other issue that was raised in the NRC
14 acceptance criteria were interference effects. And, again,
15 we provided a rather — the possibility of a conservative
16 bound, saying that the structures were closer — if the
17 structures were further apart than three diameters of the
18 largest structure, they did not have to worry about
19 interference effects.

20 But for structures closer than that together, they
21 could either do a detailed analysis or have a conservative
22 multiplier which is essentially a factor of four on the
23 dragage, which came for structures which clearly were very
24 close together. They chose, again, not to use the
25 conservative multiplier, and, indeed, the draft report, as I

BWH

1 mentioned — about two thirds of the report is based on a
2 fairly detailed literature study of the information
3 interference effects and categorizing of different
4 conditions.

5 So they have answered by saying they will use
6 appropriate data and analysis for those four structures
7 which are closer than three diameters.

8 DR. BUSH: For clarification of the statement
9 regarding the LOCA being different, is that equally
10 applicable to a small LOCA. I would think you could get
11 fluctuation effects.

12 DR. ANDERSON: You get the same kind of strain
13 phenomena for the condensation oscillation over range.

14 DR. BIENKOWSKI: I think the question was about
15 the air bubble.

16 DR. ANDERSON: We don't think we get any
17 substantial air bubble.

18 DR. BIENKOWSKI: Those loads, the air bubble
19 loads, would be bounded by the DBA loads. Even if they were
20 there, I would assume --

21 DR. PLESSET: I think Dr. Bush's point was, have
22 you really thought carefully about any problems that might
23 arise from something smaller than the DBA? Isn't that what
24 you were thinking, Spence?

25 DR. BIENKOWSKI: In connection with submerged

BWH

1 structures?

2 DR. PLESSET: Or any other part of the containment
3 problem.

4 DR. BIENKOWSKI: Certainly, I think chugging
5 loads. Everybody agrees that it is not the DBA that is the
6 bounding consideration. I think I am going outside of my
7 expertise to answer other parts of the submerged structure.

8 MR. KUDRICK: Relative to chugging, it really does
9 not matter whether it is a small break, medium break, or DBA
10 break. You have basically the same phenomenon when you get
11 into that flow regime. CO is more pronounced at the higher
12 mass fluxes, so it is more conservative looking at it from
13 the DBA standpoint. So we have looked over these loads over
14 the spectra to ensure that we have selected conservative
15 breaks.

16 DR. PLESSET: I think that is the answer that we
17 want to hear -- that you have thought about it.

18 DR. BIENKOWSKI: In connection -- as a matter of
19 fact, I was somewhat deficient in explaining all of the
20 details, because I didn't want to get into all of the
21 them. Actually on the LOCA air bubble, when they get to the
22 pool swell portion where the pool rises and comes back down,
23 they do, indeed, consider that to be half a cycle of an
24 oscillatory flow and use the drag coefficients from the
25 oscillatory flow, even for a regular LOCA. It is the

BWH 1 expanding bubble portion they consider to be a uniform
2 accelerating flow.

3 (Slide.)

4 I did not mention the issue that we addressed in
5 the acceptance criteria with the equivalent uniform flow
6 assumption. That is to be applied at a geometric center. I
7 think the issue there was really a question of geometric
8 center of what, and we tried to cover that and be
9 conservative by saying for any particular segment of the
10 structure, just take the maximum flow velocity and use that
11 position. That turned out to be not easily implemented, so
12 what the Mark II owners have done -- and it is also included
13 in the draft report -- they have done a sensitivity analysis
14 of segmenting structures into smaller and smaller segments,
15 basically a numerical study to find out at what point the
16 load, the total loads, in a structure no longer change.

17 They included structures -- the ones that were
18 going to be closest to the sources. It turned out as long
19 as you kept within one to two diameters of the structures,
20 the loads were changed by only a fraction of a percent or so
21 for going to any tighter segmentation. And I will talk
22 about this when we talk about the supplement. We will find
23 that procedure essentially acceptable.

24 DR. ZUDANS: When you say about segmentation,
25 meaning then you would use some geometric center for each of

BWH

1 the segments, rather than look for maximum velocity for
2 something that is non-describable.

3 DR. BIENKOWSKI: They are going to use the
4 geometric center. The difficulty with the maximum velocity
5 was not so much that most of the structures are long
6 cylinders, pipes, downcomers, so it wouldn't be too hard to
7 find where the geometric center or the maximum velocity was,
8 if I had only a single source and a single structure.

9 The difficulty is that in their numeric model, you
10 may have a structure, but you have many sources. And so now
11 if you take literally what you mean by the maximum velocity
12 point, you sort of have to hunt where that maximum velocity
13 point is. It turns out that if you segment the structures
14 in segments of about one diameter to one and a half
15 diameters, the effect -- there are theoretic studies to show
16 that if you have a nonuniform flow and you have a cylinder,
17 just a nonuniform flow, that taking the geometric -- the
18 velocity of the geometric center is conservative or at least
19 for theoretic calculations, is actually -- it is correct to
20 pick the velocity at the geometric center for the
21 acceleration drag at least.

22 DR. ZUDANS: The segmentation is longitudinal?

23 DR. BIENKOWSKI: Yes.

24 DR. ZUDANS: You pick a piece and then the
25 geometric center and so forth, rather than taking the entire

BWH

1 structure and picking a single geometric center?

2 DR. BIENKOWSKI: Clearly, if there was a pipe and
3 the source was here and you picked the geometric center, you
4 would not necessarily be conservative. That was clearly the
5 concern that we were trying to address in the acceptance
6 criteria by placing restrictions on the segmentation of
7 about one to one and a half diameters. We feel that concern
8 has been met.

9 DR. ZUDANS: There is no segmentation within each
10 of the segments?

11 DR. BIENKOWSKI: No, they are treated as
12 cylinders.

13 DR. ZUDANS: Since this is on velocity, there was
14 a discussion of fallback velocity. Are you going to talk
15 about that, or it doesn't represent part of your
16 presentation?

17 DR. BIENKOWSKI: The issue of the fallback
18 velocity is not part of my presentation. The treatment of
19 the submerged structures during that portion, they treat
20 essentially as -- by the same procedure, the drag
21 coefficient chosen for oscillating flow.

22 DR. ZUDANS: I would have one question, but maybe
23 there is some other question for it. The question is, the
24 draft report says that velocity will be based on the free
25 flow velocity throughout the upper surface shown directly

BWH 1 above the subject structure. I am thinking in terms of --
2 that sounds to me okay.

3 DR. PLESSET: Hold that until tomorrow. That is
4 Mark I.

5 DR. BATES: That is Mark I acceptance criteria.

6 DR. PLESSET: We will get to that for sure.

7 DR. ZUDANS: I would say that Mark II has the same
8 question. I have just used the words out of that section.
9 There is presumably a similar situation for fallback
10 velocity in Mark II, and if it is calculated from what
11 point. It is from a point that the water reaches and it
12 starts falling back or what happens if it impacts some
13 structure? It is under some angle? Is that impact velocity
14 then taken into consideration? And you can impact laterally
15 structures with higher velocities than you expect the
16 fallback velocity would be.

17 DR. ANDERSON: I don't understand the full
18 question, but as I recall the point for calculating the
19 velocity was the point of maximum elevation. Did I miss
20 some of the other points?

21 DR. ZUDANS: Maybe it does not have application to
22 Mark II as clearly as it does in Mark I.

23 DR. PLESSET: That's right. The question is not
24 without meaning, but I think it is significant really for
25 Mark I. So I think we will get some --

BWH

1 DR. ZUDANS: Tomorrow.

2 DR. PLESSET: Right.

3 DR. BIENKOWSKI: I am almost done.

4 (Slide.)

5 This is a copy of a slide that was presented to us
6 by Mark II in terms of how the concerns in connection with
7 the drag coefficients interference effects, and nodalization
8 has been addressed.

9 I am putting it up for those of you who may want
10 to know where the data and references are. For the unsteady
11 flow, we basically have two sets of references:
12 accelerating flow and oscillatory flow. This is actual a
13 number of papers of Sarpkaya. I would actually myself add
14 also a paper by Keulegan and Carpenter, because that happens
15 to be the only paper that I know of that has sharp
16 structures rather than just cylinders. So it is important
17 for one of the issues.

18 Interference effects, they divided for standard
19 drag and accelerating drag. Some of these are theoretical.
20 This one is an experimental review paper. For accelerating
21 drag, it is mostly experimental, although there is also --
22 mostly theoretical, although there is some experimental work
23 by Sarpkaya.

24 These interference effects are basically of two
25 types: one, for structures close together; another for

RWH

1 structures close to walls. We — the NRC acceptance
2 criteria, we had included the transverse forces, lift
3 forces, as part of the conservative coefficient on the
4 drag. In other words, taking the maximum total force on
5 this subject, Mark II owners have chosen to separate these,
6 so indeed they are including the lift due to vortex shedding
7 and unsteady flow which can produce significant transverse
8 forces, at least for the oscillating type flow.

9 For most of these situations, the Mark II, for the
10 LOCA air bubble where the flow is just accelerating, most of
11 the phenomena are over before you have had enough time for
12 the vortices to separate, so there is no lift force.

13 But for the SRV and condensation oscillation, one
14 has to consider these.

15 I already discussed structural nodalization, and
16 essentially the owners have done a study showing that if the
17 length of a segment is on the order of one to one and half
18 diameters, the numerical values are not changed.

19 (Slide.)

20 To summarize, then, the supplement to the NRC
21 criteria requires no changes now in the net loads, since the
22 owners have effectively accepted them as they are for the
23 lead plants. On the LOCA and SRV air bubble loads, we find
24 the data and theoretical calculations for both the drag
25 coefficients and interference effects that the owners have

BWH 1 proposed for cylindrical structures are acceptable. They
2 are based on data relevant to those structures. For
3 non-cylindrical structures, the owners propose to just use a
4 circumscribed cylinder for computing correction factors
5 between, let's say, unsteady flow and steady flow or
6 correction multipliers for interference effects, and then
7 using those correction factors of the actual drag
8 coefficients for the particular structure it had.

9 We found this to be somewhat worrisome in the
10 sense that the little bit of data that is available for
11 sharp edged structures was clearly -- the vortex separation
12 is different for unsteady oscillating flow, which is the
13 Keulegan and Carpenter paper for a flat plate -- indicates
14 much higher drag coefficients compared to steady flow than
15 you would get from just the circumscribed cylinder.

16 So we have said we are accepting the draft report
17 for cylindrical structures. For structures with sharp
18 edges, we feel that drag coefficients or standard drag
19 should be taken from relevant data which, if they can find
20 other than Keulegan and Carpenter, we would be happy to
21 see. But if not, at least for something like flat plates
22 which at least has the effect of sharp edges in it, no lift
23 coefficient -- the other thing is clearly that if you have a
24 circumscribed cylinder, the only lift you can get is from
25 vortex shedding. But if I have a, let's say, an I-beam or a

BWH

1 rectangular structure on which the flow impinges at some
2 angle other than an angle of symmetry, I can get lift on
3 that structure even without worrying about the unsteady
4 effects.

5 So clearly doing the circumscribed cylinder does
6 not account for that effect. So in the supplement we would
7 include criteria that will require it to either get such a
8 lift coefficient from data or some approximate theory, or we
9 felt that a bound of something like 1.6 from all of the data
10 I have been able to see would clearly be a conservative
11 bound. And you would have the coefficient on a reasonably
12 non-streamline structure.

0 e 1

13
14
15
16
17
18
19
20
21
22
23
24
25

mte 1 On the quencher, the only issue there is what the
2 source strength — how the source strength for the quencher
3 is chosen. And that requires some evaluation. But it
4 appears that the procedure is essentially acceptable.

5 For condensation levels, we have only been given a
6 glimpse of the — as I said, these are to be plant-unique,
7 so they are not part of the NRC acceptance criteria at this
8 stage. We have been given only a glimpse of what direction
9 the Mark II owners are going. It appears that the approach
10 appears reasonable to us now.

11 The issue will certainly again revolve around what
12 is — all of the other issues are still there. The main
13 issue will be, what is the source strength.

14 DR. WU: Is it easy to define the
15 Keulegan-Carpenter number for this kind of problem,
16 involving bubble --

17 DR. BIENKOWSKI: The period parameter?

18 DR. WU: Yes.

19 DR. BIENKOWSKI: It is not for LOCA. They are not
20 using that data. It is clear it is going to be very hard to
21 say what you are going to do about sharp-edged structures in
22 uniformly accelerating flow. But it appears that
23 oscillating flow bounds things for uniformly accelerating
24 flow, and the only parameter that would be comparable in
25 accelerating flow would be the time times the maximum

RW mte

1 velocity, divided by parameter.

2 DR. WU: I thought in the original paper they used
3 the — they used the velocity farther away from the object
4 as relatively easy.

5 DR. BIENKOWSKI: You are talking about the
6 experimental issue.

7 DR. WU: Is it really significant? That's one.
8 And if it can be fairly well defined, then what is the range
9 of the Keulegan-Carpenter number cover for this type of
10 calculation. And thirdly, is it still following a similar
11 approach, namely, the linear position of the proportion of
12 the acceleration? And the other is to the absolute velocity
13 times the velocity type of drag coefficient.

14 DR. BIENKOWSKI: You can argue that the — in
15 dimensional analysis, you can argue it is invalid if you use
16 drag coefficient and acceleration coefficient as functions
17 of all other nondimensional parameters. So in a sense — so
18 the issue is, can I pick one drag and one acceleration
19 coefficient.

20 In the Keulegan-Carpenter and Sarpkaya's work, the
21 hydrodynamic coefficients vary with parameters. So you can
22 say it is not a totally linear superposition. You're asking
23 essentially a philosophical question. I don't know the
24 answer to your question. I wish there was more data, and
25 indeed, I don't know why there has not been more data, why

RW mte

1 rather than sharp edged structures.

2 It seems to me there is a very significant issue
3 of the vortex shipper separation with sharp edges that will
4 be quite different. I was referring to the only paper I'm
5 aware of, is the Keulegan-Carpenter paper. It is the best
6 data I know of. And it is true that it is probably subject
7 to some questions.

8 DR. PLESSET: Any other questions?

9 (No response.)

10 Thank you. And I think this would be an
11 appropriate time to have a ten-minute break. So we will
12 reconvene in ten minutes.

13 (Recess.)

14 DR. PLESSET: Let's reconvene.

15 I would like to say that Dr. Bates would
16 appreciate it if those who haven't signed this attendance
17 sheet before would do it as soon as possible and give it
18 back to him.

19 I think that we will go on with the rest of our
20 agenda, and we are going to go to presentations by the Mark
21 II owners group. And I think that Mr. Crawford is going to
22 start off. Is that correct?

23 DR. CRAWFORD: Yes.

24 DR. PLESSET: Before you begin, Mr. Crawford,
25

mte

1 Professor Bienkowski, you were going to give Dr. Bates your
2 slides, or somebody, so we can have them?

3 DR. BIENKOWSKI: We are getting copies.

4 DR. PLESSET: Fine.

5 Proceed, Dr. Crawford.

6 DR. BIENKOWSKI: My name is Ray Crawford. I am
7 from Sargent & Lundy, and I would like to speak with you now
8 and tell you what the status of our analysis and assessment
9 for the effects of the submerged structure loads on the
10 downcomer, main downcomer vents is.

11 I would like to follow what Mr. Anderson
12 introduced earlier, and I would like to briefly review the
13 type of design that is employed in LaSalle and Zimmer for
14 the downcomer bracing. We have a pre-stressed concrete
15 structure with an integral diaphragm floor. The downcomers
16 themselves are anchored into the diaphragm floor, and that
17 provided the main support for those downcomers against any
18 lateral loads acting on the downcomers, any dynamic lateral
19 loads.

20 In the case of LaSalle, there was a restraint or
21 bracing system just underneath the diaphragm floor above pool
22 swell, maximum pool swell height, and that equally
23 distributed the load on the floor for the lateral loads that
24 existed.

25 (Slide.)

RW mte

1 That system of design for the downcomers was
2 analyzed for the submerged structure drag loads of LOCA and
3 SRV according to the initial load specification, as
4 Mr. Bienkowski pointed out, contained in the DFFR. That
5 assessment included the effects of inertial drag, and it
6 also included the localization of the local flow field
7 effects.

8 The assessment of the structures to this load
9 definition was contained in the design assessment report
10 submitted approximately in the first quarter of 1976. More
11 recently, in 1978, to update the design assessment report,
12 there was a closure report prepared which accounted for any
13 changes in the load definition that was contained in
14 revision two of the DFFR, and it does provide additional
15 justification for the methods of predicting the submerged
16 structure loads.

17 We have not completed our assessment for providing
18 the results and assessment for all of the loads, and that
19 was to be contained in a design assessment report
20 amendment. At that time, all of our assessment work
21 indicated that the criteria was satisfied on all of the
22 structures.

23 There have been some recent changes, however, and
24 I would like to briefly review what those changes are and
25 what we are doing about them. There has been three rather

nte 1 significant developments since that time. One is the NRC
2 acceptance criteria. Secondly is the adoption of the KWU
3 T-Quencher for SRV discharge. And thirdly is the steam
4 condensation drag loads.

5 Mr. Bienkowski has summarized very well how we
6 have addressed the criteria for unsteady flow effects on
7 drag and lift for the interference effects and how we have
8 addressed the non-uniform flow field. In LaSalle and Zimmer
9 we do not have any sharp edged structures where we are
10 concerned about the vortex shed. We use round cylinders.

11 In the case of LaSalle and Zimmer, adoption of the
12 KWU T-Quencher for SRV discharges has required relocation of
13 all of the SRV lines, and so it is immediately obvious that
14 we would have to take into account the local effects caused
15 by the relocation of these lines.

16 It is true that the KWU T-Quencher produces lower
17 bubble pressures, and it is also true that the bubble
18 frequency or the oscillation of the bubble tends to go
19 toward lower frequency. And I want to come back to that in
20 just a moment. But let me finish here pointing out that,
21 for the LOCA steam condensation drag and the LOCA events, we
22 do consider the water jet and vent clearing as well as steam
23 condensation events of chugging and condensation
24 oscillation.

25 And in the case of condensation oscillation, the

BW mte

1 magnitude of that pressure oscillation is a low magnitude,
2 and it is also — the bubble oscillation is of low
3 frequency.

4 Now, the downcomer system that we assess to does
5 have some natural frequencies that are in the lower range,
6 and so these shifts of frequencies by the SRV discharge, as
7 well as the steam condensation flows, was of concern to us.
8 The natural frequency of the downcomer was, I believe,
9 around two or three hertz. And we felt that these loads,
10 with these lower frequencies, were something that we needed
11 to examine as to the impact on these structures.

12 And our approach to that was to consider the then
13 available criteria and apply it in a very conservative way.

14 (Slide.)

15 The load definition criteria that we used has been
16 explained in the closure report, and we have included the
17 acceptance criteria. And because of the frequency shift,
18 even though the magnitudes are low, we felt uncomfortable
19 without examining that further. And so we have been
20 considering a restraint system design for that downcomer.

21 The design of the restraint system that we are
22 looking at now — we have convinced ourselves that it can
23 accommodate the NRC recommendation for the lateral loads,
24 and so our concern at this point is simply to finalize what
25 that design will be.

RW mte

1 DR. PLESSET: What are your preliminary ideas
2 about that, about this restraint system? What kind of
3 restraint system will that be? Any idea?

4 DR. CRAWFORD: Yes. I can just briefly describe
5 it, and if you want more details, I can call on one of our
6 other people. But basically, we are thinking of a restraint
7 system design that is located near the pool surface. It
8 consists of eight-inch extra-strong pipe, tying the
9 downcomers together.

10 DR. PLESSET: I saw an arrangement in Japan where
11 they are tied together near the bottom of the downcomer.
12 Have you looked at that?

13 DR. CRAWFORD: We did look at that, and that is
14 what led us to examine a reevaluation of the lateral load
15 criteria, because the acceptance criteria for the lateral
16 load is a function of the frequency of the system, and
17 putting restraint down near the tip stiffens the system and
18 increases the lateral load. And we felt that we would be
19 better off to have a more flexible system by putting in the
20 restraint system near to the pool surface.

21 DR. PLESSET: Have you looked at that possibility
22 of where these restraints might be near the bottom or higher
23 up?

24 DR. ANDERSON: No.

25 DR. PLESSET: You are not concerned?

RW mte 1 DR. ANDERSON: We just haven't received any
2 substantial information.

3 DR. ZUDANS: On this question of natural
4 frequencies for your downcomer system, are these natural
5 frequencies computed considering the fact that these
6 downcomers are submerged?




7 DR. CRAWFORD: We have considered both the
8 submerged and the non-submerged, full of water and empty.



9 DR. ZUDANS: Do you have any concerns relative to
10 the effects of the interaction and therefore your load
11 definition? Your current load definition is based on rigid
12 boundaries?

13 DR. CRAWFORD: Yes.





14 DR. ZUDANS: Once you have a situation in range
15 where your resulting frequencies of load forcing function
16 and natural frequencies of structure which was assumed
17 originally, do you have any concerns about the validity of
18 such forcing functions?



19 DR. CRAWFORD: We have considered the coupled
20 system of the fluid and the structure and the net effect
21 that we have found from our analysis thus far would indicate
22 that the load would not be as severe as the way we are
23 currently doing it. And I was trying to stress that we have
24 taken, at this point in time, a very conservative approach
25 in the method of the load application. And it is our









**IMAGE EVALUATION
TEST TARGET (MT-3)**





**IMAGE EVALUATION
TEST TARGET (MT-3)**



RW mte

1 intention to pursue this further, to see if we can convince
2 ourselves as well as the NRC that perhaps there is not a
3 need for a very substantial restraint system on the
4 downcomers.

5 DR. BUSH: How do you handle vertical motion?

6 DR. CRAWFORD: On the restraint system?

7 DR. BUSH: On the downcomer. As I understand
8 your system, what you are doing is you are coming out with a
9 web, essentially, of piping, which I presume is welded to
10 the downcomer; or is it? I hope not, but I suspect it is.

11 DR. CRAWFORD: I don't believe it is.

12 DR. ZUDANS: I am not finished with my question.

13 DR. PLESSET: Identify yourself.

14 DR. SRINIVASAN: From Sargent & Lundy.

15 (Slide.)

16 DR. SRINIVASAN: This is one of the schemes we are
17 currently examining. This is a system where the downcomers
18 would be tied together, as Dr. Kudrick explained, by
19 eight-inch pipes. But you see here, they are tied to the
20 containment on one side and on the other side.

21 Now, we will include in the design of this system
22 any drag loads that you would have in either vertical motion
23 or lateral loads on the bracing members themselves. Those
24 will be incorporated into our design.

25 DR. PLESSET: Dr. Bush is interested in the

~~1030-60~~

1031-001

RW mte

1 attachment method. Weren't you, Spence?

2 DR. BUSH: Yes, I am concerned with the growth of
3 the downcomer. And then I have a situation where there are
4 a series of welds. So I get this kind of an accident with
5 the possibility of a tear-out.

6 DR. SRINIVASAN: We do consider that. The
7 connection to the containment is not rigid. It can transfer
8 shear forces. But it has a pin, so there is a rotational
9 capability of the system about the containment. So any
10 thermal growth is accounted for.

11 DR. BUSH: That would help on your seismic loads,
12 too?

13 DR. SRINIVASAN: Yes.

14 DR. ZUDANS: I would like to come back to the same
15 question. Then you say --

16 DR. PLESSET: This relates --

17 DR. ZUDANS: To the frequencies. This structure
18 is an interesting cartoon to look at.

19 (Laughter.)

20 DR. ZUDANS: A starship. I am concerned about at
21 least apparent lack of concern about the possibility of
22 resonances and feeding the energy into that vibration mode.
23 Now, maybe you have some test results where the downcomer
24 natural frequencies were in the range of condensation
25 oscillation frequencies, and maybe you can get some

1031 002

RW mte

1 observations from that. And when you have a range of
2 frequencies of a structure in the range of frequencies, the
3 only thing that can save you is damping. Otherwise, you can
4 feed regardless of how small your excitation course is. But
5 there is lots of damping.

6 But the question is raised, are there any tests
7 where you would have any such confirming answers, any tests
8 where you have structures that really had the actual
9 frequency in the range of exciting forces.

10 DR. CRAWFORD: I would like to try to answer your
11 question with two points I tried to make clear earlier. The
12 reason for us to consider the restraint design was to
13 stiffen up the downcomers, to get out of the frequencies of
14 the forcing functions. That was our first approach. And I
15 certainly concur with you that damping is a very important
16 part, and we are looking into that further.

17 But with the restraint system design that we see
18 here, that clearly moves up the natural frequencies of the
19 system above where the primary forcing functions are.

20 DR. ZUDANS: I would agree with that, there is no
21 question.

22 DR. CRAWFORD: The other comment that I wanted to
23 mention was that in the 4T test, where there was some
24 condensation oscillation observed, the natural frequencies
25 of that downcomer, I believe, was of the order of

1031 063

RW mte

1 7 to 10 hertz, something in that range, which is apparently
2 — apparently was close to the forcing functions observed in
3 that test. But it appeared — at this level of going into
4 the detail of that, it doesn't seem that that answers all of
5 our questions yet, that we can totally eliminate that. So
6 we are looking for additional analysis.

7 DR. ZUDANS: One comment more than a question:
8 Since this is not precisely quantified phenomenon as yet,
9 what effect it has, maybe you could think of some tests
10 where you could vary the frequency of the downcomer by
11 simply stiffening for the purposes of a test, and maybe you
12 will find out that all of your loads disappear laterally.

13 DR. CRAWFORD: I think that is a good suggestion.

14 DR. PLESSET: Spence, did you have other comment?

15 DR. BUSH: I was concerned with the pinning
16 effect, the rigid aspect. That answered my question.

17 DR. SRINIVASAN: Another scheme we are looking at
18 would involve not attaching it to the containment or to the
19 pedestal, a system which would primarily tie all of the
20 downcomers together. This is the current bracing at the
21 upper elevation at LaSalle that Dr. Crawford pointed out,
22 which is a segmented system.

23 This is — we would envision a system at the pool
24 surface. We may want to have a continuous ring. So you
25 would end up with two concentric rings and some

P. 14

1 cross-members. This has the advantage of not inducing
2 additional loads on the containment.

3 DR. ZUDANS: However, you would probably, in this
4 arrangement, find a sympathetic mode of motion which would
5 have the same low frequency.

6 DR. SRINIVASAN: But that would be the overall
7 mode, and we do not anticipate for the structural loads to
8 be acting in that direction. This is more likely to be an
9 excitation where you would see that mode coming into the
10 picture. The submerged structure modes will be
11 directional. We believe the higher modes would be what is
12 more important and not the fundamental sway mode of the
13 system.

14 DR. CATTON: I thought — I am hearing two
15 stories. I thought one hypothesis was that the submerged
16 loads were random in direction. And yet you are indicating
17 that you are assuming they are directed.

18 DR. SRINIVASAN: I want to clarify. What I meant
19 was these loads are directional, meaning that they are not
20 in the same direction but multi-directional innovators,
21 random.

22 DR. CATTON: That is a random excitation?

23 DR. SRINIVASAN: Yes. All of the downcomers going
24 in the same direction. That particular mode would not be
25 excited by the submerged structure loads. That is what I

DWM mte

1 meant.

2 DR. CRAWFORD: Could I add something to that?
3 Remember, we are considering both the chugging loads,
4 condensation oscillation loads, and the SRV loads. So I
5 think the more correct expression is to say that the loads
6 are directed, like an SRV load exists at a position near the
7 quencher. And we know the kinds of directions that it would
8 be facing. They wouldn't all be in the same direction and
9 they wouldn't be random, either.

10 We are trying to treat it mechanistically, having
11 direct —

12 DR. CATTON: I understand what you are doing. I
13 have not seen any clear demonstration that it is one way or
14 the other.

15 DR. CRAWFORD: For the SRV load?

16 DR. CATTON: For the LOCA load.

17 DR. BUSH: What occurs to these systems if only
18 part of the SRVs open? You assume you get a homogeneous
19 mixing of the pool, so essentially — otherwise, you would
20 get a differential expansion aspect.

21 DR. CRAWFORD: You are speaking of the terminal
22 effects due to SRV discharge. This restraint system we are
23 considering would be up near the pool surface and for — I
24 think we would anticipate that we would have sufficient
25 mixing, even for an extended blowdown, that we wouldn't run

1031 006

1 into any severe —

2 DR. BUSH: You would have a series of cold legs
3 and hot legs, and you would almost have to depend on some
4 degree of homogeneous mixing of the pool, I would think,
5 which you probably would get. I am not arguing.

6 DR. CRAWFORD: We are anticipating there will be
7 thermal mixing with the quencher. It discharges deep into
8 the pool. We think the thermal plume will spread out and
9 provide mixing.

10 We do not assume homogeneous mixing, but we assume
11 a reasonable amount of mixing will occur.

12 DR. ZUDANS: These restraints would be in a single
13 plane?

14 DR. CRAWFORD: Yes, sir, they would.

15 DR. ZUDANS: And therefore you would have
16 considerable links of downcomer left between this plane and
17 the floor. So you actually could possibly accommodate
18 significant delta T's in each of the restraint places, and
19 still not be critical, because there is lots of free length.

20 DR. BUSH: I am worried about some of them not
21 changing the length and others changing the length. So it
22 takes your horizontal members and it begins to do this to
23 them (Indicating).

24 DR. ZUDANS: The downcomers themselves are
25 changing?

1031 007

DR. BUSH: Yes, because if the SRVs don't open,

some of the downcomers —

DR. ZUDANS: Then you have local flooding.

DR. BUSH: Yes.

DR. SRINIVASAN: In a situation where this is not continuous and segmented, it would solve that problem.

Where you could have these segments would be located such that they would be centered at about a quencher, so you could accommodate the situation where you only have some of the valves going off. So you have a localized temperature here and it does not affect the other ones that are cold.

We are looking at several options.

DR. CATTON: But it affects the one that is in the same grouping. Your region of influence of the relief valve is not going to extend through 30 degrees.

DR. SRINIVASAN: This is something we would address in our design.

DR. CATTON: What is the reasonable assumption on the size of the plume rising above the SRV?

DR. CRAWFORD: We tried to consider the -- well, the quencher is deeply discharged and discharged in the horizontal plane out, and I don't remember the exact numbers. But I would anticipate that that plume rises up, and I would anticipate it would cover at least 20 to 30 degrees.

1 DR. CATTON: How far — it is a highly bullient
2 jet and your steam coming through the quencher is going
3 through a lot of little holes, so it is going to lose most
4 of its momentum. If I had to guess, I would guess it is
5 only going to go a small distance beyond the end of the
6 quencher. That steam jet is not going to extend very far
7 into the water.

8 DR. CRAWFORD: The steam jet itself will not
9 extend into the water very far. But I am anticipating that
10 the thermal plume will go several feet away.

11 DR. CATTON: What is going to drive it?

12 DR. CRAWFORD: It is not going to go several feet
13 in the horizontal. It will be going upward, obviously. But
14 the anticipation —

15 DR. PLESSET: I think we have a comment here.

16 DR. KUDRICK: I think one comment could be made,
17 and that is that Zimmer and LaSalle have committed to an SRV
18 testing, and one of the objectives of the test which we will
19 be looking for will be a demonstration of the pool mixing
20 potential for an SRV discharge.

21 In addition, they have tested in Germany
22 quencher-type devices that is somewhat analogous to the Mark
23 II, and they have found fairly good mixing potential in the
24 pool. I don't know if that answers all of your questions,
25 but at least we will be getting some preliminary data.

BWH

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. PLESSET: Have Zimmer and LaSalle chosen a particular restraint system?

DR. CRAWFORD: For the downcomers?

DR. PLESSET: No.

DR. CRAWFORD: No, it has not been shelled yet.

DR. ZUDANS: Have they committed to doing the SRV testing in-plant?

DR. KUDRICK: Yes.

DR. ZUDANS: You would possibly be able to instrument, to take care of questions like Dr. Bush asked?

DR. PLESSET: They promised to do that; isn't that right, Mr. Brinkman?

DR. BRINKMAN: Yes, sir, that is right. We have promised to measure temperature gradients. And maybe I could volunteer something about your concern of one safety valve going off and the next one not going off. I can't give you any numbers, but to give you some more feeling, the tests were done in the CAORSO plant in Italy. They did have heavy bracing systems over there that you may be familiar with, and the bracing system survived the test, and that is not to say the problem goes away, but some tests were done already.

Another thing I think that might be worth considering is that as I look at this existing test data that I have seen from Mark Is and other in-plant tests, the

BY BWH

1 maximum temperature gradients I saw were maybe in the order
2 of from right at the quencher to the water some distance
3 away, might be 20 Fahrenheit degrees, and that tells you
4 relatively, it seems to me, how important or how severe of a
5 temperature gradient you would get from one quencher, from
6 one downcomer pipe to the next downcomer pipe.

7 What I am trying to get at is there is some
8 existing basis for design. Sargent & Lundy lays out this
9 final quencher arrangement. There is existing data that
10 gives them, I think, some fairly good guidelines as to how
11 much would be the maximum temperature gradient for downcomer
12 No. 1, downcomer No. 2.

13 I am volunteering that the water temperature
14 differences aren't tremendous; and, therefore, the
15 difference in thermal expansion I wouldn't anticipate to be
16 tremendous, either.

17 DR. CATTON: I think the temperature differences
18 you are going to find will depend strongly on where you put
19 your thermocouples, and unless they are properly located you
20 are not going to find the maximum temperature differences.
21 And Dr. Bush's question, I think, is important.

22 DR. CRAWFORD: We have extensive temperature
23 sensors in the pool for the in-plant tests for LaSalle and
24 Zimmer. We have planned extended blowdown, and we have
25 submitted, in the case of Zimmer, the proposed in-plant

1031 011

BWH

1 test.

2 DR. CATTON: What are you going to do if the
3 concerns are valid?

4 DR. CRAWFORD: If what? The severe temperature
5 gradients exist?

6 DR. CATTON: That's right. From one downcomer to
7 the next.

8 DR. CRAWFORD: You have all of the hot water going
9 up around the quencher?

10 DR. CATTON: Yes.

11 DR. CRAWFORD: I think our concern would be more
12 about the ability to condense the steam than with the
13 restraint system, if that was the case.

14 DR. ZUDANS: If you don't have restraint systems
15 that hold out, you don't have condensing systems.

16 DR. CRAWFORD: You mean if --

17 DR. ZUDANS: If you have a structure that does not
18 survive the discharge, you do not have a condensing system.
19 So, your concern really should also be, quite seriously, on
20 the whole system and downcomers, not so far as to how
21 effectively you have condensed steam, whether or not the
22 structure can take it.

23 DR. CRAWFORD: We are concerned about temperature
24 gradients.

25 DR. ZUDANS: I wanted to shift the emphasis in my

BWH

1 direction; right?

2 (Laughter.)

3 DR. PLESSET: Did you have another comment?

4 DR. SRINIVASAN: I was only going to make one
5 comment: that we are not necessarily tied to using a design
6 where these braces are going to be rigidly tied to the
7 downcomer; we could have the option of having a capability
8 so that the rigidity is not a problem.

9 DR. ZUDANS: I would suspect that would be a good
10 idea. What about the Shoreham type of design? They have
11 already designed that. We saw it.

12 DR. CRAWFORD: Yes. Shoreham does have a
13 restraint design.

14 DR. ZUDANS: Have you looked at that design?

15 DR. CRAWFORD: Yes, we have looked at it, but not
16 in detail.

17 DR. BUSH: I didn't do a very good job of
18 explaining my concern. Your last solution, I think, would
19 solve it. And that is, if I got a very long pipe that is
20 tied at the top and not at the bottom and the water level is
21 halfway up that pipe, if I don't run any water down the
22 pipe, I don't get any expansion in that first 10 feet or so
23 of pipe, or whatever it is. And as a result, if the next
24 pipe is hot and that one is cold, I certainly am going to
25 have a difference. But if you can, as you suggest — all of

1031 013

BWH

1 my concerns disappear.

2 DR. SRINIVASAN: We will address that question in
3 our design.

4 DR. PLESSET: I hope, Steve, you don't mind our
5 getting into this now. It might be helpful for us to have
6 heard early.

7 DR. HANAUER: No problem.

8 DR. CRAWFORD: To just conclude, I wanted to
9 indicate that we are also considering the possibility that
10 more realistic load definitions resulting in lower pressure
11 and better definition of the frequency range and accounting
12 for the energy dissipation and attenuation could result. It
13 may not even require a bracing system, although this is what
14 we are continuing on.

15 We are looking very carefully at the load
16 definition to convince ourselves that we need to install a
17 restraint system design. These concerns about the natural
18 resonance.

19 DR. PLESSET: Thank you.

20 We have an item here for staff comments. Do you
21 have any more comments you want to make?

22 MR. ANDERSON: Not now.

23 DR. PLESSET: Then we will go to the next item
24 from the Mark II owners group, which is, as I have it, on
25 the ring vortex model. I gather there was no organized

BWH

1 presentation.

2 MR. ANDERSON: Yes, there is no formal
3 presentation, as I understand, from the Mark II owners on
4 this. It has been moved to the long-term program. There
5 consultant is not available. Maybe now would be a good time
6 to address some comments to them regarding this.

7 DR. PLESSET: I was going to suggest that maybe we
8 have some comments from the consultants and have a chance to
9 talk to some of the people who have worked on this to have
10 the floor for a bit. Maybe I will call on Prof. Wu and then
11 Prof. Catton for different viewpoints.

12 (Laughter.)

13 DR. WU: I don't know if the problem treated by
14 Dr. Chu and Lee -- are you familiar with this, with this
15 analysis?

16 MR. ANDERSON: Yes.

17 DR. PLESSET: The staff is aware, right.

18 DR. WU: In this paper, though not expressly
19 stated, it is intended to simulate the flow of the downcomer
20 out of the suppression flue of a pool of a Mark II pe of
21 reactor. I think, to speak of it very briefly, it is based
22 on an -- on any of the viscous vortex sheets, frozen without
23 a viscous attenuation and fusion.

24 However, it does include a vortex sheet
25 generation. The viscosity is generated within the downcomer

1031 015

BWH

1 pipe and transported into the lower plenum and the — it is
2 a numerical calculation, and based on the equation that the
3 transport of the viscosity is a material property and that
4 retains this property all the way through. So, the vortex
5 sheet would be generated and then rolled up into a vortex
6 core, and this would in turn be wrapped in a — in a
7 mushroom head.

8 The numerical procedure take a four-corner
9 weighting function which has been fairly standardized and
10 well developed in numerical schemes, but otherwise there is
11 no further numerical diffusion, as I understand it. So, the
12 procedure is a fairly well known one in the profession, and
13 based on this I believe the problem is well formulated.

14 There are a few things, perhaps, I could comment
15 on. One is the boundary calculation. It is taken as a unit
16 cell and axially symmetric with the downcomer pipe central
17 axis symmetry, and it is cylindrically symmetric and bounded
18 by a cylindrical surface. I believe it is like eight feet
19 or so in radius. And the downcomer pipe is extended.
20 Related to the Mark II atypical case, nine feet from the
21 downcomer exit plane and upper to the upper plenum, with
22 nine feet below to the basemat. It is an unsteady flow
23 calculation with a switch on, starting from time T.

24 Now, the velocity condition is as follows: There
25 is no normal component of the velocity at all of these

BWH

1 bounding walls, and the initial velocity comes — is
2 prescribed at the exit plane of the downcomer pipe. And the
3 vertical velocity is assumed or prescribed to be uniform.
4 And at the same time, the free surface in the suppression
5 pool is also assumed to move uniformly upward. These are
6 the two assumptions.

7 DR. PLESSET: What was the first vertical
8 velocity?

9 DR. WU: It is prescribed, instead of at the free
10 surface within the downcomer pipe, it is prescribed at the
11 exit plane, and that is prescribed to be uniform in the
12 radial direction. So, from then on —

13 DR. PLESSET: Then the problem is defined.

14 DR. WU: Yes. And then the problem is defined.

15 In the report, I think the velocity distribution
16 along the axis has been given. And then, also, the
17 positions of the stream lines, the stream surfaces, are
18 given in a time sequence.

19 Very recently, there has been a further new
20 numerical result, probably not included in the original
21 report. And that involves some of the transverse velocity
22 at a few vertical planes. And as I have it here, it is one
23 or two feet below the exit plane of the downcomer pipe. And
24 another one is at 2.6, and that is given at a point of 55
25 seconds, and in that time the mushroom head occupies the

BWH

1 position 2.66. So, there is a radial recirculating flow.

2 And also, with a velocity distribution along the
3 axis — and Dr. Catton and I have looked at this — there is
4 certain rate of velocity decay. This is vertical, the
5 velocity gradient in the vertical direction; and, of course,
6 that should be a reasonable physical result. That probably
7 would require a further investigation into it.

8 But on the whole, it looks like the problem has a
9 few new features: One is it is highly unsteady; the other
10 is the unsteady — the three-dimensional figure around the
11 mushroom head is very conspicuous, it is probably quite
12 important; and the third one is the boundary condition due
13 to the lateral wall in the proximity of the basemat would
14 change some of the — our earlier concept of that to the
15 generation of a jet that would come from the downcomer pipe
16 to be established within a short distance.

17 So, those are some of the new physical aspects
18 that might not follow with our earlier conventional
19 experience. And aside from these feuding aspects that might
20 require further investigation or thinking to understand the
21 problem, it appears the numerical work is done with high
22 confidence. Otherwise, the results are quite reasonable.

23 That is a brief summary of my reading of that.

24 DR. PLESSET: Ivan?

25 DR. CATTON: For the most part, I agree with

BWH

1 Dr. Wu. After having gone through the paper, I have an
2 uncomfortable feeling about some of the results, and, in
3 particular, the fact that the predictions of the pressure
4 don't extend to the region where the peak pressures occur --
5 as a matter of fact, they cut off quite a bit earlier.

6 There was some comment earlier about
7 Dr. Bienkowski, that this had to do with when the vent
8 clearing occurred, but I am not sure there is a lot of
9 agreement in that, either.

10 The main point I would like to mention is that
11 certain aspects of the solution don't appear to be correct.
12 I think --

13 DR. PLESSET: You mean physical?

14 DR. CATTON: Physically.

15 DR. PLESSET: Not as far as the numerics.

16 DR. CATTON: I think the way the problem is set up
17 is a step in the right direction, but somewhere between
18 setting the problem up and getting the solutions, things
19 don't look quite right. And the axial velocity, as
20 measured from the exit plane to the bottom of the model or
21 the floor, seems to drop off much too fast. And in
22 particular, the results that Dr. Wu recently got and that
23 were transcribed over the phone -- it may be the telephone
24 was part of the problem; I am not sure.

25 (Laughter.)

BWH

1 DR. CATTON: That shows that the derivative in the
2 axial velocity is non-zero at the exit plane, and that is
3 just incorrect.

4 So, one has to kind of wonder why this could be
5 so. I will appeal to Dr. Yao's comment that this kind of
6 problem is very difficult to solve numerically. It is
7 inherently unstable. So, you have a tendency, when you look
8 at these kinds of problems, to build in a lot of numerical
9 damping or even though it starts out to be inviscid, if you
10 start checking, it is a very viscous fluid.

11 I don't know where all of this leads, but as long
12 as it is not being I guess used on a particular plant at
13 this time, it is somewhat academic.

14 The non-zero derivative looks to me as if there is
15 an error somewhere. The imposed boundary condition is not
16 reflected in the solution.

17 DR. PLESSET: I think, since there has been an
18 effort, it has been worth our looking at it so that we would
19 have some basis for an opinion. I think that both of you,
20 we are grateful to you for your looking at this. And who
21 knows, they may want to use it again. I don't know.
22 Presumably not.

23 As far as the staff knows, it is not going to be
24 invoked; is that correct?

25 MR. ANDERSON: Not for the lead plants.

BWH

1 DR. PLESSET: Not for the lead plants.

2 MR. HEDGECOCK: Hedgecock, chairman of the Mark II
3 owners, from Washington Public Power Supply System.

4 In response to comments I heard earlier, our
5 position at the moment is that this is not an academic
6 question. There is at this time some intention of the
7 non-lead plants to use this model. We would prefer to leave
8 it at this stage at this time.

9 DR. PLESSET: So, then, this was a useful
10 discussion. And I think that the points that Professors
11 Catton and Wu have made are perhaps helpful in further
12 consideration by you and your consultants.

13 MR. HEDGECOCK: We certainly appreciate it.

14 DR. PLESSET: Fine. Any other comments on this
15 point?

16 (No response.)

17 DR. PLESSET: We are in an awkward situation. We
18 can go to lunch earlier or break a little less logically. I
19 am open to suggestions.

20 Carson, do you want to have lunch now? It seems
21 to be agreed by my weighty colleagues that we are going to
22 adjourn for one hour for lunch.

23 (Whereupon, at 11:40 a.m., the meeting was
24 recessed, to reconvene at 12:45 p.m., this same day.)

25

BWH

AFTERNOON SESSION

(12:45 p.m.)

1 DR. PLESSET: We will reconvene.

2
3
4 There is one item that Dr. Crawford wishes to make
5 a brief comment on for the record. So, I will ask
6 Dr. Crawford to do that.

7 DR. CRAWFORD: I would like to clarify the
8 discussion of the downcomer restraint system that we had
9 earlier. I would like to point out that the safety relief
10 valve lines are entirely separate than the main vent LOCA
11 downcomer vents. Because of the separateness of the two and
12 because the main vent downcomer vents are all used at the
13 same time in the event of some kind of hypothetical LOCA, we
14 would not anticipate any thermal gradients.

15 And furthermore, the restraint system design is up
16 near the surface of the water, and the only portion of the
17 downcomer vents is about a 10-foot length of pipe extending
18 down into the pool, and we don't anticipate any large
19 temperature gradients from one downcomer vent to another.

20 I think that would clarify the discussion we had
21 earlier.

22 DR. PLESSET: I think that clarifies the record.

23 DR. CRAWFORD: Thank you.

24 DR. PLESSET: We are glad to have that.

25 So, we can go on now to our next agenda item,

1031 022

BWH

1 which relates to the long-term program.

2 MR. HEDGECOCK: I would like to introduce the
3 long-term program this afternoon, and I can list the
4 speakers for you to aid in the transcription. The overview
5 will be presented by Mr. Alan Smith, General Electric, our
6 program manager. And the 40 CO test program will be
7 presented by Mr. Ray Muzzy, General Electric Company. We
8 then go on to the CREARE multi-vent test, an update on those
9 from our consultant, Dr. Hottel, from CREARE. This will be
10 followed by the generic improved chugging load program,
11 presented by Dr. Jim Fitch, of General Electric. And then
12 we will apprise you of the progress in the reduction of the
13 CAORSO test data, tests themselves having been completed,
14 and Mr. Mac Davis, of General Electric, will present that.
15 Since we had covered the ring vortex model before lunch, we
16 don't intend to say anything further about that.

17 DR. PLESSET: Not at this time, but later.

18 MR. HEDGECOCK: Later. And then we will go on to
19 the plant-unique programs, and Mr. Dale Roth, of
20 Pennsylvania Power & Light will talk about the GKM-2 CO
21 tests, followed by Dr. Bedrosian, our architect engineer,
22 Burns & Roe, to talk about the WPPSS-2 chug improvement
23 program. And then comments.

24 I would like to introduce Mr. Alan Smith.

25

BWH

1 MR. SMITH: Our Mark II containment program has
2 been explained to you by the NRC and others, and I would
3 like to give you a bird's eye view of where are we in terms
4 of the number of tasks that we have been working on and the
5 different areas. The total number of tasks that we have
6 been working on in this program -- and bear with me, there
7 is subjective judgment in that, but there are over 400 tasks
8 and if we can break those down by categories, possibly eight
9 percent of those lie in the lead plant SER area, perhaps 32
10 percent in the non-lead plant area, 34 percent lie in a
11 combination of the two, and we have about 12 percent of our
12 program in the confirmatory area, and perhaps 14 or 15
13 percent in the so-called informational category, the point
14 being that the informational category is really more for the
15 owners and it does not necessarily constitute a necessary
16 part of the program.

17 Overall, where we are right now, as you can see on
18 the chart, we feel that we are about, as of July of this
19 year, 70 percent complete. And we are probably a few
20 percent beyond that as of today.

21 (Slide.)

22 The next chart, I believe you have seen this
23 earlier this morning. I would like to comment on it. The
24 area beyond the final LOCA information to the staff really
25 represents basically licensing support kinds of activities,

BWH

1 that is, basically the program in terms of the analytical
2 and the testing work is done and completed and submitted.
3 And this is additional time probably necessary to be spent
4 working with the staff, answering questions and so forth and
5 we expect that to be completed by the middle of 1981.

6 (Slide.)

7 I would like to show you now in a bit more detail
8 where we are with respect to our specific tasks in the LOCA
9 area. I have listed for you the percent, which means I
10 won't waste time going through each one of those. Each
11 triangle represents a discrete or tangible output of the
12 program, whether that be a report or a model, some discrete
13 tangible output to the NRC. And obviously, the triangles
14 that are filled in represent those things that have been
15 completed as of July and the white triangles represent those
16 things yet to be completed.

17 As you can see from this chart, our final output
18 from the CO test program, task A-17, is about the end of the
19 third quarter, which with much of our earlier actual test
20 information being available sooner than that. That is the
21 longest program task item that we presently have in the Mark
22 II program.

23 (Slide.)

24 I have a few other charts but you don't have
25 copies of them, mainly because there is a problem in the

BWH

1 reproduction of color, but I thought it might be of value
2 just to quickly show you where are we in living color, if
3 you will. And bear with me.

4 The green obviously means it is done or
5 completed. And what appears to be gray here has come — are
6 the areas we are still working on. This is just to give you
7 a bird's eye view of what does the program look like, what
8 are those areas that are still requiring some work. In the
9 steam chugging and main vent loads it is well completed in
10 many areas. The seal program is underway and of course we
11 are not yet complete with that. The chug load definition
12 program is in task A-16. You will hear more about that
13 later. It is well beyond the midway point.

14 Dr. Patel from CREARE will discuss our subscale
15 multivent program and it is also well past the midway
16 point. There is one confirmatory program that we are
17 working at.

18 (Slide.)

19 This is the safety relief valve program, generic
20 safety relief valve program, I should say, that was
21 originally conceived by the Mark II owners group. It does
22 not include the T quencher program because that came along
23 later. It has been adopted by most of the Mark II owners
24 but this represents rather the Ramshead program and the
25 X-quencher program and as you can see the Ramshead program

BWH 1 is completed. The safety relief valve quencher program is
2 very nearly completed. There are some plant-unique aspects
3 of the X-quencher program that Washington Public Power is
4 working on and then I show where the T quencher program that
5 is being used by the other seven utilities fits into the
6 process. They have their own program which has already been
7 discussed. And so everything, the Ramshead program, the
8 X-quencher program, the T quencher program, feeds into the
9 plant evaluation by their design analysis reports.

10 (Slide.)

11 The next area is submerged structures and I really
12 put this together more for my own benefit than most people's
13 because it is a very complicated program and I tried to
14 identify the simpler elements. It has three basic elements,
15 analytical, models, Mark II unique applications memoranda
16 and the testing aspect of this program.

17 (Slide.)

18 And where are we on the analytical modeling work?
19 Our LOCA Ramshead air bubble work is completed. LOCA and
20 Ramshead water jet work is completed. We are still working
21 to complete our response to the staff's inquiry on submerged
22 structures criterion. As we mentioned earlier,
23 Mr. Hedgecock indicated to you, I think there are some
24 plants beyond the lead plants that are considering using the
25 vortex. And of course there will be more work in that area.

BWH

1 There are two areas that are plant-unique ideas,
2 the water jet and the LOCA steam condensation, that are not
3 part of the generic program. Mark II has determined that
4 those are more relevant to plant-unique work and the
5 quencher air bubble work is nearing completion.

6 (Slide.)

7 The testing program that we had is a 1/4 scale
8 test that is totally complete.

9 (Slide.)

10 And we have a miscellaneous category that is
11 nearing completion. Load combinations and functional
12 capability, the task has been completed. Again, we are
13 continuing to address items that the NRC staff had in their
14 submerged structures criteria. We are nearing completion in
15 this blue zone in answering all of the NRC's formal
16 questions. We have completed most of the SRSS work. There
17 is a supplement that Drs. Newmark and Kennedy have been
18 working with us on that will be complete, and our world test
19 monitoring activity is continuing. That is a general
20 understanding of what is going on throughout the world, to
21 keep advised of what is going on.

22 That concludes my very brief overview of the
23 status of the program. I would be happy to answer any
24 questions you have.

25 DR. PLESSET: Are there any questions of

BWH 1 Mr. Smith?

2 (No response.)

3 DR. PLESSET: I assume that somebody is going to
4 watch closely what Brookhaven is doing on the study of the
5 SRSS?

6 MR. SMITH: Yes. We are vitally interested in
7 that.

8 DR. ZUDANS: On this discussion of vortex before
9 lunch, I am wondering in which areas this particular
10 research or definition of — you plan to use that particular
11 part?

12 MR. SMITH: For application for the ring vortex?

13 DR. ZUDANS: It is plant-specific or generic?

14 MR. SMITH: I would say it is more plant-specific
15 and I think we would probably have to ask each plant to
16 speak for that and probably they are not prepared at this
17 time to speak directly to that. You will no doubt find that
18 there would be some commonality but I would expect that it
19 would be also unique.

20 DR. PLESSET: The lead plants aren't involved in
21 the question there?

22 MR. SMITH: These will be non-lead plant
23 applications.

24 DR. ZUDANS: The reason I mentioned this is
25 because from what I gathered before lunch there are many

BWH

1 questions not yet resolved with respect to capability of
2 this model to predict reality.

3 MR. SMITH: Yes, and we were very interested to
4 hear what Dr. Catton and Dr. Wu said, and we will take those
5 into consideration for any application.

6 DR. PLESSET: Thank you, Mr. Smith.

7 DR. MUZZY: I am Ray Muzzy from the General
8 Electric Company.

9 (Slide.)

10 The program I am going to talk to you about today
11 is the 4T CO program. As a result of examining the lead
12 plant assessment report, NUREG-0487, there was a question
13 which was mentioned this morning concerning the potential
14 vent length because of the scaling of the 4T test
15 equipment. The vent length system within the 4T was about
16 90 feet long, whereas prototypical was about 45 feet. As a
17 result of examining considerable subscale test data and
18 analysis in attempt to resolve that issue, we concluded that
19 from the existing data, that we did not have enough
20 information at that time to resolve the issue and considered
21 two paths for possible closure of this particular question.

22 The first path would have been to go through some
23 additional analysis and subscale data, which we believe
24 would have been a long and lengthy closure, whereas the
25 better would be to go to full scale tests for unique and

BWH

1 generic information for the Mark II plants.

2 (Slide.)

3 : Some of the objectives of the program are the
4 following: to confirm the adequacy of the existing 4T
5 specification we used an existing test facility, the 4T, and
6 made up modifications in that facility which I will describe
7 in the next slide. We went to a prototypical configuration
8 and we varied the test conditions to make the test data
9 generic to all of the Mark II plants. We considered various
10 types of breaks as well as vent submergence at full
11 temperatures, max fluxes and vent rises.

12 (Slide.)

13 The test configuration is as follows: this is the
14 existing 4T 10, the wetwell for the previous test, the vent
15 system, its bracing, as well as the wetwell tank here in the
16 previous test. This was the drywell and there was a vent
17 length that consisted of pipe that came from here all the
18 way up and down through here and that created the 90-foot
19 length that I talked about.

20 For the existing system we took the drywell and
21 put it on top of the wetwell in a prototypical
22 configuration. This is the existing steam generator that is
23 used in the old 4T test and will be used as the basis for
24 the source of steam and liquid for these tests. Also
25 contained in the test equipment is typical vent riser with

BWH

1 jet relector, which is prototypical of the Mark II plant and
2 will be studied as one of the test parameters.

3 DR. ZUDANS: I previously asked a question about
4 the natural frequencies of the downcomers. Do you know the
5 natural frequency of this downcomer?

6 DR. MUZZY: No. It is identical to the downcomer
7 that was used in the previous 4T test.

8 DR. ZUDANS: It is feasible or possible or
9 required, really, to vary this particular parameter, the
10 natural frequency of the downcomer to see how it affects the
11 things that you observed, because of condensation
12 oscillation frequencies, and go through the range where it
13 becomes synchronized with that? This seems to be in my
14 mind the only reason why you people decided to consider
15 bracing of downcomers in plants that did not have bracing
16 before, because you could not answer the question of what
17 happens if they are of the same frequency and you could, in
18 fact, study this particular parameter, could you not?

19 MR DAVIS: The bracing system that Zimmer and
20 LaSalle is considering is a result of considering submerge
21 structure loads, which is the impact on one vent from
22 oscillations of another vent. It is not caused by
23 oscillation in a single vent acting on itself. From the
24 previous 4T data, we have observed that during condensation
25 oscillation there is very little, if any, movement of the

BWH

1 vent itself from its excitation to itself.

2 DR. ZUDANS: It doesn't have to be from itself.
3 There is a condensation oscillation from multiple vents and
4 it operates at a given frequency. And if the structure is
5 of the same frequency you do have a question of what happens
6 if the resonance occurs. You will never have a single vent
7 postulating a single vent in a real plant.

8 MR. DAVIS: True.

9 DR. ZUDANS: So there is other chances for other
10 vents to feed the energy, so to speak. I am asking a
11 question, is it feasible to think that you could get some
12 light shed on this resonance that might exist because you
13 stated that some of the frequencies in the structure are in
14 the range of frequencies of condensation oscillations.

15 Of course, if you make it very stiff and brace it
16 you will move it out of that range. And maybe that is the
17 solution.

18 MR. DAVIS: In the previous 4T test we did have
19 essentially different frequencies of the vent in the test,
20 in that we changed the elevation of the bracing in the tank
21 from -- I will have to guess at the numbers, like eight foot
22 from the bottom of the vent to 24 foot, so there was quite a
23 range of vent frequency. And in none of those tested, we
24 see any excursions or significant loads during condensation
25 oscillation. I am not sure I am answering your question.

BWH

1 DR. ZUDANS: You're not.

2 (Laughter.)

3 DR. ZUDANS: All you have to do is go home and
4 dig. You have the information. Because you don't know what
5 the frequencies were, even with this support shifting. You
6 would have to look at the oscillation condensation
7 oscillation frequencies and look at the frequencies of this
8 structure as you had it, and if you can show that you really
9 went through the resonance. I didn't observe anything
10 significant. That might be all you need to do.

11 In other words, you do have the information, I
12 assume, on natural frequencies of those downcomers. Have I
13 made myself clear?

14 MR. DAVIS: I believe so. Maybe I could try again
15 on why the bracing system at Zimmer —

16 DR. ZUDANS: Don't try that.

17 (Laughter.)

18 DR. PLESSET: I'd like to hear it anyway. Go
19 ahead.

20 (Laughter.)

21 DR. BRINKMAN: I would like to make sure — I
22 would like to understand for sure what the question is. The
23 question seems to me to be, if you would do a test with
24 various bracing arrangements in this tank, perhaps you could
25 demonstrate that you don't need a bracing system to the

BWH

1 power plant.

2 DR. ZUDANS: Maybe that would be a result. That
3 could have been a result. But what you would have to
4 demonstrate is that nothing adverse happens if you happen to
5 have resonance between the natural frequency of your
6 downcomer and the oscillation frequency of condensation
7 oscillation.

8 DR. BRINKMAN: You are concerned about an
9 individual downcomer, then, loading itself due to the
10 oscillations at the bottom.

11 DR. ZUDANS: Each of these downcomers is, in
12 principle, identical to the other. If one of them has a
13 frequency, natural frequency, and submerged state of 9 hertz
14 so will the others. If your condensation oscillation
15 frequency is between 6 and 14 hertz or 6 and 11 hertz, that
16 means that you do have exciting frequency that is exactly in
17 resonance with your structure.

18 What will the structure do if it is subjected to
19 such exciting force? You do not have any tests that
20 indicate such a situation. You don't have that information.

21 MR. SMITH: I think we do. We have exhibited that
22 in the original 4T program.

23 DR. ZUDANS: What did you have? I asked whether
24 you had frequencies and you said --

25 MR. SMITH: We don't have the information here as

BWH

1 to the exact frequencies, but we did experience condensation
2 oscillation in that test series. And there was no
3 deleterious structural effects.

4 DR. ZUDANS: Do you know what the frequencies of
5 the structure were?

6 MR. SMITH: I can't tell you here. We probably
7 have that information.

8 DR. BRINKMAN: I think it is fair to say that the
9 frequencies covered by the test facility bound the
10 frequencies that we would expect in the power plants. And
11 if we went home we could dig up the data and give you the
12 numbers.

13 DR. ZUDANS: I want you to convince you, yourself,
14 that resonance is not a dangerous situation. That's all.

15 DR. PLESSET: Mr. Crawford.

16 DR. CRAWFORD: Perhaps I could -- I would like to
17 try to clarify what I think the question may be, and why we
18 are still having a concern and are still considering the
19 design. In the 4T test with the single vent, we tested over
20 a range of test frequencies --

21 DR. PLESSET: Including resonance?

22 DR. CRAWFORD: Yes. But our concern for examining
23 the restraint system design is that the load magnitude at
24 the resonant frequency may cause an adjacent downcomer to be
25 excited. The reason for that concern is that the

BWH

1 self-induced load is not the same load magnitude as the load
2 induced on that downcomer by an adjacent downcomer. So that
3 is really the concern.

4 In this particular test we have tested over the
5 range and we don't feel there is any self-induced load that
6 excites the resonant condition. I would feel more
7 comfortable before — if I were to do a test to determine
8 that a neighboring downcomer would not induce a resonant if
9 I had a multivent test.

10 DR. ZUDANS: That is a very good answer.

11 DR. PLESSET: If Dr. Zudans is satisfied, accept
12 it.

13 (Laughter.)

14 DR. PLESSET: I think that you clarified very
15 well.

16 DR. ZUDANS: The question is not being ignored.

17 DR. PLESSET: No, that's for sure.

18 DR. ZUDANS: That was my concern. Nothing else.

19 He answered my question that a single vent test is not the
20 avenue to find the answer for this question.

21 DR. PLESSET: That's right.

22 DR. MUZZY: In terms of instrumentation, the
23 primary objective of the tests are to address the questions
24 concerning vent acoustics and wall load information so the
25 instrumentation was concentrated in that area. We had from

Bnl

1 our existing 4T facility approximately 64 channels of total
2 instrumentation available, of which the mix was about 3/4 of
3 high speed channels and about 1/4 low speed channels, low
4 speed being devoted to thermocouples and bubble probes and
5 the high speed with pressure measurements throughout the
6 system.

7 In addition to instrumentation on the wetwell and
8 suppression pools, the downcomer drywell blowdown line and
9 steam vessel, we have also added instrumentation for
10 measurement of the air content. We have two methods, one
11 method being a grab sample technique where we grab a sample
12 of air downstream of a vent inlet and also a backup
13 technique where we continuously monitor the air.

14 DR. CATTON: The high speed measurements, how many
15 per second on a given pressure transducer?

16 DR. MUZZY: There are similar to high speed
17 instrumentation used for the last 4T test.

18 DR. CATTON: I don't recall what that was.

19 DR. MUZZY: I don't have the exact answer.
20
21
22
23
24
25

1 DR. CATTON: Does anybody have the answer?

2 DR. MUZZY: Yes.

3 DR. PLESSET: It will be in a report.

4 DR. MUZZY: There is a test plan in the procedure
5 document. There is a document that will address the question.

6 DR. PLESSET: Maybe we could get the number later.

7 DR. MUZZY: I may be able to answer that question
8 right now.

9 DR. PLESSET: That's best.

10 (Pause.)

11 DR. MUZZY: I would like to check it later and give
12 you the answer.

13 DR. PLESSET: Yes.

14 DR. ZUDANS: Could I ask a question on the previous
15 slide?

16 DR. MUZZY: Yes.

17 DR. ZUDANS: I noticed that you don't have anything
18 indicated on downcomer.

19 DR. MUZZY: We do have instrumentation for strain
20 gauges on the lower downcomer. I do have a back-up slide.

21 DR. ZUDANS: You do have strain gauges?

22 DR. MUZZY: Yes. These are the strain gauge locations
23 on the lower downcomer and we will be recording that
24 information — on the bracer system. And we have two
25 accelerometers located —

1 DR. CATTON: Our Part 3 strain gauge is sufficient
2 to locate the direction of the force.

3 DR. MUZZY: Yes.

4 DR. ZUDANS: No braces?

5 DR. MUZZY: Yes.

6 DR. ZUDANS: Don't you plan to run it without braces?

7 DR. MUZZY: No, there are no plans to do that at
8 this time.

9 DR. ZUDANS: Why?

10 DR. MUZZY: We are primarily interested in measuring
11 the CO wall loads and addressing the question concerning the
12 vent length. That is an objective of the test -- that's
13 why we have used the equipment the way we have.

14 MR. ANDERSON: From the beginning of the 4T test,
15 there has been an attempt to look at and establish the loads
16 and to put together a facility that was prototypical of
17 Mark II plants. However, not structurally prototypical.

18 There has never been an attempt to make it
19 structurally prototypical because you have quite a variation
20 from plant to plant in the bracing systems.

21 I think you might hear something with regard to the
22 Susquehanna presentation where, in that particular case, for
23 that -- that is prototypical of that plant. And they are
24 trying to make that structurally prototypical.

25 Here you would have to run a whole series of tests.

1 DR. ZUDANS: I understand that. My comment would be
2 that if you plan to license any plant without any braces —
3 which right now Zimmer is without braces and they are not
4 committed to use the braces yet. They are on / studying it.
5 You don't have any single test for — without braces.

6 DR. ANDERSON: But that doesn't necessarily affect the
7 load.

8 DR. ZUDANS: It affects the load dramatically. The
9 load is affected. There will be effect.

10 DR. ANDERSON: The data for establishing load for
11 all of these plants comes from a variety of tests. The 8.8
12 kip static equivalent load didn't come from the 4T; it came
13 from GKM. And there are many other test facilities. So we
14 looked at those with bracing configurations to come up with
15 single-load specifications.

16 DR. ZUDANS: Is there any test at all without
17 braces any place?

18 DR. ANDERSON: I don't think so.

19 DR. ZUDANS: I suggest that we think about it.

20 DR. ANDERSON: if they do not make a modification to
21 include bracing, this will become — we will look at that
22 area at that fluid structure interaction concern.

23 DR. MUZZY: We have structured a test matrix to
24 investigate a range of parameters for the Mark II conditions
25 and have investigated break type, break size, pool temperature,

1 vent submergence, and we have inserted a riser to establish
2 the effects of a riser, which rises up into the dry well.

3 We have a two-phase program, an initial set of about
4 four tests. We get early-on indications of the behavior of
5 the system which will help us to formulate and finalize the
6 remaining Phase II test which will be done after that.

7 I will give you some schedule indications on my
8 last slide.

9 DR. CATTON: Is there any reason that you have no
10 steam break with high pool temperature?

11 DR. MUZZY: No. It is a matter of packaging the
12 various tests that we have available from the matrix, which
13 is 23 tests to maximize the information.

14 DR. CATTON: So you feel that the loads associated
15 with the liquid break will be greater than those associated
16 with the (inaudible).

17 DR. MUZZY: That has been borne out in experience.

18 (Slide.)

19 To give you an idea of how the test matrix
20 covers the range of blowdown conditions for Mark II plants,
21 we have plotted the air content versus the vent steam mass
22 flux.

23 (Slide.)

24 In terms of the usage of the data and its
25 interpretation in measuring that exit pressure history, we

1 determine the presence of the standing wave.

2 And we will also be examining the pool wall pressure
3 histories to establish the CO amplitude versus frequency
4 content and interpret it in terms of Mark II applications and
5 compare that to the DFFR.

6 (Slide.)

7 The schedule for these activities are as follows:
8 We have developed the functional specification and the test
9 plan. The facility completion, facility modification will be
10 completed this month.

11 At that particular time, near the end of the month
12 and in through October, we will be doing shakedown tests.
13 After that, we will initiate our Phase I test, the four
14 tests I talked to you about. Then there will be a time period
15 for about a month when we will examine that data and see how
16 it would possibly influence the Phase II test.

17 In December and through March, we will do our Phase
18 II testing. The data reduction will take place during this
19 time and the final test report will be out in the third
20 quarter of 1980.

21 DR. PLESSET: Are there any other questions of Mr.
22 Muzzy?

23 (No response.)

24 DR. PLESSET: Thank you.

25 DR. CATTON: How did you arrive at the high pool

1 temperature being 110 degrees?

2 DR. MUZZY: Pool temperature will increase during the
3 test. That is the initial temperature. And as the slowdown
4 proceeds, it will increase. That is how it was dictated.

5 DR. PLESSET: The next item is CREARE tests.

6 DR. PATEL: I am with CREARE, Incorporated, and I
7 will be presented to you today the multivent test program that
8 we are performing for GE.

9 (Slide.)

10 The objectives of the multivent test program are
11 basically to obtain a single vent and a multivent data base
12 which can be used to obtain the transient loads with a
13 number of vents during chugging. And secondly, we plan to
14 show that the trends that we observe in these sub-scale data
15 will be applicable and valid for application to the full-scale

16 And we will do this by comparing the single-vent
17 data at four subscales and comparing multivent data at two
18 scales.

19 (Slide.)

20 To meet the objectives of the program, we are doing
21 single vent tests at 1/10th scale, 1/6th scale, 1/4 square,
22 and 5/12ths square. The multivent tests at 1/10th scale,
23 3, 7, and 19 vents, and 1/6th scale, 3 and 7 vents.

24 DR. CATTON: When you change the scale, you change
25 all the geometrics?

1 DR. PATEL: I will get into that shortly.

2 We also did tests to see the effect of the
3 parameters like drywell size, pool size, and the location of
4 the vent in the pool.

5 (Slide.)

6 The test program was broken up into two phases.
7 In Phase I, we developed the test facility instrumentation
8 data acquisition procedures to do these tests, and then we
9 did the tests at the 1/10th scale, 1, 3, and 7 vents. And
10 at the 1/6th scale, we did the 1 and 3 vents.

11 We also did the special test in order to evaluate
12 the effect of drywell size, pool size, and the location of
13 the vent in the pool.

14 Phase II, which we are doing right now, at CREARE
15 we are doing the 5/12ths single vent, 1/4th, the 10th scale
16 for 9 vents and the 6th scale for 7. And this will complete
17 the data base for the objectives of the program.

18 The schedule for this test program is as follows --

19 (Slide.)

20 DR. CATTON: Will you show a cross-section?

21 DR. PATEL: Yes. The schedule of the program is as
22 follows: Phase I is essentially completed. The test report
23 is in the works. Phase II, testing has been started. We
24 are at approximately 40 percent complete on that. And we
25 hope to produce the test report on that sometime in the second

1 quarter of 1980.

2 The test facility, a schematic of it, is shown here.
3 And we have shown some typical geometries that we tested in
4 Phase I.

5 The drywell is essentially located on the top of
6 the wetwell and we did essentially multivents at the same
7 scale.

8 So we did a single vent test and a multivent test,
9 which looked essentially similar, except for the sizes being
10 changed according to the number of vents.

11 Do you have any questions on this one?

12 DR. CATTON: I see what you have done when you
13 scaled up. You built yourself a completely new system.

14 DR. PATEL: That's right.

15 DR. CATTON: When you go from the one vent to the
16 three vents, you are increasing the area, cross-sectional
17 area by a factor of 3.

18 DR. PATEL: Yes. The drywell is increased by a
19 factor of 3 also.

20 (Slide.)

21 The test matrix was extensive for this program and
22 the reason being that we wanted to cover the wide range of
23 parameters so that if we needed them for the scaling work,
24 we would be able to basically fall back on the data base.

25 The submergence and the clearance were scaled by

1 a scale factor. The wetwell diameter was such that the pool
2 to vent area ratio was kept constant. The drywell was scaled
3 by the cube of the scale factor from the corresponding single
4 vent full-scale drywell.

5 The wetwell space pressure was varied from
6 sub-ambient to the full 45 psia, which is a prototypical value.
7 The steam mass flux range was from .1 pounds to 16 pounds,
8 which is expected to lower the entire chugging range.

9 The pool temperatures varied from 90 to 200 and the
10 steam air content was changed from zero to .5 percent by
11 mass.

12 (Slide.)

13 I will be showing you some of the Phase I data that
14 we obtained and I will show it to you in terms of the
15 multi-vent multiplier, which is defined as the peak over pressure
16 measured at the bottom of the pool for the multi-vent
17 geometry divided by the corresponding one for the single
18 vent geometry.

19 Basically, at the same test conditions for the
20 same value of steam mass fluxes, what will air space
21 pressure and so forth —

22 Here is a composite bar which indicates the
23 multi-vent multiplier for a range of steam mass fluxes and
24 the trend is fairly clear.

25 The multi-vent multiplier is essentially less than 1.

1 That means the load in the multivent geometry are less than
2 those in the corresponding single-vent geometry. And
3 further, the loads go down as the number of vents is
4 increased.

5 This is the 1/10th scale data.

6 DR. ZUDANS: Which loads?

7 DR. PATEL: The peak over pressure at the bottom of
8 the --

9 DR. YAO: Does steam mass flux indicated for single
10 vent or for both tests?

11 DR. PATEL: The mass flux is essentially
12 non-dimensional by the total area of the vent.

13 So in the case of a single vent, it is the cross-
14 section area of one vent. For three vents, it is three times
15 that. The mass flux stays the same.

16 DR. CATTON: When you do one vent, you have a
17 particular vent to pool horizontal area. And you go to two
18 vents on this diagram here -- do I maintain that ratio vent
19 area?

20 DR. PATEL: Yes.

21 DR. ZUDANS: This is just one of the load parameters
22 that you observe the pressure at the bottom of the
23 suppression pool?

24 DR. PATEL: Yes.

25 DR. ZUDANS: Did you look at other things and they

1 showed the same type of trend?

2 DR. PATEL: We looked at peak underpressures where
3 basically the program is geared toward measuring the wall of
4 pressure loading.

5 We are not making any measurements of loads on the
6 vents and so on, like through strain gauges, et cetera.

7 So it is essentially making — drawing conclusions
8 based on the wall pressure increases.

9 DR. ZUDANS: You look at the sidewall pressures. Do
10 they exhibit the same thing?

11 DR. PATEL: Yes. We have a total of six pressure
12 transducers located on the pool walls. Some of them are at
13 the pool bottom elevation and some are at mid-submergence
14 around the circumferential locations and so on.

15 We have a lot of data at various parts of the pool.
16 And all of them are generally exhibiting the same trend.

17 DR. ZUDANS: Do you measure anything that would tell
18 you what the vent itself is?

19 DR. PATEL: The vent in terms of —

20 DR. ZUDANS: Pressure?

21 DR. PATEL: We measure the static pressures in.

22 DR. ZUDANS: How about outside?

23 DR. PATEL: The outside surface of the vent does
24 not have a pressure transducer. So we do not have a pressure
25 measurement there. We do have three transducers located on --

1 essentially put close to the vent. So we have some pressure
2 data in the pool close to the vent, but we don't have a
3 pressure transducer on the vent looking at the pool wall
4 pressures itself.

5 DR. ZUDANS: You do not measure the motion of the
6 vent itself in any way at all?

7 DR. PATEL: We have accelerometers on each of the
8 vents, so we do have acceleration data.

9 DR. YAO: How do you define "multivent multiplier"?

10 DR. PATEL: This particular slide shows the
11 multivent multiplier based on the peak pressure at the bottom
12 elevation.

13 That is essentially defined as the peak pressure
14 at the bottom elevation for the multivent geometry, divided
15 by the peak overpressure for the single vent geometry at the
16 same test conditions.

17 DR. CATTON: When you run your single vent test,
18 where are your pressure transducers relevant to the single
19 vent?

20 (Slide.)

21 DR. CATTON: Let's compare one with three.

22 DR. PATEL: I will do it at a larger scale. Suppose
23 there is a transducer here and pool elevation — do you have
24 a pen that I can use on this? Let me show you a typical
25 transducer location. There would be one here and one there

1 indicating).

2 There are essentially three around the circumference
3 at this location. There is one transducer there. So you
4 have four plus two. That is six transducers. For the
5 multivent geometry, you have one there, one there and one
6 there. Basically three around the circumference — again
7 here and one there (indicating).

8 The data I am showing you is showing the peak
9 overpressure here versus the peak overpressure there
10 (indicating).

11 DR. CATTION: When I look at the three, the location
12 of the pressure transducer is a lot further away from the
13 left most vent.

14 So I would expect that its impact on that particular
15 transducer to be much less. There is no way that I would take
16 a single vent and multiply it by 3 to get the load because
17 there are area considerations that have to be taken into
18 account.

19 Have you done any of this kind of thing?

20 DR. PATEL: That is exactly why we did the test, to
21 see the effect of pool size with the event essentially
22 centered in a different size pool. And the offset vent test
23 where we took the same pool that we use for the three-vent
24 test and we took these two vents out and then we further —
25 moved this vent around so we could quantify the effects of the

1 distance between the vent and the transducer measurement
2 location.

3 It turns out that the predominant factor which
4 governs the peak overpressure are the magnitude of the wall
5 pressures, is the size of the pool. The distance is a
6 parameter.

7 The closer you move to the transducer, the higher
8 the --

9 DR. CATTON: So the pressure source at the vent is
10 probably the same in both cases. You really just have a
11 geometric --

12 DR. PATEL: Exactly, and probably the vents are
13 not chugging in phase. So each vent is --

14 DR. CATTON: Are you able to separate that? I think
15 you have a combined lack of synchronization. And if you
16 can't separate them, then I think there is a bit of a problem
17 in accepting either one.

18 DR. PATEL: We have a single vent test where we
19 took the single vent and put it in the same size pool. Then
20 we measured the pressure.

21 In general, we find that that is --

22 DR. CATTON: Did you run three tests with the single
23 vent in everyone of those locations and look at the
24 pressure?

25 DR. PATEL: Yes.

1 DR. CATTON: That is a problem that you have to
2 work out.

3 DR. PATEL: Yes. And by taking a look at that data,
4 we will be able to answer —

5 DR. CATTON: You haven't done it yet.

6 DR. PATEL: I haven't done that completely. But
7 we have the data and that was the purpose for taking this
8 data, was to sort out what causes the mutivent -- ** opposed
9 to just showing that it does go down.

10 DR. CATTON: you have a broad range of parameters,
11 from 90 to 200 degrees, mass flux to 2.8. Air content, 2.5
12 on one graph.

13 Are you going to sort this out or find the maximum
14 value type of curve?

15 DR. PATEL: There is a report in progress right now
16 and it will be given to the NRC sometime at the end of the
17 year. We don't have complete cross-blocks for each of the
18 points you see here will be plotted against steam mass flux,
19 how it varies and so on.

20 For the presentation here, this is to give you a
21 flavor as to what this — this band represents something of
22 the order of 50 data points.

23 DR. CATTON: It represents a tremendous range in
24 important variables.

25 DR. PATEL: That's right. The point I am trying to

gsh

1 make here is that the pool size effects seem to dominate
2 the effects of the other parameters.

3 So you still get most of the data fitting into these
4 kinds of bands.

5 DR. ZUDANS: Generally, you find that the bottom
6 pressure reduces as pool size increases.

7 DR. PATEL: Yes.

8 DR. ZUDANS: The number of downcomers, the number of
9 vents does not have a linear effect on the pool pressure. The
10 effect may be —

11 DR. BUSH: When you say pool size, you are
12 talking about area relationship or body?

13 DR. PATEL: We keep the submergence the same.

14 DR. BUSH: You change the submergence level for the
15 same area of content? Does it change anything?

16 DR. PATEL: In this particular test program, we are
17 not taking a look at the effect of submergence on the wall
18 pressure.

19 We have done that in a previous test program and
20 we found that submergence in general does not affect the peak
21 overpressure to a large extent.

22 For this phase of the program, the submergence was
23 not a variable.

24 DR. BUSH: Therefore, when you talk about the size,
25 you are really talking about area of content?

gsh

1 DR. CATTON: Really, what you were saying is that
2 the monometer models are not valid.

3 DR. PATEL: The monometer models for the chugging.

4 DR. CATTON: Yes.

5 DR. PATEL: I seem to feel --

6 DR. CATTON: I don't want to lead you to a conclusion.

7 DR. PATEL: It might play an effect, although I
8 think the monometer is essentially going by the condensation
9 process. And as long as things are done, you keep that
10 fairly similar from scale to scale. You find that the
11 other parts of the geometries do not seem to affect it.

12 DR. CATTON: The monometer effect is not the
13 important one, and I would agree with that.

14 DR. PATEL: At one-sixth the scale, we see a similar
15 trend. We only did the one, the three vents here. So we
16 have the one data point. Again, you see that the loads are
17 going down.

18

19

20

21

22

23

24

25

Cr. 6841

t-
si

(Slide.)

DR. PATEL: To conclude --

DR. CATTON: One more question. I don't mean to keep beating on this. If you think that you are dealing with area and you take the particular vent area to pull area ratio, you can go to two vents, double the area, pull area, and get roughly the same load. The pressures will be different, but the load will be the same.

What are you telling me? Are you telling me the loads are the same or the pressures are the same?

DR. PATEL: The peak overpressure are the same.

I do intend to --

DR. CATTON: When you integrate over the surface you may come to a different conclusion with respect to the loads.

DR. PATEL: That may be.

DR. CATTON: You have pressure distribution and you have by no means have enough pressure transducers to determine what it is. You really need another phase to test to conclude what the loads behave as you say they do.

DR. PATEL: This is not a load aspect, per se. It is more what is happening to the pressure at the wall.

DR. CATTON: Your pressure transducers, as you indicated, is in line with the three vents and I don't have three vents unless you have located them in some symmetric way

sls-2

1 that doesn't show on your drawing. I am not sure again what
2 it means.

3 DR. PATEL: The three vents are essentially put
4 like that.

5 DR. CATTON: The pressure transducer should be
6 located so it is as close as possible to all three in order to
7 get a peak pressure.

8 DR. PATEL: We have the three circumferential
9 pressure transducers, the vent elevation.

10 DR. CATTON: They are higher.

11 DR. PATEL: We have a pressure transducer there
12 (Indicating.)

13 DR. CATTON: I noticed that one, yes. You indicated
14 that you were using the bottom one.

15 DR. PATEL: For the purpose of the data. I made
16 the comparison for these two (indicating.) If I plotted the
17 other transducers --

18 DR. CATTON: You may not be telling me about the
19 peak pressure then, the pressure that is closest to the vent
20 exit. Doesn't it -- doesn't it read higher? Could you locate
21 that circumferentially around the tree where it would read the
22 peak?

23 DR. PATEL: We do have that. The three vents are
24 essentially placed like so, and the pressure transducers at the
25 vent exit elevation. (Indicating.)

1 DR. CATTON: If you bisect one of those vents, how
2 do you know that a pressure transducer where that intersects
3 the wall wouldn't retire due to super position?

4 DR. PATEL: I don't know that, except when I plot
5 the circumferential location with the three transducers they
6 sort of give the same answers.

7 DR. CATTON: I would expect that. That is a
8 question I basically cannot answer.

9 Can't you rotate the lid of this thing?

10 (Laughter.)

11 DR. PATEL: We could do that. The purpose of the
12 program was to just see how are the pressures affected at the
13 various locations, and we happened to pick these.

14 DR. CATTON: It is an acoustic problem and you could
15 calculate where the peak pressure is and locate your pressure
16 transducer then.

17 DR. PATEL: Right.

18 DR. YAO: I have a question on the slide on this
19 multivent multiplier.

20 I tried to understand the meaning of this sentence.
21 So, from this chart if I have a single vent, let me see the
22 total load. The single vent is one unit.

23 DR. PATEL: Total load or the peak overpressure?
24 The wall?

25 DR. YAO: This chart indicates peak load.

sls-4

1 DR. PATEL: The peak overpressure at a particular
2 wall location.

3 DR. YAO: Let's assume pressure is almost uniform, so
4 it is one unit. So, I get two vents. Two vents is about
5 .57, something like that. So, is the .57 multiplied by two
6 then multiplied by another two to give you a total area? So
7 actually for two vents, test data indicates this .57 multiplied
8 by four.

9 DR. CATTON: So, the load is twice, and that sounds
10 reasonable.

11 (Laughter.)

12 DR. PATEL: The total load, if you integrate the
13 pressure around the wall, and I am sure what you are saying is
14 true. But the fact is the pressure which is measured at the
15 wall in which I believe the stress -- what one wants to work
16 with and goes down by half. So, there is a distinction between
17 the total load --

18 DR. YAO: Let's assume from your curve, the curvature,
19 let's say approximately four vents. The curvature starts to
20 change. This means where you increase the number of vents, the
21 load either increases or decreases for the number of vents
22 less than four and the tendency reverses for number of vents
23 bigger than for.

24 DR. PATEL: Excuse me? I didn't follow that.

25 DR. YAO: You have a curvature there. This

sls-5 1 curvature actually changes, the steep curvature it changes to --
2 the slope changes.

3 DR. PATEL: First of all, the line has been sort of
4 drawn through some data. I don't know how accurate it is. I
5 don't know whether you want to go to the extent of pulling
6 slopes from it. I would look at the line. But when you start
7 to differentiate a line which has been drawn through a set of
8 data, it worries me.

9 DR. YAO: The reason I don't interpret your result --
10 I get the immediate impression that the increased number of
11 vents the load decreases, and --

12 DR. CATTON: That is correct.

13 DR. YAO: Somehow this violates my intuition. This
14 is why I try to understand the meaning of that curve.

15 DR. HANAUER: The ordinant on your curve. This is a
16 number which I have to multiply by what to get the peak
17 pressure?

18 DR. PATEL: From a single vent multiplied by, for
19 example, .4 will give you the peak pressure at the same location
20 for the multivent geometry.

21 DR. HANAUER: Do I have to multiply by three?

22 DR. PATEL: No, you just multiply it by the
23 multivent multiplier.

24 DR. HANAUER: I am having the same trouble.

25 (Laughter.)

sls-6

1 If I have one downcomer in one plot of Area 1 and
2 I measure a certain number of pounds per square inch peak
3 pressure, if under the same circumstances I have three down-
4 comers in a plot of Area 3 -- will I measure a larger or
5 smaller absolute pressure?

6 DR. PATEL: You will measure a smaller absolute
7 pressure which will be forty percent of the absolute pressure
8 you measure for the single.

9 DR. HANAUER: The principle reason is the large
10 part and the fact that they don't reenforce.

11 DR. PLESSET: I think Dr. Hanauer has the floor for
12 the moment. Continue.

13 DR. HANAUER: I am finished.

14 DR. PLESSET: Will you feel better if that
15 multiplier were one-third for three vents?

16 DR. HANAUER: I just wanted to understand the
17 scale, and I didn't think people were communicating.

18 DR. PLESSET: Who is next? Let Dr. Yao continue.
19 He started this.

20 DR. YAO: What I am trying to get across, I think
21 probably, let me suggest something. If you are going to analyze
22 the data, be careful about this curve because the slope change
23 indicated there is the optimum number of vents. You will get
24 the lowest load. That sounds strange.

25 DR. PATEL: All of this curve in my opinion is

1031 061

sls-7

1 showing is that basically when you go from one vent to three
2 vents you see the largest decrease in load, and when you
3 decrease the number of vents you still see a decrease in load,
4 but the decrease is not as large.

5 Now, I think that if you multiplied those numbers
6 by the number of vents and tried to measure your load, you will
7 find a decrease and an increase character. Of course, as you
8 say, if you draw a line through a wider range of data, maybe --
9 maybe this curve is not represented in that, but my suggestion
10 is that when you analyze your data you want to be more careful
11 to locate. This may be the mean value of the -- the best
12 estimated value of this curve.

13 DR. PATEL: I think there is a little misconception
14 here. These numbers do not get multiplied by the number of
15 vents in order to give the peak overpressure. This is just a
16 direct ratio of what I measure in the single vent. I mean,
17 what I measure in the multivent divided by what I measure in
18 the single vent. As far as the pressure transducer is concerned,
19 it doesn't care whether it is one vent, three vents or whatever.
20 It is a direct ratio.

21 DR. PLESSET: What he has is an area factor which
22 is going up with the number of vents. The load could very well
23 rise as you say, and it will.

24 For example, if the multiplier was .5 and if it has
25 three times the area it will get one and a half times

1 the load.

2 DR. YAO: It seems the slope changes --

3 DR. PLESSET: Don't worry about that.

4 DR. PATEL: The thing I have shown here is the peak
5 overpressure, and if I did say load several times, I am
6 definitely wrong.

7 DR. PLESSET: We have that straight.

8 DR. PATEL: It is a peak overpressure. This is the
9 way the peak overpressure behaves. The total load on the
10 containment, if you assume to do that you would have to make an
11 assumption of what a pressure distribution on the entire wall
12 was and integrate with the area. Therefore, this curve is not
13 to be confused with the total load. This is what happens to
14 the pressure when we measure in a single vent in a multivent
15 geometry. The pressure trend shows that it is increasing with
16 the number of vents.

17 DR. PLESSET: Increasing?

18 DR. PATEL: Decreasing.

19 DR. PLESSET: Your area is going down, too.
20 Your area is going up at the same time.

21 DR. PATEL: Right.

22 DR. CATTON: Some of the vents are further away
23 from the pressure transducer.

24 DR. PLESSET: If you were going to get a load
25 roughly by taking the peak overpressure, multiplying by the

sls-9

1 area, it is most likely going to go up.

2 DR. ZUDANS: I would like to make this discussion
3 very short.

4 (Laughter.)

5 Ivan pointed out why these data cannot be used to
6 make this conclusion. The transducers are located incorrectly.

7 DR. CATTON: They may be incorrect.

8 DR. PLESSET: He doesn't have the pressure field
9 yet.

10 DR. ZUDANS: The only thing you measure correctly is
11 a single vent peak pressure. You do not have a field pressure
12 for multiple vents. Therefore, you do not know where your peak
13 is. You measure it right behind the triangular path on the
14 diameter. You shaded that point from all of the other vents.
15 I think if you listen to what Ivan says you have to rotate so
16 that you measure in between and you would find out that there
17 is a pressure variation around the circumference. I think this
18 confusion is premature.

19 DR. PLESSET: For the point at which he measured it.

20 DR. PATEL: For the point at which I measured which
21 is pull bottom elevation. This is what I see.

22 Now, I think in the following presentations you will
23 see how they use the 4T data in order to predict the Mark II
24 plant loads. At that point you can see how this --

25 DR. PLESSET: I think that Dr. Catton's suggestion

1031 064

sls-10

1 about getting a couple of other points or one other arrangement
2 would be helpful. You have done so much here with this
3 arrangement that a little more might not be too much.

4 DR. CATTON: When he goes out to eight vents or
5 seven, now you really wonder where the three pressure transducers
6 are located relative to the --

7 DR. PATEL: I think that the important point here
8 is that at the same location in the -- there will be a
9 variation around the circumference.

10 DR. CATTON: You are referring to peak pressure.
11 The only thing I am convinced of is that you know what peak
12 pressure is for the single vent. Unless you run some other
13 experiments with different locations.

14 DR. PATEL: I think there is a confusion of that
15 peak pressure.

16 DR. YAO: Maybe this will clarify the point. I think
17 from those peak pressure datum you show us, you can show
18 definite correlation between this peak load pressure and the
19 total load.

20 DR. CATTON: I think you understand what the concern
21 is. There was only one other comment, and I think you want to
22 make sure that the synchronization of the bubble collapsed
23 in the area factors are separated. If you keep them together,
24 then I am not sure what one can do with the information you are
25 generating. If you can separate the two, I think that they might

1031 065

sls-11

1 become meaningful for other aspects of the LOCA loads.

2 DR. PLESSET: I think we have belabored this a
3 little bit.

4 Mr. Sobon?

5 DR. SOBON: It seems to me a lot of this discussion
6 has taken place because it was not clear what the objective of
7 this test program is.

8 DR. PLESSET: Are you going to tell us now?

9 (Laughter.)

10 DR. SOBON: At this point it is narrow, and that is
11 to simply justify that the maximum load measured in the 4T
12 full scale test facility is bounding -- the maximum pressure --
13 it is simply to demonstrate that that is a bounding pressure
14 and it is suitable for conservative use in plant evaluations.

15 DR. PLESSET: That is using a single vent peak
16 pressure?

17 DR. SOBON: Full scale single vent pressure is
18 bounding in a conservative or a multivent geometry.

19 DR. CATTON: That depends on how you are going to
20 use it. Are you going to take the 4T test pressure and multiply
21 it by the number of vents to get the pressures?

22 DR. SOBON: We are considering that maximum as
23 conservative and as a maximum for what you would see in a
24 multivent geometry. And this test simply show that the multivent
25 pressure would be low.

1031 066

sls-12

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. PLESSET: We accept that.

(Laught^{er}.)

DR. PLESSET: Would you quickly -- you had a lot of good time.

(Laughter.)

(Slide.)

DR. PATEL: The overall characteristics of the multivent -- of the chugging is very similar to the single vent chugging. The multivent pool wall pressures are lower than those observed in the single vent geometry and the multivent multiplier is a ratio at the pool wall pressures and is less than unity and decreases with an increasing number of vents.

DR. PLESSET: Thank you.

We have another presentation on the improved description of the chug loads.

Mr. Fitch.

DR. ZUDANS: I have a serious question on this.

DR. PLESSET: Just one question.

DR. ZUDANS: I would like to ask one more question of the previous speaker.

When you listed your conclusions, were they based on the same mass flux rate for 136?

DR. PATEL: That's correct.

DR. ZUDANS: Then it is not too surprising.

1031 067

sls-13

1 MR. PATEL: It is the same mass flux.

2 DR. ZUDANS: Total mass flux, the same?

3 DR. PATEL: It is the same. The mass flow in the
4 multivent geometry will be larger than the single vent
5 geometry by the number of vents.

6 DR. ZUDANS: Is the number of kilograms per second
7 per meter squared?

8 DR. PLESSET: He said that, but he got a lot of
9 other things.

10 MR. FITCH: I am Jim Fitch with General Electric.

11 (Slide.)

12 I am going to be describing the so-called Task A-16
13 of the Mark II program to develop an improved chugging load.
14 And the work that I will be describing is basically the result
15 of a joint effort between Bechtel Corporation and General
16 Electric. And we have Bechtel representatives here to help
17 with any questions that you might have.

18 I would like to begin by briefly describing the
19 history of chugging in the Mark II program.

20 (Slide.)

21 I think we can certainly date this to the original
22 4T testing of 1975 and 1976 which identified the existence on
23 this load, and resulted initially in an application memorandum
24 describing a load to be applied to the wall of the Mark II
25 containment. This load being basically a damped sinu-soidal

1031 068

sls-14
1 signal with a frequency range of 20 to 30 hertz.

2 This load specification was later finalized, and the
3 bounding loads report. There was another development along
4 the way known as the multivalent hydrodynamic model which
5 represented an attempt to bring to bear under the problem
6 of the essentially random nature of the chugging phenomena.

7 This model we now believe was based on an overly
8 simplified representation of the fluid in the containment,
9 mainly the neglect of compressability and the possibility
10 of developing characteristic diversions in the fluid itself.
11 But it nonetheless did indicate that if one took account of the
12 random nature of chugging, the wall loads would be considerably
13 less than the bounding loads.

14 Another development was the 4T fluid structure
15 interaction study that was conducted by Anamet Laboratories.
16 I will be referring to some of the results of that which bear
17 on this methodology as we go along. There was at the end of
18 that portion of the history, however, still some basic NRC
19 concerns on fluid structure interaction. Namely, that they
20 were concerned that the difference between the fluid structure
21 interaction features of the 4T tank and of the Mark II
22 containment had not been vigorously taken into account in
23 developing wall load for the Mark II.

24 There were also some results coming back which
25 indicated that the responses calculated on the bounding load

sls-15

1 were rather high. And as a result of these two areas of
2 concern, the Task A-16 was initiated with the objective of
3 developing an improved chugging load.

4 (Slide.)

5 The approach that has been taken in the A-16
6 program is first of all to pursue some additional study of the
7 4T data. Second, to develop a model of the 4T system. Third,
8 to develop vent exit forcing functions or what might also be
9 called sources to be applied at the vent exits of a model of
10 the Mark II containment. Fourth, to actually develop a model
11 of the Mark II containment. And finally, I will be talking
12 about some calculations that have been done of actual Mark II
13 responses.

14 (Slide.)

15 The 4T facility, I think there has been a similar
16 picture of already. It was, as you know, designed to represent
17 a single cell of a Mark II plant in the sense that it consisted
18 of one vent and that volume of the suppression pool which one
19 might think of as being associated with a single vent. The
20 range of geometric parameters, such quantity as vent diameters
21 submergence clearance cover the range of the Mark II parameters.
22 And the thermal dynamic parameters, initial pool temperature
23 and brake size for example covered the range of what was
24 anticipated to occur during a postulated LOCA.

25 (Slide.)

1031 070

sls-16

1 The data base that we have concentrated on consists of
2 a library of 137 individual chug events from the total of
3 some 600-odd taken during the entire 4T test. These chugs, we
4 believe, are representative of the worst chugging events that
5 took place during the test in the sense that they contain
6 chugs from those runs in which there was the highest probability
7 of getting a large amplitude event, by which I mean a large
8 maximum peak pressure on the bottom center of the 4T tank.

9 The specific data that we focused on was the bottom
10 center pressure tracers. In examining these pressure tracers
11 we have arrived at the conclusion that they can be divided some-
12 what subjectively, of course, into four basic categories. The
13 first of these is probably what most people think of when they
14 think of the chug, a rather large amplitude damped sinu-soidal
15 signal with frequencies in the 20-30 hertz range.

16 The second category is a lower amplitude sinu-soidal
17 event that persists for perhaps some three and four cycles with
18 frequencies of five, thirteen and twenty-one hertz, typically.

19 The third category is sort of a combination of those
20 two with the damped sinu-soidal signal separate on a lower
21 amplitude sinu-soidal signal and showing frequencies of five,
22 thirteen and twenty-one hertz and frequencies in the 20-30
23 hertz range.

24 And finally, we have what you might think of as the
25 garbage variety chugs which were basically low amplitude events

1031 071

sls-17

1 containing those frequencies that I have already mentioned.
2 And, in addition, frequencies -- a whole host of other
3 frequencies ranging up to maybe 50 hertz. The examination of
4 this data and analysis of it has led us to conclude that the
5 dominant frequencies, mainly the 5, 13 and 21 hertz and the
6 20-30 hertz frequencies, can be attributed to the critical
7 elements of the system which are the vent pipe and the tank
8 pool portion of the facility. And that if one analyzes those
9 separate elements as one dimensional acoustical system
10 containing either steam or water, you can predict that a
11 natural vibration analysis very close to the frequencies that
12 were actually observed in the data. And you find the 5, 13
13 and 21 as being the fundamental and first two harmonics of
14 acoustic vibrations in the vent. And with some proper
15 additional considerations, we found that the 20-30 hertz
16 frequencies can be explained in terms of an organ pipe mode of
17 the fluid in the wetwell.

18 With this conclusion at hand, we then embark on a
19 modeling activity to represent the 4T system. And the essential
20 elements of this system, which I will be discussing now are, one,
21 that the fluid behavior is modeled as that of a linear
22 acoustic fluid. The chug excitation is presented as a point
23 source excitation at the location of the vent exit.

24 We hypothesize after the vent is decoupled from the
25 tank pool system, in the sense that frequencies which are seen

1 as a result of the acoustic excitation of the vent do appear
2 in the pool, and subsequently on the wall.

3 However, those frequencies which aren't excited
4 by an impulsive loading of the pool water are not seen in the
5 vent. The theoretical reason that one would have for believing
6 that is that there is a very substantial impedance mismatch
7 between the water and the steam. The kind of handy-dandy way
8 we have adopted in talking about this is that the fisherman
9 has a great deal of difficulty hearing the fish talk, but the
10 reverse is not true.

sls-18

End t-9

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 We think this applies to analysis of the 4T system.
2 Another element of the model is a sonic speed adjustment which
3 we have used to account for the effect of fluid structure
4 interaction, and I will be saying a bit more about that.

5 And finally, as an element in the development of
6 the model, I would like to mention some chug simulation
7 activities. I think calling this a chug simulation is a bit
8 of a overstatement, to say the least.

9 What it really represents is a wall pressure simu-
10 lation. And I don't want to place too much weight on what this
11 means, so far as the validity of the model. But let me tell you
12 what we did.

13 We arrived at the judgment of looking at the 4T data
14 and the way this model responds, that a meaningful impulsive
15 excitation of the system, that you could represent that by a
16 36 millisecond duration under pressure. The actual functional
17 form we used was a triangular under pressure of 36 millisecond
18 duration -- and let's think of the amplitude as being unde-
19 termined at the moment.

20 Using an acoustic model of the vent, excited the
21 vent with this impulsive underpressure, and say how it responded,
22 mainly in terms of how the first two harmonics appeared in
23 relation to the fundamental, the amplitude of the fundamental.

24 Then, regarding both the overall amplitude of the
25 vent signal and the amplitude of the impulse as adjustable

rm 2
1 parameters, leaving alone the relation between the vent
2 harmonics, we attempted to simulate actual chugs in the 4T
3 data base. I am going to show one example of that.

4 (Slide.)

5 The bottom portion of the figure here is an actual
6 time trace and associated power spectral density plot of the
7 bottom center pressure from chug No. 30 of the 4T test
8 sequence. This is a chug we would place fairly clearly in our
9 No. 1, Category No. 1.

10 The top portion of the figure is the time trace,
11 and power spectral density that we were able to achieve by
12 making an adjustment of the overall amplitude of the vent
13 contributions and the impulse contributions.

14 I think maybe all this says is that with an input
15 function that fits kind of on intuitive feeling about what
16 a chug excitation might look like, we are able with this
17 simplified linearized model of the system to produce bottom
18 pressure signals which appear to be very good simulations of
19 those actually seen in the 4T.

20 DR. CATTON: Do you separate out the 4T's separate
21 characteristics from characterization of the chug?

22 DR. FITCH: No. The model, as it was used to do
23 this simulation, incorporates what we believe to be an adequate
24 representation of the 4T's structural characteristics. I am
25 going to say a little bit more about that.

1 DR. CATTON: I can wait.

2 DR. FITCH: I would like to turn now to some other
3 verification work that was done on the model. And the first
4 thing I would like to mention is some studies that were done
5 with the computer called KFIX which represents the Navier-Stokes
6 equations in a rigid container. And what was done here was to
7 model the steam in the vent, the water in the pool, the actual
8 geometry of the boundary of those two elements of the system.

9 The model was excited, both the vent and the pool
10 were excited with a pressure signal which was of sufficient
11 amplitude to give us the kind of signals that are seen on the
12 bottom of the 4T. And the calculation of the response was
13 made both with and without the viscous terms and the nonlinear
14 convective terms.

15 And we found that those, deletion of those two terms
16 from the representation of the fluid did not have any effect
17 on the response.

18 So we concluded from this that the assumption of a
19 linear acoustic fluid is being satisfied.

20 What this means is that the particle velocities
21 were very small in comparison to the sonic speed and the
22 density and the pressure perturbations relative to their back-
23 ground values, were very small.

24 Additionally, with the use of this model, we confirmed
25 or added confirmation, let's say, to the assumption that

rmg 4
1 frequencies that are generated by impulsive excitation of the
2 pool do not propagate back into the vent, whereas the
3 frequencies that are excited in the vent do propagate into
4 the pool and are seen on the wall.

5 And while we were working with KFIX, we were working
6 on the other hand with our simplified model, using the point
7 source. And we concluded that so far as the character of the
8 fluid response is concerned, that we were able to excite the
9 response of the fluid just as well with a point source
10 consisting of an impulse plus the input to the pool that one
11 would get from the vent, that you could excite the same response
12 as you could in the FKIX model by modeling both the steam and
13 the water.

14 I guess part of that result was the fact that the
15 physical presence of the vent type on the axis of the tank
16 did not have a significant effect on the response. And this
17 was partly expected, because of the one-dimensional character
18 of this working type load response of the pool.

19 Some additional confirmation of our assumptions
20 came from two of the tests that Anamet performed in the 4T
21 facility, one in which they imploded a bell jar, an evacuated
22 bell jar tied to the end of a vent pipe; and a second one in
23 which they dropped a projectile-shaped weight down through the
24 fluid and impacted the baseplate at its center.

25 The response of the 4T to both those excitations

1 was a damped sinusoidal signal, much as we saw in the data,
2 with a frequency of -- that was downshifted from the one that
3 you would calculate for the fundamental organ pipe mode in a
4 rigid tank.

5 And by turning to some centered types of analyses,
6 the type that are done to account for the effect of pipe wall
7 flexibility on the propagation of a pressure pulse, we find
8 that with a relatively simple formula that involves the
9 properties of steel and the fluid, we are able to deduce an
10 adjustment in the summed speed input and an input parameter
11 to the model that will account for the effect of the flexibility
12 of the walls and the baseplate, which is primarily to reduce
13 the frequency of the fundamental response mode of the tank.

14 As a final step in the verification of that method
15 of accounting for fluid/structure interaction, we are pursuing
16 some NASTRAN studies where we have modeled with finite elements
17 both the acoustic fluid and the elastic boundary with full
18 coupling -- and I don't have the final results from those
19 studies at this point; we are just in the middle of this.

20 But that will form, we think, a significant
21 additional confirmation, that our method of accounting for
22 fluid/structure interaction is adequate.

23 (Slide.)

24 The next step in the chronology is to get to what we
25 were after, which was actual load specifications. And the way --

1 our starting point for this was to establish what one might
2 call a simple vent forcing function or source using the model
3 of the 4T and the 4T data.

4 And in doing this, we had the thought in mind when
5 we came to the actual Mark 2 containment application, that we
6 would have a load case in which all of the vents were excited
7 synchronously with the same amplitude signal, so that in trying
8 to come up with a load case that we think is a bounding
9 representation of what could happen during chugging.

10 We tried to balance how the bounding we needed to
11 be with this single vent source against the fact that we were
12 going to be applying this to the Mark 2 plant with all of the
13 vents synchronously firing off at full amplitude.

14 The criteria that we used to develop the single vent
15 source are in terms of the total -- they are derived by looking
16 at the bottom center pressure signal produced when the single
17 vent forcing function is imposed at the vent exit location in
18 our model of the 4T.

19 And we established criteria on the total power in
20 the signal produced, criteria on the power by frequency,
21 and an additional criterion on the peak pressure of the time
22 history of the signal.

23 DR. CATTON: Are you taking that signal that you
24 showed us previously?

25 DR. FITCH: No.

1 DR. CATTON: Or are you decoupling it from the
2 structure, asking yourself what was the source strength in 4T
3 and taking that source strength and going back to the Mark 2
4 and incorporating the structure? Is that the procedure?

5 DR. FITCH: We believe the model we are using to
6 compute this source has incorporated the structural effects
7 by virtue of the adjustment in the sonic speed.

8 There is an additional consideration which involves
9 the damping associated with the structure.

10 DR. CATTON: I don't understand your answer.

11 DR. WU: With this structural bending included,
12 would that be the measured data --

13 DR. CATTON: You have a measured pressure on the
14 boundary. Are you going from the measured pressure on the
15 boundary through a structural analysis and saying, gee, what
16 was the source at the vent exit, and then taking that vent
17 exit source and putting it into a Mark 2?

18 DR. FITCH: Right. I guess I didn't -- I complicated
19 it.

20 DR. CATTON: Yes, you did.

21 (Laughter.)

22 DR. FITCH: The source has the same character as
23 the source that I described earlier in the simulation study.
24 We did not constrain ourselves, as I mentioned, at that point
25 we were trying to simulate an actual chug, one individual chug,

1 so that we were adjusting the amplitude of the impulse of the
2 vent signal to do that. We now play that game all over again,
3 trying to satisfy the specific criteria.

4 I haven't told you specifically what they were, but
5 I have outlined them in general. And having determined the
6 source which satisfied those criteria, we then needed to account
7 for differences between the 4T and the Mark 2.

8 And the most notable of those is the difference
9 the shorter vent lengths of the Mark 2. So that we recognized
10 that we had to adjust those frequencies that we associate with
11 the vent, the excitation of the vent in the 4T during
12 chugging by a factor to account for the shorter vent length
13 in the Mark 2 plant.

14 Having done that, we then assigned -- we identified
15 Load Case 1, I have called it, where that vent exit forcing
16 function is assigned to all of the vents synchronously. And
17 we subsequently developed a Load Case 2 which is an attempt to
18 again look at the random nature of chugging and make some
19 allowance for the possibility that during the course of the
20 chugging portion of a blowdown, you could develop an asymmetry
21 in the force exerted on the containment.

22 So that we have a second load case which again uses
23 this same single vent forcing function as its basic building
24 block, but applies a circumferential multiplier which is
25 intended to cover the possibility of an asymmetric loading.

1 I will show you a little more detail on a single
2 vent forcing function.

3 (Slide.)

4 I think the most revealing way to look at it is in
5 terms of the power spectral density of the bottom center
6 pressure produced by the single vent forcing function applied
7 in the 4T model versus what I have compared it with here, the
8 average power spectral density on the 137 chugs in the data
9 base.

10 Now, I think the first thing to observe is that
11 the PSD produced by the forcing function envelopes all of the
12 peaks of the PSD, the average PSD from the pit data base. It
13 also obviously included a considerably greater total signal
14 power.

15 The main reason for that is this spectral peak at
16 28 hertz which kind of stands out. The reason why we felt it
17 was necessary to put in that additional signal power in that
18 frequency range is to cover the possibility that all of these
19 vents could simultaneously produce one of these major ring-out
20 type chugs --

21 Those chugs form such a relatively small portion
22 of the data base, even when you are conservative in the choice
23 of your data base, that that spectral peak tends to be squashed
24 out in the averaging process so that you don't see it in the
25 PSD of the data, that we know it is there, in individual chugs.

1 And we felt that it was necessary to make allowance
2 for it.

3 We do have a couple of locations where we are not
4 absolutely enveloping the average PSD, and we think those need
5 attention. But we don't think that they are going to be a
6 serious problem as far as the load definition is concerned.

7 (Slide.)

8 One more picture on the single vent forcing function.

9 DR. ZUDANS: How did you get that first peak of
10 the average to coincide with your forcing function?

11 DR. FITCH: By tuning the knob that we have available
12 on the amplitude of the portion of the forcing function that
13 we attribute to the acoustic signal excited in the vent. We
14 just cranked it up alone -- we were working with the amplitude
15 of the impulse, and the amplitude of the sinusoidal portion of
16 the signal, and we cranked them up until we got the desired
17 response.

18 DR. ZUDANS: You give me an answer to the next
19 question, and that is, how did it get on your average? When
20 you averaged 137 individual chugs, it has to be pretty much
21 of a coincidence or pretty much of a playing with the time
22 shift between chugs to get the first peak on your recorded
23 chugs, not on your forcing function, the first big peak.

24 DR. FITCH: The fundamental of the vent was very
25 consistent.

1 DR. ZUDANS: You didn't have time shift, nothing?

2 DR. FITCH: No. The 5 hertz signal was always there.

3 DR. ZUDANS: And the second single vent forcing
4 function peak, is that realistic? When you played with the
5 first one to match it, I guess you got the second one as a
6 fringe benefit.

7 (Laughter.)

8 DR. FITCH: That would be attributing too much to
9 what we did. I mentioned that when we did the simulation study,
10 I fixed the relative amplitude of the fundamental and the
11 first harmonic. When we played this game of getting the
12 forcing function which enveloped the data, I removed that
13 constraint.

14 So that we, as it turns out, I think the relative
15 amplitude of those two peaks is not unlike what it would be
16 if you excited the model of the vent separately, but that was
17 not an imposed constraint when we did this.

18 DR. CATTON: This is not your vent exit source
19 that we are looking at?

20 DR. FITCH: No, this is the bottom center pressure
21 signal produced when we crank that source into the model.

22 DR. CATTON: You are going to take this and back
23 out a source?

24 DR. FITCH: Yes. We have backed out a source, and
25 a source produces the dashed line.

12

1 DR. CATTON: I understand.

2 DR. ZUDANS: If you remember our previous discussion
3 of the resonance and things of that nature, if you eliminate
4 that possibility, because actually you took the structure
5 flexibility by adjusting your sonic speed, the pipe only,
6 right?

7 DR. FITCH: On the water.

8 DR. ZUDANS: Now, in this case your forcing
9 function frequency content is strictly determined by the
10 structural and water characteristics, right, not by forcing
11 function -- it might account for some other physical reasons
12 in there?

13 DR. FITCH: The frequency content accounts for the
14 response of the steam in the vent. That is the first. And
15 the dominant signals that we see in the 4T data --

16 DR. ZUDANS: The structural and acoustic.

17 DR. FITCH: And the vent pipe acoustical frequencies.
18 So the forcing function which is not applied as a point source
19 must incorporate both the vent pipe excitation -- one might
20 think of the vent pipe now as a separate element exciting
21 the tank pool system.

22 The source must incorporate those frequencies and
23 also have the capability of exciting the tank pool system in
24 such a way as to envelope or bound in an appropriate sense the
25 frequencies that we attribute to that portion of the system in

1 the data. That is where the impulsive part of it comes from.

2 And the importance of modeling the fluid in the tank
3 as a compressible fluid is that you now have the capability
4 of picking up this resonance where we see it in the data.

5 DR. ZUDANS: I think what you say is clear and
6 precisely stated. What bothers me a little bit is chugging
7 being something that you could see that had more source than
8 water and steam did at these relative volumes of the system.

9 Now, you have the dominant frequencies strictly
10 defined by certain modes of the critical combination of water
11 and space that volume would respond to?

12 DR. FITCH: That is essentially correct.

13 DR. ZUDANS: And then when the water condenses in
14 the steam, it excites these things and that is what we see,
15 for the most part.

16 There is nothing inherently physical in the steam
17 condensation process itself that you could -- that you would
18 have to identify when you describe the configuration accurately.
19 In terms of the linear multiple response, you have all you need;
20 is that a correct statement?

21 DR. FITCH: Yes. That is what this method is based
22 on. I think -- the answer is yes.

23 DR. WU: Similar to this, have you tested the --
24 your point source representation by checking with the predicted
25 pressure elsewhere -- how many places have you checked the

4
end #10

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

pressure measurement versus the energy frequency distribution
at the site of the wall or other places?

341 11 01

WH 1 We have not done that in any kind of detail. That
2 should be done. The pull response, according to the
3 prediction, is essentially a quarter sine wave, standing
4 from the bottom to the top, and it should be possible to
5 ascertain that. We have started on that, but I just don't
6 have anything concrete to say about it at this point that is
7 good additional verification.

8 DR. WU: This might explain the mechanism of the
9 chugging to see if it is really a point source or if the
10 acoustic effects might be important. You might have some
11 other mechanism involved like the vortices.

12 DR. FITCH: If we get a tilt when we make the
13 comparison --

14 DR. ASHLEY: The library we used to develop these
15 sources from consisted of bottom-center pressure. There were
16 some tests done by Anamet Laboratory with the same tank
17 where the bell jar collapsed where they measured and have
18 produced and sent to the NRC the standing wave pattern, and
19 it is the quarter standing wave, and it is produced by this,
20 because it is the solution of the acoustic wave in the
21 tank.

22 So insofar as that confirmation has been done, but
23 not for each chug of the 137.

24 DR. WU: Standing wave with respect to what?

25 DR. ASHLEY: In the fluid portion of the 4-T test

1031 088

341 11 02

1 tank. It is a quarter standing wave.

2 DR. FITCH: That was the implosion of the
3 evacuated bell jar. That was the response. In that test,
4 they had a nice sequence of transducers up the wall and you
5 can fit them with the quarter wave pressure variation.

6 DR. WU: That is very interesting. Thank you. It
7 is easy to match the standing wave and the point source
8 easily?

9 DR. FITCH: We can reproduce the quarter standing
10 wave pattern as measured.

11 DR. ASHLEY: Yes, we developed some impulsive
12 source and then normalize it to unity pressure.

13 (Slide.)

14 DR. FITCH: One more figure on the single vent
15 forcing function. The bottom pressure trace. In time it
16 may not look an awful lot like any individual chug, but I
17 think that the reason for this can best be explained by
18 saying that we have here a composite chug in an attempt to
19 suitably bound all of the power to all of the individual
20 frequencies, and that is the essential basis on which the
21 validity of this source rests.

22 We have, as I mentioned earlier though,
23 established a criterion on peak pressure because we thought
24 that was important. The predicted peak pressure of 9.5 psi
25 is quite conservative, relative to the data base we were

POOR
ORIGINAL

1031 082

macBWH

1 working with. I am not stating that that is an absolute
2 bounding peak pressure. I think it is appropriately
3 conservative for the way these loads will be applied in
4 containment.

5 DR. ZUDANS: Since you have really worked with a
6 linear system, you could apply this to multiple vents just
7 as easy.

8 DR. FITCH: Right.

9 DR. ZUDANS: I'm sorry.

10 (Laughter.)

11 (Slide.)

12 DR. FITCH: The final step is the Mark II
13 containment model which has again been based on this linear
14 acoustical representation of the fluid chug excitation
15 sources and each of the vent exit locations. The
16 calculation of the Mark II force response I am going to be
17 showing you has been carried out with a procedure described,
18 among others by Professor Sonon at MIT, in which you first
19 calculate rigid wall loads and then apply those rigid wall
20 loads to a model of the flexible structure with appropriate
21 account taken of the fluid.

22 I might mention also as part of the program, we
23 have a NASTRAN model of the Mark II containment being
24 cranked up in order to verify the particular set of computer
25 programs and procedure that is now being used to do that.

POOR
ORIGINAL

1 The results I will be showing you from Mark II response will
2 be an acceleration response spectra at a couple of selected
3 locations.

4 (Slide.)

5 There are a couple of points of importance here.
6 I am going to show you a couple of pressure histories on
7 containment from rigid wall pressure histories from this
8 location and then acceleration response spectra on the
9 pedestal near here.

10 (Indicating.)

11 And on the containment wall about here.

12 (Indicating.)

13 (Slide.)

14 The next two figures show the rigid pressure wall
15 pressure traces associated with our symmetric, so-called
16 symmetric, all vents in unison load and the asymmetric
17 load. And I apologize for changing units. These are
18 plotted in roughly 7 X psi. That is for that location down
19 at the bottom of the containment wall by the base.

20 I think I will just skip over the asymmetric one.
21 There is nothing significantly different about it. This is,
22 perhaps, not surprising when you think about it, but we
23 really, in terms of a rigid wall load, no longer have a
24 perfectly symmetric wall on the containment.

25 (Slide.)

macBWH

1 This is due to the nonuniform azimuthal
 2 distribution of the vents in the Mark II plants. There is
 3 actually some variation in the rigid wall load with
 4 angle, not -- it is about half of what the variation is with
 5 the deliberately asymmetric load. But nonetheless it is
 6 significant.

7 (Slide.)

8 Here is the acceleration response spectrum for the
 9 point that I showed you on the top of the pedestal compared
 10 with the result obtained by using the current bounding load
 11 specs. There has been achieved with this load a significant
 12 reduction in the response.

13 (Slide.)

14 And a similar plot for the containment locations
 15 that I showed here. And finally I would like to get a quick
 16 summary up here.

17 (Slide.)

18 I would like to say that these are the things we
 19 have achieved with the A-16 program. First, we have
 20 developed forcing functions which we believe we can
 21 establish our bounding representations of what an actual
 22 Mark II containment could be subjected to during the
 23 chugging phase of a LOCA, that we think we have provided a
 24 basis for modeling the differences between the 4-1 system
 25 and the actual Mark II plant, and unscrambling that part of

BWH

1 the problem.

2 And finally that we have computed acceleration
3 response spectra which are significantly reduced from those
4 that you would calculate using these current different load
5 specifications.

6 DR. ZUDANS: So you apply this same source at
7 every one of the events, and you took the acoustic
8 characteristics of the entire containment instead of just
9 4-T, and you added all of the individual number of modes for
10 each of the vent. And that is what you got, what you have
11 shown us now?

12 DR. FITCH: That's correct. Yes.

13 DR. ZUDANS: Is there a report where this is
14 discussed. It sounds like it is an extremely interesting
15 piece of work.

16 DR. FITCH: Who can speak for the report at this
17 time? Gordon?

18 DR. ASHLEY: There is a report in preparation that
19 will be sent to the NRC, probably the middle or the end of
20 November, and it will be made available to you.

21 DR. ZUDANS: It is very good work.

22 DR. PLESSET: Fine. Thank you, Mr. Fitch. We
23 have another presentation before we have our break. Also
24 scheduled for 30 minutes.

25 (Laughter.)

POOR ORIGINAL

mcbwh

1 MR. DAVIS: I am Mac Davis from General Electric.
2 I will try to get us back on schedule.

3 (Slide.)

4 What I will be discussing with you today on the
5 CAORSO test is briefly going over the test configurations,
6 what the objectives of the tests were, just an
7 instrumentation summary of the test matrix, and the results
8 of the phase I test, some preliminary results of phase II,
9 and then our conclusions from the test to date.

10 (Slide.)

11 This we have seen a couple of times today which is
12 a cross-section of the Mark II plant.

13 (Slide.)

14 This slide will show you the arrangement of the
15 quenchers in the CAORSO plant. I have indicated that when I
16 talk about the multivalve phase II test a little bit later,
17 what the groupings were for the various multiple tests.
18 Unfortunately, my slide is color-coded and your copies
19 aren't coded at all, but you can see the are the two
20 quenchers that we used in the two vent test, the purple and
21 the green. It is shown here.

22 (Slide.)

23 The objectives of the test were to confirm the
24 load definition that we had provided in the DFFR and also to
25 provide a data base for future load reduction after the

841 11 08

m SBWH

1 earlier users, if there were any, of the quencher. And the
2 things that we looked at and tried to provide data for were
3 the pool boundary pressures. We looked at the response of
4 the building with accelerometers. We looked at the
5 discharge line clearing and reflood that occurs after an
6 actuation of a quencher, response of the quencher itself due
7 to the air bubble and air clearing loads.

8 We looked at cool thermal mixing from an extended
9 blowdown and we — that's some qualitative data on what
10 would be happening to submerged structures and some strain
11 gauges and some instrumentation on the liner itself and on
12 the downcomer.

13 (Slide.)

14 Just kind of a total assessment of the
15 instrumentation that we had in the test. It was rather
16 extensive. There were approximately — this is about 185 or
17 190 sensors in total. For the suppression pull itself in the
18 quencher and safety relief valve line, we measured the
19 pressure, temperature. We measured the strain in the pipe
20 and the quencher itself, accelerometers on the quencher
21 itself, and we were looking at the water level in the pipe.

22 On the containment structure, we had strain gauges
23 and accelerometers. We measured the vacuum breaker flow for
24 one of the — on one of the safety relief valve lines that
25 we did multiple testing on, and we looked at the stem

841 11 09

mccBWH

1 position which told us when the valve opened, and then we
2 had nine other miscellaneous sensors located.

3 (Slide.)

4 Just a summary of the phase I test. And this by
5 the way, this information has been reported, and it has been
6 submitted recently to the NRC.

7 On the phase I testing -- this is a summary of the
8 type of tests we ran. In the phase I, we ran single valve
9 tests only, no multiple valve, and we ran first actuation
10 tests, and we ran consecutive actuation tests to see what
11 was occurring as a result of having various things going on
12 in the piping system after the first actuation.

13 And during these tests we varied these
14 parameters. The water leg. We varied the pipe temperature
15 from cold, warm, to hot. We varied the vacuum breaker area
16 to see what the effects of the vacuum breaker on the reflood
17 transient, and then we changed the valve that was actuated,
18 and we used four different valves in the test.

19 In phase II we repeated tests of the single valve
20 tests, which also included some testing, varied the vessel
21 pressure, to get an indication of what the change in
22 boundary loads were as a function of vessel pressure. We
23 had 11 multiple valve actuations, and we ran some leaky
24 valve tests. We didn't really plan these tests, but we --
25 it had been requested many times by the NRC to run a leaky

341 11 10

macBWH

1 valve test, and you might say we were lucky that we had a
2 leaky valve.

3 (Laughter.)

4 We ran one extended valve blowdown, and we also
5 varied the number of vacuum breakers utilized. We varied
6 the pipe temperature, the vessel pressure, and then we
7 changed the valve groupings.

8 (Slide.)

9 These are the phase I test results which are in a
10 report that has been submitted. When we look at these
11 comparisons, I have one column here that says "Maximum Test
12 Values" for various conditions.

13 One is the first actuation. One is the
14 consecutive actuation. And when we look at these, we have
15 picked out all of the data points the maximum positive
16 pressure and the maximum negative pressure which don't
17 necessarily occur on the same test point. We have
18 calculated using the DFFR methodology predictions for both
19 the mean 90-90 values for the boundary pressure.

20 These are calculated based upon the nominal
21 conditions for first actuation and the same for consecutive
22 actuation, and you can see that there is a significant
23 difference between test data and what our predictive values
24 are using our DFFR methodology.

25 The predominant bubble frequencies were from 5 to

1031 097

841 11 11

macBWH

1 11 hertz. We did observe in the tests pressure attenuation
2 which seemed to be more rapid than what we have used as our
3 methodology from the DFFR, and the attenuation with distance
4 was a little bit less -- a little bit greater than what we
5 used for our methodology.

6 I would like to point out that when you are
7 looking at these values and trying to make some assessment
8 of how conservative the predictions might be relative to the
9 test data that there are quite a bit of efforts going on in
10 looking at this data to better define what this conservatism
11 might be, and Burnes & Rowe is doing a detailed evaluation
12 of this data, primarily looking for how you apply it to Mark
13 II plant, rather than just plain old data report.

14 They are addressing it for application in their
15 particular plant.

16 DR. BUSH: Was time a parameter in your
17 consecutive actuation?

18 MR. DAVIS: Yes, we varied the time between
19 actuations. I don't remember the exact values, but we did
20 vary the times between the actuations.

21 DR. BUSH: Did you reach -- is time a critical
22 path?

23 MR. DAVIS: We believe we tested at the most
24 critical time variation for the consecutive actuation.

25 DR. BUSH: So time was another variable in your

1031 098

m-BWH 1 matrix?

2 MR. DAVIS: That's true.

3 DR. PLESSET: The predictions on DFFR, was that
4 for a quencher?

5 MR. DAVIS: For a X-Quencher.

6 DR. PLESSET: Like the test.

7 MR. DAVIS: Yes, and it is predicted using the
8 parameters of the CAORSO plant itself.

9 (Slide.)

10 Other parameters that -- test results are the
11 discharge line pressure. Pressure in the line agreed with
12 the predictions. We did confirm the effects of the vacuum
13 breaker side on the reload transient. That means how far
14 the water level, how far it reentered the line after the
15 valve was actuated. The dynamic stresses on the quencher
16 were less than what we predicted. Our maximum measured
17 building response from the suppression pool loads were less
18 than .07G, which is a very low value.

19 The liner strains were below predictions, and the
20 bending strains were less than what we predicted.

21 DR. BUSH: How are you defining "dynamic
22 stresses"?

23 MR. DAVIS: The dynamic response of the quencher
24 strain gauges, strain gauges on the quencher.

25 DR. BUSH: If the time interval is low, then I get

macBWH

1 a totally different response than if it is longer, which
2 means it is quasi-static, and I want to know if these are
3 truly dynamic stresses or not.

4 MR. DAVIS: These are dynamic stresses in that the
5 puncture arm is oscillating at a high rate.

6 DR. ZUDANS: And you had this strain gauge trace?

7 MR. DAVIS: Right.

8 (Slide.)

9 On the phase II results, and we are just in the
10 process of putting this report together, the single valve
11 test is very consistent with the phase I testing. Relative
12 to the multiple valve boundary pressures, they are relative
13 for four and eight valves, and our maximum test predictions,
14 our maximum predictions are shown over here, using the DFR
15 methodology again. And the maximum values we got out of the
16 test are shown here, and, again, you can see that there is a
17 significant test between the predictions and the values.

18 Again, this data is also being looked at by WPPSS
19 as part of a plant application. During the 13 minute
20 blowdown, we looked at the distribution of temperature in
21 the pool. It looks like there are approximately 10 degree
22 temperature differences between LOCA, bulk and LOCA.

23 Relative to our conclusions on this, we feel that
24 we met the objectives of the test. The data was consistent
25 and repeataole. The predictions of what is going on in the

mccBWH

1 plant compared well with the test data. The boundary
2 pressures were well below what we predicted, and I think we
3 have shown that the DFFR methodology is conservative, and
4 there is some work going on which will show it is more
5 conservative than you might subjectively get from these
6 slides.

7 DR. CATTON: How important is it that you know the
8 LOCA to bulk Delta-T? What role does it play?

9 MR. DAVIS: When we look at the pool temperature
10 limit as defined by the NRC criteria of 200 degree LOCA,
11 when you look at all the various transients you can have in
12 a plant, you want to be sure that you stay at or below that
13 200 degree local temperature and the quencher, as far as the
14 importance it plays. It gives you a value to compare your
15 calculated bulk cooled temperature, which is the way we do
16 our analysis with the local temperature and the NRC criteria
17 of 200 degrees.

18 The 200 degrees is something we had accepted,
19 although we feel --

20 DR. CATTON: I understand that. Now what I am
21 wondering, then, is how did you locate the thermocouples
22 that measured this -- what do you mean by local
23 temperatures? Is it maximum temperature?

24 MR. DAVIS: In that area of the pool that is
25 feeding the steam jet as it comes out of the quencher

macBWH 1 itself.

2 DR. CATTON: How do you know where to put the
3 thermocouple relative to the quencher. If you put it too
4 close, you are going to measure saturation.

5 MR. DAVIS: We had some on the quencher. We had
6 some at various locations from the quencher and around the
7 pool. I think it would be best if I tell you that we are
8 putting the report together that evaluates this data,
9 relative to the bulk to LOCA pool temperature without trying
10 to jump ahead as to what the conclusions are.

11 DR. CATTON: I can see where you could get
12 whatever local to bulk LOCA Delta-T by picking a
13 thermocouple, so there has to be some volume that you
14 average. I would be interested in seeing the mechanics you
15 go through, particularly the rationalization.

16 MR. DAVIS: That's all I have. Before we take a
17 break, if we could, Ray Muzzy has the answer to Dr. Catton's
18 question.

19 MR. MUZZY: The question was concerning the high
20 speed channels of the 4-T CO test. We are recording the
21 data on analog tape, and we are digitizing the tape at the
22 rate of 1000 samples per second.

23 DR. CATTON: Thank you. That is quite adequate.

24 DR. PLESSET: Very good. We will take a 13 minute
25 break until 3:15.

1031 102

841 11 16

(Laughter.)

(Recess.)

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1031 103

BWH

1 DR. PLESSET: Let's reconvene and go to the next
2 presentation on the GKM test. Would you proceed.

3 MR. ROTH: I am from Pennsylvania Power & Light
4 Company. I am here to discuss tests that we will be running
5 in the GKM facility in Manheim, Germany. You heard this
6 morning from Ray Muzzy, of GE, a discussion of the decision
7 that was made to run a full-scale condensation oscillation
8 test. At the time that decision was made, PPL made a
9 further decision to proceed with their own test on a
10 prototypical basis at Manheim in the GKM facility. That was
11 made in January of '79.

12 At that time, we were actively pursuing meeting a
13 May of '80 fuel load date, and our review indicated that the
14 GKM test would provide us with data earlier than they
15 proposed for two tests. And in addition, the GKM test
16 facility could be modified to more exactly represent the
17 Susquehanna single cell and, hopefully, give us data which
18 would be more prototypical of the Susquehanna configuration
19 of containment and would, hopefully, expedite our evaluation
20 of that data and licensing review that would go along with
21 that to meet the May of '80 fuel load date.

22 Since the decision was made, a lot of things have
23 happened, and presently we are working toward a December of
24 '80 fuel load date. And the urgency of the test is sort of
25 not as bad as it was. The decision was made early this

BWH

1 year, and the primary reason was scheduling.

2 The next slide is the schedule of the test.

3 (Slide.)

4 Presently, we have just — we are just beginning
5 shakedown. Hopefully, next week we will begin shakedown of
6 the facility and actual testing will begin the first part of
7 October.

8 (Slide.)

9 One of the benefits we saw from the GKM facility
10 was the ability to represent more exactly the parameters of
11 the Susquehanna single cell. This slide lays out the
12 parameters that we did match in the GKM facility, and we
13 will go through them all. They are all there. The drywell
14 volume, wetwell air space volume, the unit cell, the vent,
15 submergence clearance to the bottom, flexibility of the
16 walls. They were all modified to match the single cell at
17 Susquehanna.

18 (Slide.)

19 We did have to do a lot of modifications to the
20 GKM tank, and this shows what we did at the facility. If
21 you are familiar with the tests that were run at GKM by KWU,
22 they included a flexible wall to simulate the flexibility of
23 the German BWRs. That was removed. We added a new drywell
24 in the tank. We included a new inner cylinder in order
25 get the right unit cell area. We stiffened the tank

BWH

1 foundation for structural reasons. We included a
2 prototypical vent and bracing system for the Susquehanna
3 configuration.

4 We added a viewing port in order to get some
5 high-speed photography of the occurrences at the end of the
6 vent, and we added a couple of submerged structure targets
7 -- quencher arms and wide-flanged beam -- to get additional
8 data on submerged structure loads.

9 The next slide is one you may have seen before.
10 (Slide.)

11 It is the GKM tank. What it looked like prior to
12 the modifications we made. This is what it looks like when
13 it was used by KWU for their test. I have indicated up here
14 in green on the flimsy where we had to cut the facility in
15 order to make modifications.

16 The next slide shows what it looks like today.
17 (Slide.)

18 Again, the green line sort of corresponds with the
19 green line on the previous slide. The dimensions are all
20 millimeters here. The old tank essentially is now the
21 wetwell boundary for our modified tank. We added a new
22 drywell. In order to get the correct unit cell, like I
23 said, we included an inner cylinder in here. The dimension
24 of the cylinder is about 100 millimeters thick. That was
25 necessitated by getting the correct flexibility of the wall

BWH

1 to match the Susquehanna flexibility.

2 We included down here a viewing port and hope to
3 get some good movies, high-speed photography, at the end of
4 the vent.

5 The foundation was stiffened, and we included in
6 there the vent stiffness up here, and the bracing elevation
7 was matched. Down here we show the target quencher arm was
8 to be located beneath the vent exit at the right elevation
9 corresponding to that in the Susquehanna plant.

10 In addition, there is another target beam situated
11 about this elevation. It is not shown in this slide, but is
12 shown in a subsequent slide.

13 (Slide.)

14 DR. BUSH: Did I understand you to say that the
15 100-millimeter wall was to simulate the concrete, the
16 reinforced concrete?

17 MR. ROTH: Yes. That is shown -- that is shown on
18 this additional slide.

19 (Slide.)

20 The instrumentation, we have about 60 channels of
21 instrumentation, measuring pressures and temperatures in the
22 drywell in the vent, the wetwell air space, and the boundary
23 of the pool. Also plan to measure the water level in the
24 vent, the air content in the vent, by a continuous system,
25 and I hope we have a sample, a grub sample, and measure

BWH

1 displacements on the vessel, indication of any movement,
2 measuring the strain on the vent, and the bracing and the
3 quencher arm and the forces on the target beam and movies of
4 the vent exit.

5 (Slide.)

6 The next two slides show a little bit more of the
7 instrumentation, the layout of the instrumentation. It is
8 self-explanatory, really. This gives you an overall
9 representation.

10 The next slide goes into a little more detail down
11 in the wetwell portion of the tank, a little more exactly.

12 (Slide.)

13 This shows a little bit better the inner cylinder
14 that was added in here in order to get the right area. You
15 can see in this one indication of the target beam.

16 DR. HANAUER: Are there strain gauges on the
17 downcomer?

18 MR. ROTH: Yes. They are not shown on that slide,
19 but there are strain gauges. They may have been added after
20 this slide was made, but I can assure there are.

21 (Slide.)

22 The next slide shows a cross-section at the
23 bracing elevation. Included in here, two braces, 90 degrees
24 to each other. This brace, this configuration here, the
25 connection to the vent, is prototypical of the connection we

BWH

1 have in the Susquehanna. This brace portion extends through
2 the inner cylinder and is actually attached to the outer
3 cylinder. The outer cylinder is the old tank, and this
4 represents the new inner cylinder, and we will be measuring
5 the strain on that brace from the collapse of the steam
6 bubble somewhere around the vent here (indicating).

7 The next slide clarifies that a little bit more.
8 You see here the same representation from the previous slide
9 blown up, and this is a cross section through that. This is
10 a connection of the vent to the brace. The brace passes
11 through the inner cylinder and is attached to the outer
12 cylinder here. The strains are read in this section here,
13 and we put a flexible coupling to protect the strain gauges
14 (indicating).

15 (Slide.)

16 The last slide is the test matrix as it exists
17 today, basically doing 10 tests, individual tests, and then
18 a repeat test at each matrix point. It shows 20 tests, but
19 it is actually 10 variations. We are varying the steam mass
20 flux pool temperature during somewhat the air content, and
21 everything else that we feel is prototypical of Susquehanna,
22 so we don't intend to vary submergence or anything else.

23 DR. PLESSET: Any questions?

24 (No response.)

25 DR. PLESSET: Thank you.

BWH

1 DR. MARK: This will be run with compressed air or
2 steam?

3 MR. ROTH: Steam.

4 DR. MARK: I noticed, in the last chart, "Air 100
5 percent."

6 MR. ROTH: That means air content in the drywell
7 prior to the tests. One of the concerns is that there may
8 be differences in the air content.

9 DR. ZUDANS: A little observation. You have the
10 quencher arm sticking out one side, and you also have an
11 I-beam on the other side. You are going to measure lateral
12 loads on this downcomer? You have strain gauges in two
13 directions. Are you going to be able to decipher where they
14 come from, whether from fluid interaction with these
15 asymmetric pieces of structure that are there or because of
16 some condensation process?

17 MR. ROTH: Generally, the lateral load, the peak
18 lateral load in the bracing, is due to the collapse of the
19 steam bubble.

20 DR. ZUDANS: Generally. But you do have
21 asymmetric protrusions that will affect the flow of water
22 and impinge on the sides.

23 MR. ROTH: The quencher arm is located directly
24 under the -- it is relatively symmetric, although, of
25 course, it doesn't extend all the way across the pool. You

BWH

1 are right. The target beam is asymmetric in the pool. I
2 don't know if that would influence the measurement. Really,
3 the maximum load we are going to see is due to the collapse
4 of the bubble.

5 DR. CATTON: Where is the pressure transducer, the
6 one you are going to measure the pressure with?

7 MR. ROTH: The pressure where?

8 DR. CATTON: Dr. Zudans questioned the arm. If
9 you are measuring it at the bottom, the arm is between you
10 and the bottom of the downcomer?

11 MR. ROTH: I think that is offset somewhat.
12 Is it directly under?

13 DR. ASHLEY: It is at the bottom center. We are
14 looking at a quarter standing wave in this tank and not much
15 fluid motion after the jet clearing is through the chugging
16 CO regime. It is basically a standing pressure wave.

17 DR. CATTON: The pressure transducer is underneath
18 the arm.

19 DR. ASHLEY: There is one bottom dead center and a
20 string of them up the side of the tank also. I believe that
21 the arm is instrumented.

22 MR. ROTH: I think we have sufficient pressure
23 gauges throughout the pool. We won't be relying just on the
24 one pressure gauge. This is the one you are concerned about
25 (indicating).

BWH

1 DR. CATTON: It is masked from the vent.

2 DR. ZUDANS: It doesn't matter where the pressure
3 gauge is located. My concern is that it may not have
4 significant impact on the results. It may not have any at
5 all. The only thing is that you are not going to get the
6 clean answer to the question that you are raising.

7 Condensation loads on the downcomer, they will be affected
8 by the fact that there is perturbations of flow due to
9 elements that are hanging out there in a nonsymmetrical
10 fashion.

11 Now, even if you measure all of the pressures on
12 all of the surfaces, they still have the same inability. Is
13 it important? I don't know.

14 MR. ROTH: We will have to think about that.

15 DR. ASHLEY: The load on the vent or the downcomer
16 is essentially caused by a local condensation phenomena.
17 The bubble sneaks up on the side and then collapses or
18 collapses in some asymmetric manner and water rushes in from
19 the side and creates the load. It is not created by a
20 pressure field in the water itself. That is a smaller
21 event. This the best thinking of both the German people and
22 people at General Electric, I believe.

23 DR. ZUDANS: You precondition in your own mind
24 that that is what you will be looking for. My question is
25 very simple: Is it possible to, in fact, have a clean test

BWH

1 like that?

2 DR. ASHLEY: You will know the pressure field
3 throughout the water portion. You will see if there are
4 asymmetries introduced because of the protrusions.

5 DR. ZUDANS: I have nothing more.

6 DR. BEDROSIAN: Our presentation will serve the
7 purpose of presenting a summary of our efforts in defining a
8 chugging load and methodology for application for WPPSS
9 No. 2 for the specific purpose of applying it to WPPSS-2.

10 (Slide.)

11 This might give you some background of what has
12 happened. We basically developed the chugging load
13 definition and the methodology for the Mark II containment
14 for specific application to WPPSS-2. And we had some
15 meetings with the NRC staff in late '78. We had some other
16 meetings with the NRC staff and consultants in the early
17 1979. And we also submitted to the NRC a summary in 1979
18 and a technical report in June of this year.

19 This presentation is concerned with the phenomena
20 which occurs in the tail end of the LOCA with the chugging,
21 which occurred in the Mark II plants. And we think the
22 conditions in this cross-sectional view of the Mark II plant
23 are like this at that time.

24 The steam -- at that time, the flow of steam is
25 established from the pressurized drywell through the vents,

BWH

1 and at the vent exit there is an interface between the vents
2 and the water surrounding it from the suppression pool, and
3 that is the steam condensers. Because of the reduced flow
4 rates of steam, the surface is not stable, and it collapses.

5 (Slide.)

6 This is an impressionistic view of what is
7 happening at the vent, and shows the interface of the water
8 in the pool. And as we said, the phenomenon is basically
9 representative of this interface, and the interface
10 collapses, and the net effect is to induce a forcing signal
11 which shows the event in the suppression pool.

12 (Slide.)

13 The next slide represents, in summary, the
14 problem. It explains our understanding and also indicates
15 our approach in answering the two questions we were asked.
16 The first was to define a chugging load definition and then
17 look at the available test data and then apply it to the
18 Mark II containments, the chugging load conditions.

19 If a forcing signal is imparted to the vent above
20 the vent exit, it excites the pressure in the vent and the
21 pressure wave in the pool. These reflect and interact, and
22 in the end of the -- traveling through the pool, reach the
23 pool boundary, at which time we label this as a "pressure
24 wave." When applied to this flexible boundary, the boundary
25 will reflect, and then it will interact with the water

BWH

1 contained behind it, and that will give rise to an
2 additional pressure perturbation, which we labeled "FSI," in
3 the common terminology.

4 This is the part that is the result of the
5 interaction between the containment boundary and the
6 containment water. This is really what one has available
7 from the records of boundary pressures from the tests.

8 In terms of the two questions we had to answer,
9 first, we had to solve the first problem, which means, given
10 a set of pressures at the boundary of a test facility and
11 its associated geometry, we had to express the forcing
12 function which, at this point, becomes independent of the
13 geometry of the test facility. And it may be transported
14 into a Mark II and used for design conditions of the Mark II
15 containment, assuming that the conditions in the test are
16 reflective of conditions expected in the Mark II during
17 chugging loads.

18 (Slide.)

19 The answer to the first question started with the
20 data developed in GE's 4T test facility. This test was
21 representative of the Mark II conditions during a LOCA
22 event, including long-term effects such as chugging. And
23 furthermore, the facility approximated a unit cell in the
24 Mark II geometry, the vent size. And for these conditions
25 -- or because of these conditions which were duplicated in

BWH

1 the test facility, we considered that the load extracted
2 from these test results would be a load which could be
3 extrapolated for Mark II containment.

4 (Slide.)

5 This is a picture of the 4T facility. It was
6 described before. The only difference between the 4T
7 facility and the Mark II is the length of the vent for the
8 downcomer vent. And since our load definition was extracted
9 independent of this vent length, we made it portable to a
10 Mark II without further assumptions. But we had to address
11 that.

12 (Slide.)

13 In answer to the first question of how to define a
14 single vent design load specification, since the test data
15 was available from a single vent test facility, the 4T
16 facility, we followed, in short, the three steps summarized
17 on this chart.

18 (Slide.)

19 First, we analyzed the 4T boundary pressures, and
20 tried to identify certain characteristics. And there we saw
21 the chugging phenomena. And then, in order to identify the
22 main 4T system components which are excited by the chugging
23 phenomena, saw that the next step we could develop would be
24 a realistic model of the 4T facility, and, with this help,
25 to extract the forcing function at the vent end or exit.

BWH

1 (Slide.)

2 In the first step, the first phase we analyzed, we
3 tried to identify the characteristics of the chugging load,
4 and despite the variety of time histories and recorded, we
5 identified in all cases the same set of discrete
6 frequencies. We observed random trends, both in terms of
7 peak amplitude and frequency trends in the phases. And we
8 also have been able to identify the forcing nature of the
9 chugging load.

10 We then went further to analyze the traces and
11 tried to identify the main components of the 4T facility
12 that were excited during the chugging phenomena. And we
13 found that these frequencies would be identified to the vent
14 acoustic frequencies and to the water tank, including
15 support frequency.

16 The vent acoustic frequencies would be in the
17 range of five, a couple of harmonics, evidently, in the
18 recorded cases, the first and second, probably, and the
19 water tank support frequency, the main and sometimes the
20 second frequency which were also evident in the test.

21 (Slide.)

22 We were able to identify these frequencies,
23 assuming that the steam in the vent is a linear acoustic
24 fluid and that the water in the pool is likewise linear
25 acoustic fluid, that the boundary structure is linearly

BWH

- 1 elastic. That gave us a chance to go into the second
- 2 step —
- 3 (Slide.)
- 4 — And develop an analytical model of the 4T
- 5 system, a linear model, which is shown in this figure.
- 6 (Slide.)
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

1 It is made of a vent with steam inside, the steam
2 being modeled as one-dimensional acoustic. The water in the
3 suppression pool surrounding the vent modeled as an
4 axial (inaudible). And then also, the supports represented
5 by (inaudible).

6 With this model at hand, we were then able to
7 find a chugging load exit, which is its source, and this
8 load being now independent of the geometry of the 40 tank
9 would be portable and transferrable to the Mark II, since
10 the thermodynamic conditions during the 4I test were
11 similar in application of conditions expected in the Mark II
12 plant during the chugging effects because we identified some
13 random trends in the data. We performed a statistical analysis
14 of the data and we were able to determine a design level
15 load at the required probability of non-exceedence and
16 confidence level.

17 Based on that, we could develop the design load
18 specification.

19 That also included some observed characteristics of
20 steam and water properties, as well as the expected
21 variations in steam and water properties during long-term
22 LOCA effects in a Mark II containment.

23 In somewhat detail, what we did is explained in
24 this picture.

25 (Slide.)

1 We started with the 4T traces and we had the
2 numbers supplied by General Electric. And we used as a measure
3 of the traces the response spectra on these traces.

4 Any equivalent measuring units could have been used
5 such as the amplitude spectra.

6 After obtaining the response spectra associated
7 with each of the available traces, we performed a statistical
8 analysis at each frequency and obtained a design level
9 response spectrum at the required probability of non-exceedence
10 and confidence level.

11 Then with the model that 4T had developed
12 previously and what we learned about the inclusive nature of
13 the chugging load, and roughly about the expected duration
14 of the load, we applied this load at the vent and coupled
15 vent pool tank support system.

16 It excited the system and computed the response of
17 the system at locations comparable to where the data was
18 recorded in the 4T tank.

19 At the bottom center, we then obtained these
20 responses, the response spectra of these responses and computed
21 the response spectra and compared the resulting envelope with
22 the design level envelope obtained from the statistical
23 interpretation of the 4T data.

24 At the time, this envelope was representative, we
25 identified an acceptable conservative load.

gsh
1 The design load we obtained has this configuration.
2 It is impulsive in nature. It is time dependent. The one
3 shown in this particular viewgraph response to a probability
4 of non-exceedence of 50 percent and a confidence level of
5 about — that would correspond to the distribution of mean
6 plus two standard deviations.

7 It looks like this (indicating).

8 This is the load at vent exit that would be applied
9 over the interface between the steam and the vent —

10 DR. CATTON: Is that 50 milliseconds wide?

11 DR. BEDROSIAN: Yes.

12 DR. CATTON: That seems awful wide.

13 DR. BEDROSIAN: We investigated the traces and found
14 out that in view of the (inaudible) of the load, that the
15 variation was between 50 and 60 milliseconds. We picked up
16 this value — maybe it was representative of most of the cases
17 we looked at.

18 DR. CATTON: What does it do to your conclusions if
19 you decrease that?

20 DR. BEDROSIAN: No.

21 DR. CATTON: It doesn't really matter.

22 DR. BEDROSIAN: For the impulsive load, what really
23 matters is the (inaudible).

24 DR. CATTON: Not the frequency.

25 DR. BEDROSIAN: No.

1 DR. ZUDANS: Where did you apply this load?

2 DR. BEDROSIAN: Over the steam/water interface at
3 vent exist, over the entire interface.

4 DR. ZUDANS: In other words, it doesn't have to be
5 flat; it could have been curved?

6 DR. BEDROSIAN: It is a hemispherical or cylindrical -

7 DR. ZUDANS: So a 50-millisecond duration is
8 short compared to -

9 DR. BEDROSIAN: What?

10 DR. ZUDANS: The 50 milliseconds is very short
11 compared to natural periods involved in the response. It
12 really doesn't matter how short it is.

13 DR. BEDROSIAN: Indeed, for T tank, we used short
14 impulse loads and longer impulse loads. And the responses we
15 obtained were (inaudible).

16 DR. CATTON: Your amplitude also appears to be low.

17 DR. BEDROSIAN: It is proportional with the total
18 energy imparted in the system. If you use a shorter impulse,
19 you might have to use a larger amplitude.

20 is not the amplitude which --

21 DR. CATTON: I cannot mentally integrate your curve
22 with the data.

23 DR. BEDROSIAN: I am suggesting that if we use a
24 shorter duration, you may need larger amplitude.

25 In answer to the second question, which was to

ash

1 transfer this source load to a Mark II system, which is a
2 multivent geometry, we basically followed the process pictured
3 in this picture.

4 (Slide.)

5 We started with the traces, the statistical
6 interpretation, the source load in the single vent 4T test
7 facility and plotted that load at all of the vent exits
8 in a multivent Mark II geometry and excited this geometry
9 with the steam in the vent and water in the suppression pool
10 and the containing elastic structure and obtained the
11 responses of the complex.

12 To define the loading conditions for the Mark II,
13 we, based on engineering judgment and what we expected to
14 happen at the tail end of the LOCA, we devised what we
15 labelled to be a mainly symmetrical loading condition. This
16 loading condition assigns the source load at the same
17 intensity concurrently at all vent ends at the same time.

18 And additionally, because the design was likely
19 to see some unbalance as a result of the response and
20 because we expect that towards the end of the LOCA, there
21 may be some non-conformities within this system, we
22 assigned it three stronger sources at three radially located
23 vent exits. These stronger sources we estimated based on
24 engineering judgment, and were conservatively to account
25 for the expected non-symmetries.

gsh
1 (Slide.)

2 In addition, we devised a mainly non-symmetrical
3 loading condition and this assumes variation in the intensity
4 of the loads at the vent exits as shown in this picture on
5 the average, which means it is the center of the system of
6 the downcomers at mean intensity and linearly varying
7 between the two extremes along the large diameter from mean
8 plus or minus one standard deviation.

9 The idea was to try to, again, give the designers
10 the tools which enabled them to account for some horizontal
11 response in addition to the main vertical response, and to
12 account in some sense for the probable nominal non-symmetries
13 at the tail end of the LOCA in a Mark II plant.

14 We note at that time probably the conditions in
15 the drywell and in the pool are quite uniform. And both
16 systems will see probably nominal nonsymmetries.

17 And we felt that this would account for this.

18 (Slide.)

19 We analyzed the coupling system composed of vents
20 coupled with the pool and the support beams and surrounding
21 structures.

22 I would like to show you some of the typical
23 results we obtained. This is the response of the reactor
24 building at reactor pressure vessel support level. It is
25 the horizontal response and is expressed in terms of slow

POOR
ORIGINAL

1031 124

1 response spectra, which means it is the response of a single
 2 system if it would be located at that location and it is
 3 an acceleration response spectrum.

4 The units are in Gs and it is given for this set of
 5 (inaudible). And it appears to be reasonably and is expected
 6 limiting.

7 (Slide.)

8 I would like to show you some of the responses we
 9 calculated on the boundary of the welded portion of our
 10 containment structure. And I would like to note that our
 11 containment structure is made of steel. It is a steel shell.
 12 And this is, again, it is expressed in terms of response
 13 spectra. It is an acceleration response spectra and it is
 14 at the location where the containment structure sees the
 15 maximum response.

16 This is about at half pool depth. Some of these
 17 responses may appear to be more significant.

18 I might explain why such larger volumes occur. The
 19 way we see it is if you impart to a system a load within an
 20 acoustic fluid which is practically non-compressible, the
 21 boundary will see that flow.

22 In our case, the containment boundary is a thin
 23 shell and it is physically separated by the rest of the
 24 reactor building by a physical gap.

25 So the boundary will see this load in the thin shell.

1 It will penetrate not too far into the shell. And as we go
2 away from the parameter and into the adjacent structural
3 components, we will see less and less of the expectation.

4 In addition, I would like to note that the rather
5 large values are recorded in this location and that can be
6 explained because of some conservative assumptions we had
7 to make in this Mark II analysis, short of having full scale
8 multivalent data.

9 Those include the way we assign in-phase the
10 forcing signals to all vent exits and did not account for
11 the phasing of the signals between events because of
12 (inaudible), and the fact that the representation as an
13 acoustic fluid of the pool itself transfers the load,
14 acting on the boundary — that is an acoustic fluid which has
15 no damping.

16 This is why if you look at this picture, one of
17 the coupled containment system frequencies, because of the
18 undamped pool representation and the rather small damping
19 assigned to the containment steel shell boundary, the response
20 will have a number of cycles.

21 And in the flow response spectrum, they will amount
22 to (inaudible).

23 DR. ZUDANS: I have two questions. One question:
24 is this a special case or application of what Mr. Jim Fitch
25 presented, or is it a completely independently derived source

POOR
ORIGINAL

1 function?

2 DR. BEDROSIAN: It was developed independently. It
3 was finalized in late 1978 before, I think, the other effort.

4 DR. ZUDANS: We heard a presentation that heard very
5 much like what you have said. We didn't see the forcing
6 function Jim Fitch indicated, but that is beside the point.

7 How did you get the — I guess in the beginning,
8 you explained how are you going to solve the overall problem.
9 Did you assume that there are point sources distributed
10 throughout the fluid and ignored the physical presence of
11 downcomers as obstructions?

12 DR. BEDROSIAN: The downcomers would not have
13 presented obstructions.

14 DR. ZUDANS: You would have homogenous fluid —

15 DR. BEDROSIAN: They were represented as rigid
16 boundaries in our Mark II containment analyses. The
17 downcomers were present as rigid boundaries.

18 DR. ZUDANS: You would have extremely complicated
19 geometry.

20 DR. BEDROSIAN: It is complicated.

21 DR. ZUDANS: Did you go around different rigid
22 boundaries?

23 DR. BEDROSIAN: I think we are helped by the
24 distribution of the vents in the WPPSS geometry. It could
25 be done in a similar manner with any other containments.

1 All of the vents are radially located.

2 So we either performed the analysis for the
3 radially located and then (inaudible). This was performed in
4 the frequency domain, so it was an uneconomical task.

5 DR. ZUDANS: It was not a wave propagation type of
6 analysis?

7 DR. BEDROSIAN: It was a combination of wave
8 propagation in the vents and the suppression pool, that part
9 of the combined system. And it was a linearly elastic
10 dynamic analysis for the remainder of the structure.

11 DR. ZUDANS: The wave propagation from the end of the
12 downcomer to the wall of containment should see rigid
13 structures.

14 DR. BEDROSIAN: Yes.

15 DR. ZUDANS: These are submerged, rigid pieces
16 sitting --

17 DR. BEDROSIAN: Our analysis accounted for the
18 downcomers as rigid boundaries.

19 DR. PLESSET: The wavelengths are pretty long, I
20 think, aren't they? They are quite long and I think that
21 you have to keep that in mind.

22 That applies to your comment about the Pennsylvania
23 Power and Light thing. The wavelengths are long.

24 Do you agree with that?

25 MR. ROTH: Yes, we are hoping that is the case.

POOR
ORIGINAL

ash

1 DR. PLESSET: I think you can estimate what the
2 wave lengths are going to be.

3 DR. ROTH: Yes.

4 (Laughter.)

5 What are they, 50 feet? 100 feet? Something like
6 that?

7 DR. ROTH: About 100 feet.

8 DR. BEDROSIAN: 80 feet.

9 DR. PLESSET: These are very long wavelength effects.

10 DR. BEDROSIAN: We don't think the reflection between
11 the vents —

12 DR. ZUDANS: That was not, in fact, directly
13 accounted for.

14 DR. BEDROSIAN: It was counted in our analysis.

15 DR. ZUDANS: It is strictly a three-dimensional
16 analysis.

17 DR. BEDROSIAN: Yes.

18 DR. ZUDANS: Is it the same forcing function that
19 Jim Fitch said or not?

20 DR. BEDROSIAN: I have not seen his forcing function.

21 DR. FITCH: It is not the same. Certain aspects of
22 it would be the same; namely, the triangular part. The larger
23 triangle is, although ours is a somewhat shorter duration.
24 But probably the most significant difference you would see in
25 looking at it is that since we don't have the event pipes

1 model, our forcing function includes the vent response.

2 So that tacked onto the triangular portion is a
3 sinusoidal signal.

4 DR. ZUDANS: It is amazing that you would come up
5 with the same idea independently.

6 (Laughter.)

7 DR. PLESSET: It is acoustics and that is well
8 known.

9 (Laughter.)

10 DR. PLESSET: Sobon?

11 DR. SOBON: Apparently, during the break there was
12 some discussions between some of your consultants regarding
13 the multivent test program with CREARE. Perhaps a comment
14 or two might be appropriate at this time to address some
15 of that.

16 DR. PLESSET: Who will do that?

17 DR. PATEL: Since the presentation was so interesting
18 to the members, we decided to give it a second try.

19 (Laughter.)

20 DR. PLESSET: Everything is interesting to us.

21 DR. PATEL: There was a question which was raised
22 by, I believe, Dr. Catton, and I think there were a couple
23 of points which I failed to clarify.

24 First of all, I have a hand-sketched figure here.
25 That is the single vent geometry and this is the corresponding

POOR
ORIGINAL

1031 130

1 multi-vent geometry.

2 Now since the geometries were essentially preserved,
3 if all of the vents basically went in phase, the pressure
4 that — for example, you would observe at that point
5 exactly what you would have observed — that you would observe
6 at that point (indicating.)

7 DR. PLESSET: One would be greater, the loads would
8 be greater?

9 DR. PATEL: Yes. I would just like to address the
10 question. Since it is lower than one, it shows that the vents
11 were not chugging out of phase, that within a given chug, the
12 vents were chugging just slightly out of phase or enough out
13 of phase that the pool pressure here was lower than the
14 pool pressure there, as expected, because of the vent's
15 chugging in a larger pool.

16 This is an important point for the methodology which
17 is being used where we take the single vent 4T data and apply
18 it to the Mark II plant.

19 Here they are taking all of the vents in phase and
20 the data that I presented therefore shows that this
21 assumption is certainly fairly conservative in giving the
22 pressures at the pool boundaries.

23 DR. PLESSET: Thank you. I can see why Mr. Socon
24 wanted this clarified.

25

mte

1 I hope this will all be clearly described in your
2 report.

3 DR. PATEL: It will be.

4 DR. PLESSET: It is now Cliff Anderson's turn to
5 give some comment from NRC.

6 DR. ANDERSON: The staff and our consultants have
7 been reviewing these programs, essentially every one of
8 these programs that were presented for the long-term
9 program. We are keeping on top of this. The programs are
10 not complete at this point and we have not completed our
11 evaluations.

12 The process of the meetings that we have had --
13 and we have had something like two meetings for each -- on
14 each one of these topics with the Mark II owners, and also
15 plant-unique meetings discussing the Susquehanna program and
16 Dr. Bedrosian's improved chugging load specifications. We
17 have identified some areas that we wanted to see addressed.
18 And what I wanted to do now is just touch on some of those
19 significant comments that we have already made to the Mark
20 II owners for three of the areas: condensation oscillation
21 tests, and the creari tests, and the improved chug
22 specification.

23 I am not going to try to separate out the two
24 condensation oscillation programs, and I will try to
25 separate out the improved chugging specifications. I will

nte 1 lump some of these together.

2 (Slide.)

3 The first one is the condensation oscillation
4 test, again including both the 4T CO test and the KWU test
5 being conducted for Susquehanna.

6 The first comment is, we did observe, the staff
7 has observed, as a result of the tests conducted in the FFTS
8 facility that the highest loads were observed under
9 conditions of high total mass flux — it should be total
10 mass flux — and under conditions of low air content.
11 Recognizing this, we want to make sure that the test matrix
12 for both of these tests would bracket the values for the
13 plants. They are conservative values for total mass flux
14 and air content.

15 We have reviewed the test matrix for the 4T CO
16 tests and they have provided a comparison of the anticipated
17 values of total mass flux and air content against the
18 calculated values for the Mark II plants, and we have
19 convinced ourselves that they have addressed this to our
20 satisfaction.

21 The second comment is with regard to the potential
22 for data scatter, and we want to make sure that once they
23 have identified what the limiting conditions are as they go
24 through these tests, that they should then reserve enough
25 open slots to run replicate tests, so we can get a better

Inte

1 definition of the load. The next, recognizing the
 2 importance of air content, we feel it is important that they
 3 do have proper type of instrumentation and measuring
 4 techniques to know what the air content is in the test. We
 5 have convinced ourselves, in looking at the type of things
 6 that are being done in both of these test facilities, that
 7 they are giving considerable amount of attention to this,
 8 and they should be able to address this one properly.

9 The last comment: In the case of the Susquehanna
 10 tests, they are making an attempt to measure lateral loads.
 11 We had not heard of any intention to measure lateral loads
 12 in the case of the 4T CO test. Our concern is that in the
 13 case of the FFTS facility, the highest lateral loads were
 14 observed in the conducting of the CO test, and we have
 15 conveyed the concern to the Mark II owners that they should
 16 give this attention, should have proper instrumentation to
 17 measure lateral loads in that facility, to confirm the
 18 conservative nature of our current specifications.

19 The next, the comments with regard to the Creari
 20 multi-vent test.

21 (Slide.)

22 The function of these tests in the Mark II program
 23 has changed back and forth some over the conduct of these
 24 tests. The original purpose was simply to show that a
 25 multiplier, multi-vent multiplier of less than one was

mte

1 In other words, using the single-vent full-scale full-scale
2 4T data was adequate. And there was some thought about
3 trying to quantify that multiplier and use it in conjunction
4 with the multi-vent hydrodynamic model.

5 That effort does not appear to be -- they are not
6 doing that at that time -- at this time -- so, with the
7 understanding that the primary purpose of these tests is to
8 show a multi-vent multiplier of less than one, our review of
9 this data at this point does indicate that this is correct.
10 However, we feel there is some value in taking a pretty good
11 hard look at a lot of this data, if there is a lot of data
12 there, and being able to separate out some of these
13 multi-vent effects.

14 There are competing things that are happening
15 there, including -- there are FSI effects that are unique to
16 those facilities. It is our understanding that there will
17 be an effort -- I am not sure if it is NMSS -- will be
18 looking at and doing studies of this facility to be able to
19 separate out the different effects that are occurring, so
20 that we -- there is a better handle on the margin associated
21 with multi-vent effects.

22 And then finally, we believe that, again, there
23 are a lot of things that could be done with vent data, and
24 that data should be studied carefully for determination of
25 how it could be used in supporting some of the assumptions

1 in other long-term program efforts. In particular, the one
2 we are talking about here is the improved chugging load
3 specifications, and I will talk about that in the next
4 slide.

5 (Slide.)

6 And this is with regard to the improved chug
7 specifications. The first comment here, investigate 4T
8 high-frequency response. We did observe that there was some
9 high-frequency response in the 4T measurements, and also,
10 when one uses these 4T measurements to come up with a
11 source, there was observed some high-frequency response.
12 The cause of that is not completely apparent at this time.
13 It could be anything from some part of it due to
14 instrumentation in the case of one of the approaches, where
15 there might be some numerical questions involved with the
16 way that they come up with the amplified response spectra
17 that is used to establish the source.

18 We feel they should look at this to understand
19 what is causing this, and if it is real, then it should be
20 included as a part of the source specification.

21 The next one is, as you heard, two different
22 approaches with a lot of similarities. One thing we might
23 note is that one of the models that is to be applied to the
24 Mark II plant is somewhat simpler than the other, in that
25 the Bechtel approach does use a closed solution of the

mte

1 Navier-Stokes equation with a number of dials. That is to
2 be checked by some detailed Nastran calculation.

3 : Our concern here is that these assumptions would
4 be verified, and they are doing something along this line,
5 both in the study of the 4T facility and in the calculations
6 of the Mark II plant.

7 The next comment here is, the concern has always
8 been that one would be able to come up with a source that is
9 free of 4T signature. Both of these methodologies rely
10 pretty heavily on data from the 4T facility. The total
11 methodology is not just the analytical model. It also
12 includes taking a look at the 137 chugs from the 4T
13 facility.

14 We think there is merit in applying this
15 methodology to do some calculations of other tests.

16 And then, finally — this is the one that relates
17 back to the comment that I made on the Creeri facility. We
18 believe that they should take a look at the available
19 multi-vent test data that they have. This is with regard to
20 how they establish that source.

21 Our concern here, again, as I mentioned before, is
22 that there is a potential for a number of large chugs
23 occurring at the same time and your not having a mixture of
24 large chugs, small chugs, et cetera. We believe by looking
25 at the multi-vent test data, one can get somewhat of an

mte

1 idea as to whether a number of large chugs occur at the same
2 time. As a part of our evaluation of these efforts, there
3 is a research program with Livermore. They have developed a
4 code, the PELE IC code, that is comparable to K-FIX. They
5 are doing calculations of the same type that you heard
6 described here, where you heard Dr. Bedrosian's approach and
7 Jim Fitch's approach.

8 We are using that program to help us in the — to
9 help us assess any of these models and the assumptions that
10 are implicit in there, and also in evaluating some of the
11 different sources that you have heard here. And possibly we
12 will be doing some more work with it and looking at some
13 other test data that is available.

14 That concludes our comments.

15 DR. PLESSET: Thank you, Cliff. Let me see if any
16 of the Committee members or consultants have comments on
17 your comments.

18 (No response.)

19 DR. PLESSET: I guess not. Let me ask you a
20 question for clarification. I am pretty sure I know the
21 answer. The Japanese data is not generally available to the
22 Mark II owners group, is that correct?

23 DR. ANDERSON: Right.

24 DR. PLESSET: And will not be, presumably?

25 DR. ANDERSON: We don't know. As far as we know

1 right now, it will not be.

2 DR. PLESSET: They will be inscrutable.

3 (Laughter.)

4 DR. SOBON: We have been working to try and obtain
5 the data. The point is, though, that it is the timeliness
6 and the form in which it would be provided. At the moment
7 it appears as though the reports would have to be finalized,
8 and that there would be more or less some reports which are
9 of some value, but of course the raw data is much better.
10 And that we think is not going to happen, at least as the
11 scheme of things is moving now, until after we likely would
12 get data from the 4T test facility.

13 DR. PLESSET: They showed me the facility. There
14 is some question about whether they would or not. But they
15 finally agreed. I don't know why they are very protective
16 of it. It is an impressive facility, I will say that.

17 Now, let me ask you one other question. Did the
18 GKM data — that will not be generally available?

19 DR. ANDERSON: That is our understanding. GKS or
20 GKM?

21 DR. PLESSET: GKSS is what I should have said.

22 DR. ANDERSON: As far as we see now, that is in
23 the same classification as the Japanese test. And yes, it
24 is not generally available.

25 DR. SOBON: The detailed data will not be

nte

1 available.

2 DR. KUDRICK: Summary reports and evaluations will
3 be available.

4 DR. PLESSET: And the time scale for that, would
5 that be helpful, or will it be a little bit slow?

6 DR. KUDRICK: I am not aware of the current
7 schedule for those summary reports. I would imagine that
8 before the end of the year, they would be available.

9 DR. ANDERSON: If you see the test schedule
10 going over period of a year and a half, starting now, and
11 while we will be getting some test reports as we go through
12 this program -- the Mark II owners' long-term program is to
13 be completed in 1980. So I would say generally it is not
14 going to be available on a time frame consistent with what
15 we are trying to do right now.

16 DR. PLESSET: Thank you.

17 DR. ZUDANS: You mentioned a third method is being
18 developed.

19 DR. ANDERSON: It is not exactly a method, but a
20 way of checking some of these methods.

21 DR. ZUDANS: The method that Livermore is doing,
22 they --

23 DR. ANDERSON: PELE IC -- it is equivalent to the
24 K-FIX, and it is a very rigorous treatment of this. It is
25 more rigorous than the Nastran calculations. There are

1 some potentials that we may do some less rigorous
2 calculations that are comparable. But no, it is not 3-D.
3 It would be for 4T, which is —

4 DR. ZUDANS: Is it aimed at generating the forcing
5 function, taking boundary conditions away?

6 DR. ANDERSON: We are not trying to take the
7 library and then work out of that source. We are trying to
8 take — first of all, the sources that have been provided,
9 and do some sensitivity study with those sources and see
10 what happens on the boundary of the 4T facility. That is
11 one thing.

12 Another thing is to look at the assumptions
13 involved in the modeling of the two approaches and check out
14 those with an independent model.

15 DR. PLESSET: Thank you.

16 Now we have to go into closed session because of
17 proprietary material. But in order not to have you wait and
18 come back to the open session, which would just consist of
19 some general discussion, I am suggesting that we adjourn at
20 the end of the closed session, so that those who are not
21 going to be here for the closed session could leave now and
22 not have to come back. They might not want to come back
23 anyway.

24 (Laughter.)

25 What I propose is that we now go into closed

PHHmte

1 session, and that session will adjourn -- we will adjourn at
 2 the end of that closed session. We we will take just a
 3 minute or two to do that. I don't think we need to break.

4 (Whereupon, at 4:30 p.m., the proceeding was
 5 adjourned.)

- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

c. 16

T-1
CR6841

Introduction Slides

1. Purpose of Meeting
2. Mar. II Meeting Agenda
3. Mark II Facility Schedules
4. Typical Mark II Containment
5. Chronology of Primary LOCA Loads
6. LOCA Sequence of Events
7. Alternate Lead Plant Loads
8. Downcomer Design
9. Mark II Program Completion Estimate
10. Plant Unique Programs
11. Primary LTP Tasks
12. Related Foreign Tests

PURPOSE OF MEETING

- ALTERNATE LPP LOADS
- LEAD PLANT DOWNCOMER SUPPORT
- LONG TERM PROGRAM STATUS
- RELATED FOREIGN TESTS

MARK II ACRS
MEETING AGENDA
SEPTEMBER 13, 1979


- I. INTRODUCTION 15 MIN.

- II. LEAD PLANT LOADS
 - A. LOCA LOADS 30 MIN.
 - B. SRV LOADS 15 MIN.
 - C. SUBMERGED STRUCTURE LOADS 20 MIN.
 - D. DOWNCOMER SUPPORT 60 MIN.


- III. LONG TERM PROGRAM
 - A. GENERIC SUPPORTING PROGRAM 150 MIN.
 - B. RELATED PLANT UNIQUE PROGRAMS 35 MIN.
 - C. STAFF COMMENTS ON LTP 15 MIN.
 - D. RELATED FOREIGN TESTS 30 MIN.

- IV. SUMMARY STATEMENTS 10 MIN.

MARK II FACILITY SCHEDULES



● FSAR SUBMITTED
 ▽ SER
 ○ FUEL LOAD DATE
 * LEAD PLANTS



Typical Mark II Pressure Suppression Containment

POOR
ORIGINAL

CHRONOLOGY OF PRIMARY LOCA LOADS

- VENT CLEARING
 - JET LOADS ON BASE MAT


- AIR BUBBLE FORMATION
 - DRAG LOADS ON SUBMERGED COMPONENTS

- POOL SWELL
 - AIR BUBBLE PRESSURE LOAD ON SUBMERGED BOUNDARY
 - DRAG LOADS ON SUBMERGED COMPONENTS
 - IMPACT LOADS ON WETWELL COMPONENTS
 - WETWELL AIR COMPRESSION LOADS ON BOUNDARY
 - UPWARD DIAPHRAGM LOADS

- POOL FALLBACK
 - DRAG LOADS ON SUBMERGED COMPONENTS

- STEAM BLOWDOWN AND CONDENSATION
 - DOWNCOMER LATERAL LOADS
 - PRESSURE LOADS ON SUBMERGED BOUNDARY
 - DRAG LOADS ON SUBMERGED COMPONENTS

LOCA Sequence of Events



Peak drywell and wetwell pressure 50S

Maximum diaphragm ΔP down 0.7S

Maximum diaphragm ΔP up 2.0S

ALTERNATE LEAD PLANT LOADS

LOCA

- SUBMERGED BOUNDARY
- POOL SWELL ELEVATION & WETWELL
AIR COMPRESSION
- ASYMMETRIC POOL SWELL

SRV

- ALL VALVE LOAD CASE 5

SUBMERGED STRUCTURE DRAG

- MODIFIED DRAG COEFFICIENTS (UNSTEADY FLOW AND
INTERFERENCE EFFECTS)
- LIFT DUE TO VORTEX SHEDDING
- STRUCTURAL NODALIZATION

DOWNCOMER DESIGN

UNBRACED DOWNCOMER DESIGN

SUBMERGED STRUCTURE DRAG LOADS (CO AND SRV AIR BUBBLE)


REFINED SUBMERGED DRAG LOADS

REDESIGN DOWNCOMER SUPPORTS

LATERAL LOAD CHANGES

MK II PROGRAM TASKS

TO BE COMPLETED



1031 152

PLANT UNIQUE PROGRAMS

	<u>BAILLY</u>	<u>HANFORD</u>	<u>LIMERICK</u>	<u>NINE MILE PT.</u>	<u>SUSQUEHANNA</u>
LOCA					
- VENT CLEARING	X			X	
- POOL SWELL		X			
- C. O. & CHUGGING		X			X
SRV					
- TEMPERATURE LIMIT		X			
- AIR CLEARING				X	
- TIE DOWN	X			X	
SUBMERGED STRUCTURES					
- JET					
- AIR BUBBLE	X	X	X		X
- STEAM COND.		X	X	X	X

1031 153

PRIMARY LTP
TASKS

GENERIC

- 4T CO TESTS
- CREARE MULTIVENT TESTS
- IMPROVED CHUG LOAD
- CAORSO SRV TESTS

PLANT UNIQUE

- GKM II CO TESTS
- WPPS-2 IMPROVED CHUG LOAD

RELATED FOREIGN TESTS

JAERI MULTIVENT FULL SCALE TESTS

- 1/18 SECTOR, 7 VENTS, MARK II PROTOTYPICAL
- PRELIMINARY RESULTS

POOL SWELL
CO AND CHUG LOADS

GKSS TESTS

- 3 LARGE VENTS
- 3 SHAKEDOWN TESTS COMPLETE

T-21
3

Alternate LOCA Load Slides

1. Alternate LOCA Load Summary
2. Original Vent Clearing Load
3. Revised Vent Clearing Load
4. Original DFFR Pool Swell Load
5. NRC Acceptance Criteria Pool Swell Load
6. Alternate Methodology Pool Swell Loads
7. Pool Swell Criteria Evaluation
8. Comparison of Phase I Measured and Calculated Pool Swell Height
9. Comparison of Phase II Measured and Calculated Pool Swell Height
10. Original Asymmetric Pool Boundary Load.
11. Revised Asymmetric Pool Boundary Load

ALTERNATE LOCA LOAD
SUMMARY

POOL BOUNDARY LOADS

POOL SWELL ELEVATION AND WETWELL AIR COMPRESSION

ASYMMETRIC POOL SWELL

ORIGINAL
VENT CLEARING LOAD

ORIGIN

WATER CLEARING INDUCED PRESSURE ON POOL BOUNDARY

ORIGINAL MARK II SPECIFICATION

BASEMAT - 33 PSI OVERPRESSURE

BASIS

JET IMPINGEMENT ON BASEMAT
MAXIMUM VENT CLEARING VELOCITY
TOTAL MOMENTUM TRANSFER

NUREG 0487 CRITERIA

INCLUDE 33 PSI OVERPRESSURE AT WALLS

REVISED VENT
CLEARING LOAD

ALTERNATE SPECIFICATION

- BASEMAT AND WETWELL WALLS BELOW VENTS
24 PSI OVER LOCAL HYDROSTATIC PRESSURE
- LINEARLY ATTENUATE TO ZERO AT POOL SURFACE

BASIS

MARK II OWNERS

- 20 PSI IS 4T BOUND OF 20 TESTS
- INCREASE BY 4 PSI FOR MAXIMUM MK II DRYWELL
PRESSURIZATION


NRC

- LEAST SQUARES FIT OF 4T AND MARVIKEN DATA

$$\Delta P \text{ vs } \frac{\overline{MHL}}{A_p / A_v}$$


- 99-99 NON-EXCEEDANCE
CONFIDENCE LIMIT

ORIGINAL DEFR METHODOLOGY



- MAXIMUM POOL SWELL UNDERPREDICTED IN TWO CASES
- LARGE UNCERTAINTY IN POOL SWELL ELEVATION

MARK II OWNERS GROUP ALTERNATE METHODOLOGY



- TERMINATION HEIGHT DEFINED BY Δ PUP SPECIFICATION AS DETERMINED FROM NRC ACCEPTANCE CRITERIA
- TERMINATION HEIGHT NO LESS THAN 1.5 x SUBMERGENCE
- MAXIMUM WETWELL AIRSPACE PRESSURE BASED ON TERMINATION HEIGHT

POOL SWELL CRITERIA
EVALUATION


- CALCULATED SWELL HEIGHTS FOR SELECTED PHASE I AND II TESTS SHOW: METHODOLOGY CONSERVATISM

- RUN 35 EXCEEDS CALCULATION BY 6 INCHES


- METHODOLOGY CONSERVATISMS
 - 4 T CONSERVATISMS
 - NEDM-10320 CONSERVATISMS
 - LEVEL SENSOR FROTH DETECTION
 - DBA SATURATED LIQUID BREAK

- METHODOLOGY LIMITATION -
 - INCLUDE CONSERVATISMS OF NEDM-10320 FOR DRYWELL PRESSURE RESPONSE

1031 163



COMPARISON OF MEASURED AND CALCULATED SWELL HEIGHT AT PHASE I



COMPARISON OF MEASURED AND
CALCULATED SWELL HEIGHT
4T PHASE II

ORIGINAL
ASYMMETRIC POOL
BOUNDARY LOAD

ORIGIN

CIRCUMFERENTIAL VARIATIONS IN VENT AIR/STEAM MIXTURE
RESULT IN ASYMMETRIC BUBBLE PRESSURE LOAD ON BOUNDARY

NUREG 0487 CRITERIA

- ALL AIR VENTED ON ONE HALF OF CONTAINMENT AND
STEAM ON OTHER HALF
- MAXIMUM PSAM VENT CLEARING AIR BUBBLE PRESSURE ONE
HALF OF CONTAINMENT AND ZERO PRESSURE OTHER HALF

REVISED ASYMMETRIC POOL BOUNDARY LOAD

REVISED SPECIFICATION

20% MAXIMUM VENT CLEARING AIR BUBBLE PRESSURE ONE HALF OF CONTAINMENT AND ZERO PRESSURE OTHER HALF

BASIS

- CALCULATIONS
 - MODEL BUBBLE PRESSURE DIFFERENCE IN 2 VENTS INITIALLY FILLED WITH AIR
 - NEAR VENT IMMEDIATELY SUPPLIED WITH HOMOGENEOUS STEAM/AIR MIXTURE
 - FAR VENT SUPPLIED WITH AIR FOR 0.4 SECONDS
 - AIR/STEAM FRONT VELOCITY FROM BATTELLE TESTS
 - OTHER CONSERVATIVE ASSUMPTIONS-LOW BREAK ELEVATION, SHORT VENT CLEARING TIME AND INSTANT STEAM CONDENSATION
 - CALCULATE $\Delta P = 8$ PSI WITH 65% STEAM MIXTURE IN ONE VENT AND ALL AIR IN OTHER VENT
- ARGUMENTS FOR LOW STEAM/AIR VARIATIONS IN THE DRYWELL
 - HIGHLY TURBULENT FLOW
 - DRYWELL STRUCTURE AID IN MIXING
 - MARVIKEN AND BATTELLE TEST DATA INDICATE GOOD MIXING

OT-3

MARK II LEAD PLANT

SRV LOADS ACCEPTANCE CRITERIA
NUREG-0487 OPEN ITEM

BACKGROUND: MARK II LEAD PLANTS ACCEPT NUREG-0487 SRV LOADS CRITERIA EXCEPT LOAD CASE 5.

LOAD CASE 5 (NUREG-0487):

- (1) ALL VALVES DISCHARGE SIMULTANEOUSLY ASSUMING ALL BUBBLES OSCILLATE IN-PHASE;
- (2) PRESSURE AMPLITUDES OF EACH BUBBLE SHALL BE PREDICTED BY RAMSHEAD MODELS DESCRIBED IN DFFR REV. 2;
- (3) PRESSURE AMPLITUDES DUE TO MULTIPLE BUBBLES SHALL BE ADDED BY ABSOLUTE SUM;
- (4) A RANGE OF BUBBLE FREQUENCY OF 4 TO 12 HZ SHALL BE EVALUATED FOR STRUCTURAL, PIPING AND EQUIPMENT RESPONSE.

MARK II LEAD PLANTS DESIGN BASIS AND PROPOSED ALTERNATIVES

I. CURRENT DESIGN BASIS

- RAMSHEAD LOADS AND BUBBLE FREQUENCY PREDICTED BY DFFR MODEL;
- BUBBLE PHASING DUE TO SRV SET-POINT, SRV LINE LENGTH;
- VARIOUS ALL SRVs CASES HAVE BEEN EVALUATED;
- DESIGN CASE SELECTED ON THE BASIS OF STRUCTURAL CHARACTERISTIC,

II. PROPOSED ALTERNATIVES

- RE-EVALUATE CURRENT DESIGN BY USING T-QUENCHER LOADS AND BUBBLE FREQUENCY AS A RESULT OF KWU TESTS;
- ALL BUBBLES IN-PHASE;
- MEET THE INTENT OF NUREG CRITERIA.

STAFF'S EVALUATION OF LEAD
PLANT PROPOSED ALTERNATIVE

- PROPOSED ALTERNATIVE COMPLIES WITH NUREG CRITERIA EXCEPT THE FOLLOWING.

<u>NUREG</u>	<u>PROPOSED ALTERNATIVE</u>	<u>STAFF'S EVALUATION</u>
PRESSURE AMPLITUDE BASED ON RAMSHEAD	PRESSURE AMPLITUDE BASED ON T-QUENCHER	ACCEPTABLE. ALL LEAD PLANTS HAVE COMMITTED TO T-QUENCHER. PRESSURE AMPLITUDE USED FOR RE-EVALUATION OF PLANT DESIGN IS SUPPORTED BY KWU T-QUENCHER TESTS.
FREQUENCY RANGE 4 - 12 Hz	3 - 9 Hz	ACCEPTABLE. PROPOSED FREQUENCY RANGE SUPPORTED BY KWU T-QUENCHER TESTS

STATUS OF LEAD PLANTS
EVALUATION BY USING T-QUENCHER
LOAD

MAJOR STRUCTURES

SUBSTANTIAL MARGIN
HAS BEEN DEMONSTRATED

PIPING

- EVALUATION ON CRITICAL PIPING SYSTEMS HAS BEEN COMPLETED. RESULTS SHOW CURRENT DESIGN ADEQUATE.
- SHOREHAM HAS DOCUMENTED THE EVALUATION RESULT
- LASALLE AND ZIMMER HAD PRESENTED THEIR EVALUATION RESULTS ON JULY MEETING. EVALUATION RESULTS WILL BE DOCUMENTED BY 3RD Q OF 1979.

EQUIPMENT

- EVALUATION IS UNDERWAY.
- PRELIMINARY ASSESSMENT SHOWS CURRENT DESIGN ADEQUATE
- COMPLETION DATE TO BE ESTABLISHED.

T-5

MARK II LEAD PLANTS

SUBMERGED STRUCTURE DRAG LOADS

- INITIAL LOAD SPECIFICATION IN NEDO-21061 SEPT 1975 (DFFR)
 - EXPANDED TO INCLUDE INERTIAL DRAG
 - EXPANDED TO INCLUDE LOCAL FLOW FIELD EFFECTS

- DESIGN ASSESSMENT REPORT (DAR) 1ST QRTR 1976
 - STRUCTURAL ASSESSMENT FOR DFFR LOADS
 - SRV RAMSHEAD DESIGN BASIS

- DESIGN ASSESSMENT CLOSURE REPORT 3RD QRTR 1978
 - STRUCTURAL ASSESSMENT FOR DFFR - 2 LOADS
 - METHODS FOR PREDICTING LOADS JUSTIFIED
 - RESULTS OF LOADS ON STRUCTURES PROVIDED IN DAR AMENDMENT

- ASSESSMENT CRITERIA SATISFIED ON ALL STRUCTURES

MARK II LEAD PLANTS

SUBMERGED STRUCTURE DRAG LOADS (CONT'D)

- RECENT RESULTS AND DEVELOPMENTS
 - NRC ACCEPTANCE CRITERIA (SEPT 1978)
 - KWU T-QUENCHER FOR SRV DISCHARGE (DEC 1978)
 - LOCA/STEAM CONDENSATION DRAG (JUNE 1978)

- NRC ACCEPTANCE CRITERIA ADDRESSED
 - UNSTEADY FLOW EFFECTS ON DRAG AND LIFT
 - INTERFERENCE EFFECTS
 - NON-UNIFORM FLOW FIELD

- KWU T-QUENCHER FOR SRV DISCHARGES
 - RELOCATION OF SRV LINES
 - BUBBLE PRESSURE DECREASES
 - BUBBLE FREQUENCY DECREASES

- LOCA/STEAM CONDENSATION DRAG
 - WATER JET/VENT CLEARING
 - CHUGGING
 - CONDENSATION OSCILLATION
 - LOW FREQUENCY
 - LOW MAGNITUDE

MARK II LEAD PLANTS

SUBMERGED STRUCTURE DRAG LOADS (CONT'D)

- CURRENT STATUS SUMMARY

- LOAD DEFINITION CRITERIA

- (1) DESIGN ASSESSMENT CLOSURE REPORT METHODS

- (2) NRC ACCEPTANCE CRITERIA

- DOWNCOMER RESTRAINT SYSTEM

- FUTURE PROJECTIONS

- REALISTIC LOAD DEFINITION

- (1) LOWER BUBBLE PRESSURE

- (2) NARROW FREQUENCY RANGE

- (3) ENERGY DISSIPATION AND ATTENUATION

- DOWNCOMER RESTRAINT MAY NOT BE REQUIRED

T-42 6

LOCA/SRV SUBMERGED STRUCTURE LOADS

- ORIGIN OF LOADS
- HISTORY OF LOAD SPECIFICATION - LEAD PLANTS
- INITIAL OWNERS METHODOLOGY
- NRC ACCEPTANCE CRITERIA
- OWNERS' RESPONSE
- NRC SUPPLEMENT TO ACCEPTANCE CRITERIA

- TECHNICAL BASIS FOR:
 - OWNERS' METHODOLOGY
 - NRC ACCEPTANCE CRITERIA
 - ACCEPTANCE CRITERIA SUPPLEMENT

INITIAL MARK II OWNERS' LOAD SPECIFICATION

- WATER JET LOADS
 - QUASI ONE-DIMENSIONAL MODEL
 - NEGLIGIBLE INDUCED FLOW TRANSIENTS
 - STANDARD DRAG ONLY (STRUCTURES WITHIN JET)
 - MOMENTUM BALANCE (STRUCTURES INTERSECTING THE JET)

- AIR BUBBLE LOADS
 - SPHERICAL SOURCE AND IMAGES
 - ONE-DIMENSIONAL FLOW AFTER COALESCENCE (LOCA)
 - EQUIVALENT UNIFORM FLOW AT GEOMETRIC CENTER OF
STRUCTURE
 - ACCELERATION (LOCA) & STANDARD (LOCA/SRV) DRAG
 - NO INTERFERENCE OR BLOCKAGE EFFECTS

- STEAM CONDENSATION LOADS
 - NO GENERIC BASIS PRESENTED

NRC ACCEPTANCE CRITERIA

- DFFR METHODOLOGY & APPLICATIONS MEMORANDUM
SUBJECT TO MODIFICATIONS/ADDITIONS IN:

- LOCA/RAMSHEAD SRV JET LOADS
- SRV QUENCHER JET LOADS

- LOCA AIR BUBBLE LOADS
- SRV/RAMSHEAD AIR BUBBLE LOADS
- SRV/QUENCHER AIR BUBBLE LOADS

- STEAM CONDENSATION LOADS

POOR
ORIGINAL

WATER JET LOADS

- NRC ACCEPTANCE CRITERIA
 - LOCA JET LOADS
 - MODIFY ONE-DIMENSIONAL MODEL
 - INDUCED FLOW AT JET FRONT
 - INCLUDE ACCELERATION DRAG
 - SRV-QUENCHER JET LOADS
 - SPHERE OF INFLUENCE (QUENCHER ARM)

- OWNERS' RESPONSE
 - LOCA JET LOADS
 - ACCEPT NRC CRITERIA OR
 - PLANT UNIQUE (RING VORTEX MODEL)
 - SRV-QUENCHER JET LOADS
 - MODIFY SPHERE OF INFLUENCE TO 5FT CYLINDER

- NRC SUPPLEMENT
 - OWNERS' RESPONSE ACCEPTABLE

NRC CRITERIA - MARK II OWNERS RESPONSE

LOCA AIR BUBBLE DRAG LOADS

NRC MODIFICATION

OWNERS RESPONSE

- | | |
|--------------------------------------------------------------------------------|--------------------------------------------------------------|
| •• BUBBLE ASYMMETRY (10%) | ACCEPTABLE |
| ✓•• STANDARD DRAG COEFFICIENT
BASED ON ACCELERATING
FLOWS | DIFFERENT DATA BASE
(UNIFORM ACCELERATION &
IMPULSIVE) |
| ✓•• EQUIVALENT UNIFORM FLOW
(AT MAX. VELOCITY NOT
GEOMETRIC CENTER) | SENSIVITY ANALYSIS OF
USING GEOMETRIC CENTER |
| /•• INTERFERENCE EFFECTS
(DETAILED ANALYSIS OR
CONSERVATIVE MULTIPLIERS) | DETAILED ANALYSIS BEING
PERFORMED |
| •• BLOCKAGE EFFECTS
USE STANDARD "WINDTUNNEL"
CORRECTION | ACCEPTABLE |

SRV-QUENCHER AIR BUBBLE LOADS

- | | |
|-------------------------------|-------------------------------------------------------------------------------------------------|
| ✓•• AS ABOVE -MODIFIED SOURCE | EFFECTS ABOVE EXCEPT
DRAG COEFF. BASED ON
OSCILLATING FLOW
SOURCE-QUENCHER CORRELATION |
|-------------------------------|-------------------------------------------------------------------------------------------------|

CONDENSATION LOADS

- | | |
|-----------------|--------------------------------------------------------|
| •• PLANT UNIQUE | EFFECTS ABOVE WITH
OSCILLATORY FLOW
4T DATA BASE |
|-----------------|--------------------------------------------------------|

CONCERNS ADDRESSED

I. MODIFIED DRAG COEFFICIENTS

A. UNSTEADY FLOW

1. UNSTEADY ACCELERATING FLOW - SARPKAYA AND GARRISON
2. OSCILLATORY FLOW - SARPKAYA

B. INTERFERENCE EFFECTS

1. STANDARD DRAG

- A. DALTON AND SZABO
- B. HORI
- C. ZDRAVKOVICH

2. ACCELERATION DRAG

- A. DALTON AND HELFINSTEIN
- B. SARPKAYA
- C. YAMAMOTO
- D. YAMOMOTO AND NATH

II. LIFT DUE TO VORTEX SHEDDING

A. OCCURS ONLY AFTER SEPARATION

B. PREDICTED BY DURATION OF FLUID FLOW

C. POTENTIAL TRANSVERSE PERIODIC LOAD

D. LIFT COEFFICIENT AND VORTEX SHEDDING FREQUENCY

1. DEN HARTOG

2. ROBERSON AND CROWE

3. SARPKAYA

4. SARPKAYA AND GARRISON

III. STRUCTURAL NODALIZATION

A. NODAL LENGTH (L) SUCH THAT $1.0 \leq L/D \leq 1.5$

B. SENSITIVITY STUDY SHOWS APPLICABILITY

NRC SUPPLEMENT TO ACCEPTANCE CRITERIA

- LOCA/SRV JET LOADS
 - NO CHANGES
 - ALTERNATIVES - PLANT UNIQUE

- LOCA/SRV AIR BUBBLE LOADS
 - DRAFT REPORT ACCEPTABLE FOR CYLINDRICAL STRUCTURES
 - WITH MINOR MODIFICATIONS
 - FOR STRUCTURES WITH SHARP EDGES:
 - DRAG COEFFICIENT FROM RELEVANT DATA (PLATES)
 - LIFT COEFFICIENT FROM DATA, THEORY OR $C_L=1.6$
 - QUENCHER SOURCE STRENGTH - EVALUATION

- CONDENSATION LOADS
 - APPROACH ACCEPTABLE
 - SOURCE STRENGTH - EVALUATION

T-1

MARK II CONTAINMENT PROGRAM

TASK STRUCTURE SUMMARY

TOTAL NUMBER OF TASKS ————— \approx 101

<u>MARK II PLANT APPLICATION</u>	<u>% OF TOTAL TASKS</u>
LEAD PLANT SER	8
NON-LEAD PLANT	32
COMBINATION OF PLANT CATEGORIES	34
CONFIRMATORY	12
INFORMATIONAL	14
TOTAL	<u>100%</u>


JULY 1979 COMPLETION STATUS:
(BASED ON COST WEIGHTING)

• OVERALL PROGRAM

70%

ARS/DH

9/79



ESTIMATED COMPLETION DATE


POOR ORIGINAL

AK I1 PROGRAM TASKS
TO BE COMPLETED


1031 182

MARK II GENERAL PROGRAM SCHEDULE


LOCA RELATED ACTIVITIES



SRV RELATED ACTIVITIES




MISCELLANEOUS ACTIVITIES



1071

T-7

CONDENSATION OSCILLATION



4T CO TEST PROGRAM


OBJECTIVES

- CONFIRM ADEQUACY OF EXISTING C.O. SPECIFICATION
- EXISTING FACILITY (4T)
- PROTOTYPICAL CONFIGURATION
- VARYING TEST CONDITIONS

RJM 9/79

1031 185

TEST CONFIGURATION FOR MARK II CONDENSATION OSCILLATION TESTS



4T CO INSTRUMENTATION (PRELIMINARY)

<u>LOCATION</u>	<u>INSTRUMENT TYPE</u>	<u>MEASUREMENT</u>	<u>NO.</u>
Wetwell & Suppression Pool	Flush Mount Press. xdcr	Pool Boundary Press.	11
		Wetwell airspace press.	1
	Accelerometers	Fac. Response	6
	Strain gages	Fac. Comp. Response	3
	Thermocouples	Pool temperature	11
		Freespace temperature	1
		Cavity Press. xdcr	Liquid Level
Downcomer	Flush Mount Press. xdcr	Vent acoustics	5
	Cavity ΔP xdcr	Vent flow	1
	Cavity press. xdcr	Vent:flow	1
	Level probe	Chug initiation	1
	Accelerometers	Chug initiation	2
	Thermocouples	Vent flow & temp.	1
Drywell	Flush Mount Press. xdcr	Acoustics	1
	Cavity press. xdcr	Static press.	1
	Capacitance Probe	Liquid retention	1
	Thermocouples	Drywell temperature	1
Blowdown Line	Cavity press. xdcr	Blowdown flow	1
	Thermocouples	Blowdown line exit temp.	1
Steam Vessel	Cavity ΔP xdcr	Liquid blowdown flow	8
	Cavity press. xdcr	Vessel pressure	1
Vacuum Breaker	Micro Switch	Valve opening	1

Other Instrumentation

o Air Content

RJM
9/79


1031 187

4T CO TEST MATRIX (PRELIMINARY)

No.	Break Type	Break Size(in)	Pool Temp. (°F)	Vent Submer.(ft.)	Vent Riser
<u>Phase I</u>					
1	Steam	3.0	70	11	No
2	Liquid	3.0	70	11	No
3	Liquid	3.8	70	11	No
4	Liquid	3.8	70	11	Yes
<u>Phase II</u>					
5	Liquid	3.8	80	11	No
6	Liquid	3.8	80	11	No
17	Steam	3.0	70	9	No
18	Steam	3.0	70	13.5	No
16	Steam	3.0	70	11	Yes
7	Liquid	3.8	90	11	No
8	Liquid	3.8	110	11	No
9	Liquid	3.0	110	11	No
10	Liquid	3.0	70	9	No
11	Liquid	3.0	70	13.5	No
12	Liquid	2.5	110	11	No
14	Liquid	2.1	70	11	No
13	Liquid	2.1	110	11	No
15	Liquid	3.0	70	11	Yes
20	Steam	2.5	70	11	No
19	Steam	3.0	70	13.5	No
21	Steam	2.5	70	11	No
22	←----- Repeat ----->				
23	←----- Repeat ----->				

RJM
9/79

4T C.O. TEST MATRIX
 AND
 MARK II C.O. CONDITIONS
 FOR BLOWDOWNS



4T CO DATA INTERPRETATION

ELEMENTS

• VENT PRESSURE
HISTORIES

• POOL WALL
PRESSURES

USAGE

- DETERMINATION OF
STANDING WAVE PRESENCE

- ESTABLISH CO AMPLITUDE
vs FREQUENCY CONTENT

- INTERPRETATION FOR
MARK II APPLICATION

- COMPARE TO DFFR

RJM 9/79

4T C.O. PROGRAM SCHEDULE

- FUNCTIONAL SPECIFICATION - COMPLETE
- TEST PLAN COMPLETE
- COMPLETE FACILITY MODIFICATION SEPT 79
- SHAKEDOWN TEST SEPT/OCT 79
- PHASE I TEST OCT/NOV 79
- PHASE II TEST DEC 79/MAR 80
- DATA REDUCTION NOV 79/JUNE 80
- FINAL TEST REPORT 3Q 80

RJM 9/79

TS
f
e


ACRS PRESENTATION

SEPTEMBER 13, 1979

LOS ANGELES, CALIFORNIA

MULTIVENT TEST PROGRAM

PERFORMED FOR GE AND MARK II OWNERS

BY

CREARE INCORPORATED
HANOVER, NEW HAMPSHIRE

B. R. PATEL
CREARE INC.

MULTIVENT TEST PROGRAM

OVERALL OBJECTIVES


- OBTAIN A SINGLE-VENT/MULTIVENT CHUGGING DATA BASE TO ESTABLISH TRENDS IN POOL WALL LOADS WITH NUMBER OF VENTS
- DEMONSTRATE THAT THE MULTIVENT TRENDS OBSERVED IN SUB-SCALE TESTS ARE VALID BY
 - COMPARING SINGLE VENT DATA AT FOUR SUBSCALES
 - COMPARING MULTIVENT DATA AT TWO SUBSCALES

MULTIVENT TEST PROGRAM

- SINGLE VENT TESTS:
1/10, 1/6, 1/4, 5/12 SCALES
 - MULTIVENT TESTS:
1/10 SCALE 3, 7, 19 VENTS
1/6 SCALE 3, 7 VENTS
 - ADDITIONAL TESTS TO EVALUATE EFFECTS OF:
DRYWELL SIZE
POOL SIZE
VENT LOCATION IN THE POOL
- TOTAL NUMBER OF TESTS: 749

MULTIVENT TEST PROGRAM

PROGRAM OVERVIEW



MULTIVENT TEST PROGRAM

SCHEDULE

ACTIVITY	1978				1979				1980			
	1	2	3	4	1	2	3	4	1	2	3	4
<u>PHASE 1</u>												
• FACILITY CONSTRUCTION & SHAKEDOWN	██████████											
• PHASE 1 TESTS & ANALYSIS				██████████								
• PHASE 1 TEST REPORT									▽			
<u>PHASE 2</u>												
• PHASE 2 TESTS						██████████						
• ANALYSES								██████████				
• FINAL REPORT												▽

MULTIVENT TEST PROGRAM

TEST MATRIX

SUBMERGENCE AND CLEARANCE (FT): SCALED BY THE SCALE FACTOR

WETWELL DIAMETER (FT): SCALED TO KEEP POOL TO VENT AREA RATIO
CONSTANT*

DRYWELL VOLUME (FT³): SCALED BY THE CUBE OF THE SCALE FACTOR*


WETWELL AIRSPACE PRESSURE (PSIA): SUB-AMBIENT TO 45

STEAM MASS FLUX (LBM/SEC FT²): 0.1 TO 16

POOL TEMPERATURE (°F): 90 TO 200

STEAM AIR-CONTENT (%): 0 TO 0.5

—*EXCEPT WHERE VARIED ON PURPOSE.



POOR ORIGINAL


MULTIVENT TEST PROGRAM

PHASE 1

PRELIMINARY DATA


PRELIMINARY UNCHECKED DATA

WETWELL AIRSPACE PRESSURE (psia)	45.0±0.0
STEAM MASS FLUX (lb/sec ft ²)	2 to 8
POOL TEMPERATURE (deg F)	90 to 200
AIR CONTENT (Z)	0.0 to 0.5
GEOMETRIES A.K.P : 1/10 SCALE MULTI-VENT	



PRELIMINARY UNCHECKED DATA

WETWELL AIRSPACE PRESSURE (psia)	45.0±0.0
STEAM MASS FLUX (lb/sec ft ²)	2 to 8
POOL TEMPERATURE (deg F)	90 to 200
AIR CONTENT (Z)	0.0 to 0.5
GEOMETRIES J.M : 1/6 SCALE MULTI-VENT	



1/10 & 1/6 SCALE MULTIVENT DATA

CONCLUSIONS

- OVERALL CHARACTERISTICS OF MULTIVENT CHUGGING ARE SIMILAR TO SINGLE VENT CHUGGING
- MULTIVENT POOL WALL PRESSURES ARE LOWER THAN SINGLE VENT POOL WALL PRESSURES, I.E., THE MULTIVENT MULTIPLIER IS LESS THAN UNITY
- THE MULTIVENT MULTIPLIER DECREASES WITH INCREASING NUMBER OF VENTS

T-9-11
○

IMPROVED CHUG LOAD

MARK II PROGRAM - TASK A.16

SEPTEMBER 13, 1979

1031 203

IMPROVED CHUG LOAD

BACKGROUND

- 4T CHUGGING TESTS (1975,76)
- APPLICATION MEMORANDUM (1977)
- BOUNDING LOADS REPORT (1977)
- MULTIVENT HYDRODYNAMIC MODEL (1978)
- 4T FSI STUDY (ANAMET, 1978)
- NRC FSI CONCERNS
- LARGE MARK II RESPONSES
- TASK A.16 OF THE MARK II PROGRAM

IMPROVED CHUG LOAD

APPROACH

- FURTHER STUDY OF 4T DATA
- 4T MODEL
- VENT EXIT FORCING FUNCTIONS
- MARK II CONTAINMENT MODEL
- MARK II RESPONSE




Figure 3-1 4T Test Facility Schematic

IMPROVED CHUG LOAD


4T DATA

- 137 CHUGS
- FOUR CATEGORIES
- DOMINANT FREQUENCIES
 - VENT PIPE
 - TANK/POOL

4T MODEL


- LINEAR ACOUSTIC FLUID
- POINT SOURCE CHUG EXCITATION
- VENT DECOUPLED FROM TANK/POOL
- SONIC SPEED ADJUSTMENT FOR 4T FSI
- CHUG SIMULATION

IWEGS SIMULATION OF CATEGORY I CHUG



(a) Predicted Pressure Time-History


CHUG NR. 30



(c) Experimental Pressure Time History


POOR ORIGINAL

IWEGS SIMULATION OF CATEGORY I CHUG - C-701 M/S



(b) Predicted PSD

GE CHUG NR. 30 - T = 0.341 - 0.768 SEC



(d) Experimental PSD

Figure 5-5 Comparison of IWEGS Results with Chug #30

IMPROVED CHUG LOAD

4T MODEL VERIFICATION


- KFIX STUDIES
- BELL JAR TESTS
- BASEPLATE EXCITATION TESTS
- STANDARD ANALYSIS OF PIPE FLEXIBILITY EFFECTS
- NASTRAN STUDIES

IMPROVED CHUG LOAD


DEVELOPMENT OF VENT EXIT FORCING FUNCTIONS

- ESTABLISHED SINGLE VENT CRITERIA
 - TOTAL SIGNAL POWER OF 4T RESPONSE
 - POWER BY FREQUENCY
 - PEAK PRESSURE
- COMPUTED WITH 4T MODEL
- ACCOUNTED FOR DIFFERENCE BETWEEN 4T AND MARK II
- ASSIGNED TO MARK II VENTS IN PHASE (LOAD CASE 1)
- ASSIGNED TO MARK II VENTS IN PHASE WITH CIRCUMFERENTIAL MULTIPLIER (LOAD CASE 2)

PSD COMPARISON



4T BCP RESPONSE TO SINGLE-VENT FORCING FUNCTION



IMPROVED CHUG LOAD


MARK II CONTAINMENT MODEL

- ACTUAL MARK II GEOMETRY
- LINEAR ACOUSTIC FLUID
- CHUG EXCITATIONS AS POINT SOURCES

MARK II RESPONSE


- RIGID WALL LOADS
- ACCELERATION RESPONSE SPECTRA

VERY POOR ORIGINAL




Typical Mark II Pressure Suppression Containment


Pressure, kPa




POOR ORIGINAL

SPECTRUM DENSITY - SYMMETRIC








ORIGINAL
POOR




POOR ORIGINAL



1031 218





1031 010

IMPROVED CHUG LOAD

SUMMARY

- DEVELOPED FORCING FUNCTIONS WHICH BOUND MARK II CHUGGING
- PROVIDED BASIS FOR MODELING DIFFERENCES BETWEEN 4T EXPERIMENT AND ACTUAL MARK II
- COMPUTED MARK II ACCELERATION RESPONSE SPECTRA WHICH ARE SIGNIFICANTLY REDUCED FROM RESULTS USING CURRENT DFFR LOAD SPECIFICATION

T-11

CAORSO

SAFETY/RELIEF VALVE DISCHARGE

TEST PROGRAM


WMD 9/79
1031 221

CAORSO TEST

- TEST CONFIGURATION
- TEST OBJECTIVES
- INSTRUMENTATION
- TEST SUMMARY
- PHASE I RESULTS
- PHASE II RESULTS (PRELIMINARY)
- CONCLUSIONS


WD 9/79

1031 222



Mark II Pressure Suppression Containment

POOR
ORIGINAL



NOTE:
 1. ALL MEASUREMENTS ARE IN FEET
 UNLESS OTHERWISE NOTED.

Caorso Quencher Locations

TEST OBJECTIVES

- CONFIRM CROSS QUENCHER LOAD DEFINITION
- PROVIDE DATA BASE FOR FUTURE LOAD REDUCTION
- PROVIDE DATA FOR EVALUATION OF
 - POOL BOUNDARY PRESSURES
 - BUILDING DYNAMIC RESPONSE
 - DISCHARGE LINE CLEARING AND REFLOOD
 - QUENCHER STRUCTURAL RESPONSE
 - POOL THERMAL MIXING
 - SUBMERGED STRUCTURES
 - LINER & DOWNCOMER STRUCTURAL RESPONSE

INSTRUMENTATION

<u>SENSOR:</u>	<u>NUMBER</u>
● SUPPRESSION POOL	
PRESSURE	40
TEMPERATURE	10
● QUENCHER & SRVDL	
PRESSURE	11
TEMPERATURE	17
STRAIN GAGE	40
ACCELEROMETER	6
WATER LEVEL	13
● CONTAINMENT STRUCTURE	
ACCELEROMETER	17
STRAIN GAGE	18
● VACUUM BREAKER FLOW	2
● SRV STEM POSITION	4
● MISCELLANEOUS	9

TEST SUMMARY

<u>CONDITION</u>	<u>NUMBER OF VALVE ACTUATIONS</u>
<u>PHASE I</u>	
SINGLE VALVE FIRST ACTUATION	23
SINGLE VALVE CONSECUTIVE ACTUATION	29
VARIED: WATER LEG	
PIPE TEMPERATURE	
VACUUM BREAKER AREA	
VALVE ACTUATED	
<u>PHASE II</u>	
SINGLE VALVE FIRST ACTUATION	11
SINGLE VALVE CONSECUTIVE ACTUATION	16
MULTIPLE VALVE ACTUATION	11
LEAKY VALVE FIRST ACTUATION	5
LEAKY VALVE CONSECUTIVE ACTUATION	8
SINGLE VALVE EXTENDED BLOW DOWN	1
VARIED: NUMBER OF VACUUM BREAKERS	
PIPE TEMPERATURE	
VESSEL PRESSURE	
VALVE GROUPINGS	

WMD 9/79

1031 227

PHASE I RESULTS

POOL BOUNDARY PRESSURES

DFFR PREDICTIONS

	<u>MAX TEST</u>	<u>MEAN</u>	<u>90-90</u>
● 1st ACTUATION			
POSITIVE	4.8	8.5	12.2
NEGATIVE	4.3	6.2	7.9
● CONSECUTIVE ACTUATION			
POSITIVE	8.0	14.8	23.2
NEGATIVE	5.7	8.9	11.4

● PREDOMINANT BUBBLE FREQUENCIES 5-11 Hz

● OBSERVED PRESSURE-TIME ATTENUATION MORE RAPID THAN DFFR METHODOLOGY

● OBSERVED PRESSURE DISTANCE ATTENUATION MORE THAN DFFR METHODOLOGY

* A DETAILED EVALUATION OF CAORSO DATA IS BEING PERFORMED BY BIR INC. TO IMPROVE SRV LOAD DEFINITION FOR APPLICATION ON WPPSS-NP #2

WMD 9/79

1031 228

● OTHER PARAMETERS

- DISCHARGE LINE PRESSURE AGREED WELL WITH PREDICTIONS
- CONFIRMED EFFECTS OF VACUUM BREAKER SIZE ON REFLOOD TRANSIENT
- DYNAMIC STRESSES ON QUENCHER LESS THAN PREDICTED
- MAXIMUM MEASURED BUILDING RESPONSE FROM SUPPRESSION POOL LOADS WERE BELOW .07g
- LINER STRAINS WELL BELOW PREDICTIONS
- BENDING STRAINS ON DOWNCOMER WELL BELOW PREDICTIONS

WMD 9/79

1031 229

PHASE II RESULTS

PRELIMINARY

- SINGLE VALVE RETESTS CONSISTENT WITH PHASE I
- MULTIPLE VALVE POOL BOUNDARY PRESSURES

DFFR
PREDICTIONS

	<u>MAX TEST</u>	<u>MEAN</u>	<u>90-90</u>
• 4 VALVES			
POSITIVE	6.5	9.9	14.0
NEGATIVE	4.8	6.9	8.5
• 8 VALVES			
POSITIVE	5.5	11.7	17.0
NEGATIVE	4.8	7.7	10.0

- THIRTEEN MINUTE BLOWDOWN RESULTED IN LOCAL TO BULK $\Delta T \approx 10^{\circ}$

CONCLUSIONS

- TEST OBJECTIVES MET
- DATA CONSISTENT AND REPEATABLE
- COMPARES WELL WITH PIPE PREDICTIONS
- WELL BELOW PREDICTIONS FOR POOL BOUNDARY PRESSURES
- DFFR METHODOLOGY CONSERVATIVE *

WMD 9/79


1031 231

T-12

PP&L GKM-IIM TEST PROGRAM

- DECISION TO PROCEED WITH GKM-IIM MADE IN JANUARY, 1979
- SUSQUEHANNA SES FUEL LOAD WAS THEN SCHEDULED FOR MAY, 1980
- THE GKM-IIM TESTS PROVIDED DATA EARLIER THAN THE 4T TEST AND THE MORE PROTOTYPICAL NATURE OF THE FACILITY ALLOWED FOR A MORE EXPEDITIOUS EVALUATION OF DATA AND SUBSEQUENT LICENSING REVIEW

GKM-II-M SCHEDULE



1031 233


Comparison of Fixed Parameters**POOR ORIGINAL**

	SSES Single Cell	GKM II M Test Vessel (Design Values)
Drywell Free Volume, m ³ (including Vent Pipe)	75 78	75 78
Wetwell Free Air Volume, m ³ (normal water level)	50	50
Drywell/Wetwell Air Volume Ratio	1.5	1.5
Free Pool Area, m ²		
Small Cell at Containment Wall	3.66	3.66
Mean Value	5.64	
Vent Pipe Dimensions:		
Length, m	13.86	13.86
Outer Diameter, mm	610	610
Wall Thickness, mm	9.5	9.5
Vent Pipe Submergence, m (high water level)	3.66	3.66
Vent Pipe Clearance, m	3.66	3.66
Distance between Bracing and Vent Opening, m	2.44	2.44
Volume Flexibility of Wet Containment Walls, dm ³ /bar	0.6	0.6

PP&L GKM-IIM TEST PROGRAM


FACILITY MODIFICATIONS INCLUDED:

- REMOVAL OF FLEXIBLE WALL
- ADDITION OF NEW DRYWELL
- ADDITION OF INNER CYLINDER
- STIFFENING OF TANK FOUNDATION
- ADDITION OF PROTOTYPICAL VENT AND BRACING SYSTEM
- ADDITION OF VIEWING PORT
- ADDITION OF SUBMERGED STRUCTURES TARGETS
 - o QUENCHER ARM
 - o WIDE-FLANGE BEAM



POOR ORIGINAL

GKM II - Versuchsstand
 Anordnung des Kondensationsrohres 600 φ im Versuchsbehälter S 3 (Behälter- und Rohrinstrumentierung)
 Versuche 1... 20



GKM II-M-Condensation Tests

Test Tank


PP&L GKM-IIM TEST PROGRAM

APPROXIMATELY 60 CHANNELS OF TEST INSTRUMENTATION

MEASUREMENT VALUE INCLUDE:

- PRESSURES AND TEMPERATURES IN THE DRYWELL, VENT AND WETWELL AIRSPACE AND WETTED BOUNDARY
- WATER LEVEL IN THE VENT
- AIR CONTENT IN THE VENT
- DISPLACEMENT AND STRAIN ON THE VESSEL
- STRAIN ON THE VENT BRACING AND QUENCHER ARM
- FORCE ON THE TARGET BEAM
- MOVIES OF VENT EXIT


- Legend: P Pressure transducer
 T Temperature transducer
 L Water Level
 OR Oxygen Rate




GKM II-M-Condensation Tests

Test Instrumentation

- Legend: P Pressure transducer
 T Thermocouple
 DG Displacement Gage
 LP Level Probe
 LC Load Cell
 SG Strain Gage
 AF Air Fraction




Section A-B





GKM II - M - Condensation Tests

Test Instrumentation



GKM II-M-Condensation Tests

Bracing Configuration



GKM II-M Test Matrix

Test Number	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
Break Size (mm)	*	*																		
			*	*	*	*	*	*	*	*										
											*	*	*	*	*	*	*	*	*	*
														*	*	*	*	*	*	*
Pool Temperature			*	*										*	*	*	*	*	*	*
											*	*	*	*	*	*	*	*	*	*
														*	*	*	*	*	*	*
Drywell Air Content	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*	*
							*	*	*	*	*	*	*	*	*	*	*	*	*	*
Repeat Test		*				*	*	*	*	*	*	*	*	*	*	*	*	*	*	*

12-13
PRESENTATION TO ACRS SUBCOMMITTEE MEETING
OF SEPTEMBER 13, 1979

CHUGGING LOADS - IMPROVED DEFINITION AND
APPLICATION METHODOLOGY TO MARK II CONTAINMENTS

DEVELOPED BY BURNS AND ROE, INC.

FOR

APPLICATION ON WPPSS - WNP #2

B.B.
9/13/79

1031 244

BACKGROUND


- MEETINGS WITH NRC STAFF IN LATE 1978
- MEETINGS WITH NRC STAFF AND CONSULTANTS IN EARLY 1979
- SUMMARY REPORT SUBMITTED TO NRC IN APRIL 1979
- TECHNICAL REPORT SUBMITTED TO NRC IN JUNE 1979

B.B.
9/13/79

1031 245

MARK II CONTAINMENT:

CROSS-SECTIONAL VIEW




E.B.
9/13/79

1031 246

EXPERIMENTAL DATA BASE DEVELOPED IN GE'S 4T FACILITY
FOR MARK II PLANTS.

- 4T TESTS ARE REPRESENTATIVE OF MARK II PLANT
CONDITIONS DURING LOCA;
- 4T FACILITY APPROXIMATES A "UNIT-CELL" OF A
MARK II CONTAINMENT.

SCHEMATIC OF THE 4-T TEST FACILITY




SINGLE VENT DESIGN LOAD
SPECIFICATION

B.B.
9/13/79

1031 249 7

DEVELOPMENT OF IMPROVED CHUGGING
LOAD - FLOW CHART



STEP I. ANALYSIS OF 4T BOUNDARY PRESSURE TRACES

A. IDENTIFY CHUGGING LOAD CHARACTERISTICS

- APPARENT WIDE VARIETY OF PRESSURE TRACES;
- SAME DISCRETE SET OF MAIN FREQUENCIES IDENTIFIED IN ALL TRACES (APPROX.);
- RANDOM TRENDS OBSERVED;
- IMPULSIVE NATURE OF CHUGGING LOAD.

STEP I. ANALYSIS OF 4T BOUNDARY PRESSURE TRACES (CONT'D)

B. IDENTIFY MAIN COMPONENTS OF 4T SYSTEM AFFECTED
BY CHUGGING LOAD.

- VENT FREQUENCIES;
- WATER-TANK-SUPPORT FREQUENCY.

STEP II. DEVELOPMENT OF ANALYTICAL MODEL OF 4T SYSTEM


B.B.
9/13/79

1031 253

11

MATHEMATICAL MODEL OF 4T TANK

(REDUCED MODEL)



POOR
ORIGINAL


B.B.
9/13/79

1031 254

STEP III. DEVELOPMENT OF BOUNDING CHUGGING LOAD AT
"SOURCE" (I.E., AT VENT EXIT)

- PERFORMED STATISTICAL ANALYSIS OF DATA;
- DEFINED THE DESIGN LEVEL LOAD;
- DEVELOPED THE DESIGN LOAD SPECIFICATION.

DEVELOPMENT OF A BOUNDING CHUGGING
LOAD AT "SOURCE" - FLOW CHART




POOR ORIGINAL

B.B.
9/13/79

1031 256

DESIGN LOAD AT SOURCE




CHUGGING LOAD - APPLICATION METHODOLOGY TO MARK II
CONTAINMENTS

B.B.
9/13/79

1031 258 16



APPLICATION METHODOLOGY TO
MARK II CONTAINMENTS - DIAGRAM



POOR
ORIGINAL

B.B.
9/13/79


1031 259




POOR ORIGINAL

B.B.
9/13/79

1031 260 18



$K=1.0$



SECTION B-B




II - MAINLY NON-SYMMETRICAL LOADING CONDITION

B.B.
9/13/79

POOR
ORIGINAL


1031 261



JPPSS REACTOR BLDG. NEARLY SYMMETRIC CHUCCING
 MASS NO. 59 EL. 520 FT. HORIZ. TRANSLATION
 RPV SUPPORT

B.B.
 9/13/79

POOR
 ORIGINAL



WPPSS REACTOR BLDG. NEARLY SYMMETRIC CURVE, NC
 MASS NO. 33 EL. 459 FT. HORIZ. TRANSLATION
 CONTAINMENT VESSEL

B.B.
 9/13/79

POOR
 ORIGINAL

T-14

NRC Comments
Mark II Generic
Long Term Program

1. CO Tests
2. Creare Tests
3. Improved Chug Load

NRC COMMENTS
CO TESTS

- ACHIEVE COMBINATION OF HIGH VENT STEAM MASS FLUX AND AIR CONTENT TO BOUND ANTICIPATED PLANT VALUES
- REPLICATE TESTS AT LIMITING CONDITIONS
- ACCURATE MEASUREMENT OF VENT AIR/STEAM MIXTURE
- MEASURE VENT LATERAL LOADS

NRC COMMENTS

CREATE TESTS

- TESTS APPEAR TO CONFIRM MULTIVENT MULTIPLIER LESS THAN ONE
- FURTHER STUDY OF FSI EFFECTS
- DETAILED STUDY OF RESULTS

NRC COMMENTS
IMPROVED CHUG SPECIFICATION

- INVESTIGATE 4T HIGH FREQUENCY RESPONSE
- VERIFY SIMPLIFIED ACOUSTIC MODEL ASSUMPTIONS
- METHODOLOGY SHOULD BE CONFIRMED BY APPLICATION TO RELATED STEAM TESTS
- MULTIVENT TEST DATA SHOULD BE STUDIED TO VERIFY STATISTICAL TREATMENT OF 4T DATA.