

**Florida
Power**
CORPORATION

September 24, 1979

File: 3-0-3-a

Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Facility Operating License No. DPR-72

Dear Sir:

As requested in Amendment No. 23 to our Facility Operating License No. DPR-72, Florida Power Corporation proposes the following items:

- a. A weekly surveillance check of the noncertified fire detection and signaling system annunciator panel in the control room; and
- b. A monthly test of the unsupervised circuits leading from the fire alarm control panel to the noncertified fire detection and signaling system annunciator panel in the control room.

These items will be implemented on or before November 1, 1979.

If you require any additional discussion concerning our submission, please contact us as soon as possible.

Sincerely,

FLORIDA POWER CORPORATION

W. P. Stewart

W. P. Stewart
Manager
Nuclear Operations

RMBkcRc(D6)


1029 065

79092603~~27~~²⁷

STATE OF FLORIDA


COUNTY OF PINELLAS

W. P. Stewart states that he is the Manager, Nuclear Operations, of Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information and belief.



W. P. Stewart

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 24th day of September, 1979.



Notary Public

Notary Public, State of Florida at Large,
My Commission Expires: August 8, 1983

CameronNotary 3(D12)

1029 066