



720

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION IV  
611 RYAN PLAZA DRIVE, SUITE 1000  
ARLINGTON, TEXAS 76012

August 16, 1979

In Reply Refer to:  
RIV  
Docket No. STN 50-482/Rpt. 79/08

Kansas Gas and Electric Company  
ATTN: Mr. G. L. Koester  
Vice President-Operations  
Post Office Box 208  
Wichita, Kansas 76201

Gentlemen:

Thank you for your letter dated June 21, 1979, informing us of the steps you have taken to correct the deviation identified in our letter dated May 17, 1979.

Based on the telecon on July 12, 1979, between Mr. John Bailey of your staff and Mr. E. R. Schweibinz of our Region III office, your FSAR submittal will reflect the Bechtel Specification No. 10466-C151(Q), Paragraph 7.5.7, which requires (1) that only type 1 or 2 radiographic film shall be used, and (2) that fluorescent screens shall not be used. Based on this understanding, your response is acceptable and we will examine your corrective action during a future inspection.

Please inform us if your understanding of this item is different from that stated.

Sincerely,

A handwritten signature in cursive script, appearing to read "W. C. Seidle".

W. C. Seidle, Chief  
Reactor Construction and  
Engineering Support Branch

790926 0380

1029 067