



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

September 19, 1979

U. S. Nuclear Regulatory Commission
Attention: Mr. R. H. Engelken, Director
Region V Office of Inspection &
Enforcement
1990 North California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94596

Docket No. 50-312
Rancho Seco Nuclear Generating
Station, Unit No. 1
IE Bulletin 79-05C

Dear Mr. Engelken,

The Sacramento Municipal Utility District responded to IE Bulletin No. 79-05C on August 27, 1979. In that response, we committed to provide further analysis covering a range of time lapses between reactor trip and pump trip to support the early reactor coolant pump trip. The Babcock & Wilcox Company has performed this analysis and the District has determined this analysis to be applicable to Rancho Seco Unit 1. The report, "Supplemental Small Break Analysis" is enclosed.

Item 4 of IE Bulletin 79-05C required emergency procedure revision and licensed reactor operator training based on the guidelines developed under the analysis to support an early reactor coolant pump trip. We wish to inform you at this time that the required procedure revision and operator training was completed as requested.

Sincerely yours,

POOR
ORIGINAL

John J. Mattime
Assistant General Manager
and Chief Engineer

Enclosure

cc: Director, Office of Inspection and Enforcement
Director, Office of Nuclear Reactor Regulation ✓

COPY

1080 019

7909260383

COPY
6002
5/11