

MAY 26 1978

POOR ORIGINAL

SD
416/417

MEMORANDUM FOR: J. F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management

FROM: I. Sihweil, Chief
Structural Engineering Branch
Division of Systems Safety

SUBJECT: ACCEPTANCE REVIEW OF THE GRAND GULF NUCLEAR STATION
OPERATING LICENSE APPLICATION (SEB:1135)

The Structural Engineering Branch has completed a preliminary review of the FSAR submitted by the applicant. The information provided in our areas is in conformance with the September, 1975 edition of the "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants". Due to other higher priority tasks, we have not reviewed the adequacy of the information provided. This will be done at the Q1 stage.

On the basis of our preliminary review, we recommend the docketing of the subject application. Since this is the first OL application that utilized a Mark III containment, the applicant should be prepared to provide detailed information that demonstrates the ability of structures, systems and components to withstand the effects of pool dynamic loads.

DISTRIBUTIONS
NRR READING FILE
SEB READING FILE
SUBJECT

I. Sihweil, Chief
Structural Engineering Branch
Division of Systems Safety

cc: R. Mattson
R. Boyd
N. Heller
J. Knight
D. Vassallo
C. Thomas
C. Hofmayer
C. Tan

memo
Side 4

OFFICE	DSS:SEB	DSS:SEB	DSS:SEB 1-5	
SURNAME	CTan;jd	CHofmayer	ISihweil	773080247
DATE	5/25/78	5/26/78	5/26/78	