

TERK



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SEPTEMBER 18 1979

Docket No. 50-344

Mr. Charles Goodwin, Jr.
Assistant Vice President
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Goodwin:

RE: REACTOR CAVITY SEAL RING GENERIC ISSUE (PWR)

We have completed our review of your letter of January 27, 1978, in regard to the potential for the reactor cavity annulus seal ring to become a destructive missile in the event of a loss-of-coolant accident pipe break inside the reactor cavity.

Your response acceptably resolves this issue for Trojan Nuclear Plant.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Schwencer".

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

1073 297

7910020 704 P

Mr. Charles Goodwin, Jr.
Portland General Electric Company

cc: Mr. H. H. Phillips
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97051

Warren Hastings, Esquire
Counsel for Portland General
Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Mr. Jack W. Lentsch, Manager
Generation Licensing and Analysis
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Columbia County Courthouse
Law Library, Circuit Court Room
St. Helens, Oregon 97501

Director, Oregon Department of Energy
Labor and Industries Building, Room 111
Salem, Oregon 97310

Richard M. Sandvik, Esquire
Counsel for Oregon Energy Facility
Siting Counsel and Oregon Department
of Energy
500 Pacific Building
520 S.W. Yamhill
Portland, Oregon 97204

Michael Malmrose
U. S. Nuclear Regulatory Commission
Trojan Nuclear Plant
P. O. Box 0
Rainier, Oregon 97048

Mr. Donald W. Godard, Supervisor
Siting and Regulation
Oregon Department of Energy
Labor and Industries Building, Room 111
Salem, Oregon 97310

1073 298