



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V
1990 N. CALIFORNIA BOULEVARD
SUITE 202, WALNUT CREEK PLAZA
WALNUT CREEK, CALIFORNIA 94596

T/C

September 14, 1979

Docket No. 50-206

Southern California Edison Company
P. O. Box 800
2244 Walnut Grove Avenue
Rosemead, California 91770

Attention: Mr. A. L. Arenal
Vice President, Advanced Engineering

Gentlemen:

The enclosed Information Notice No. 79-22 provides information with regard to a potential unreviewed safety question involving high energy lines and control systems.

Sincerely,

R. H. Engelken
Director

Enclosures:

1. Information Notice 79-22
2. List of IE Information Notices
Issued in Last Six Months

cc w/enclosures:
J. M. Curran, SCE
J. T. Head, SCE

POOR ORIGINAL

1076 080

7910110306

DUPLICATE

Accession No: 79082201²⁴
SSINS: 6870

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

September 14, 1979

IE Information Notice No. 79-22

QUALIFICATION OF CONTROL SYSTEMS

Public Service Electric and Gas Company notified the NRC of a potential unreviewed safety question at their Salem Unit 1 facility. This notification was based on a continuing review by Westinghouse of the environmental qualifications of equipment that they supply for nuclear steam supply systems. Based on the present status of this effort, Westinghouse has informed their customers that the performance of non-safety grade equipment subjected to an adverse environment could impact the protective functions performed by safety grade equipment. These non-safety grade systems include:

- Steam generator power operated relief valve control system
- Pressurizer power operated relief valve control system
- Main feedwater control system
- Automatic rod control system

These systems could potentially malfunction due to a high energy line break inside or outside of containment. NRC is also concerned that the adverse environment could also give erroneous information to the plant operators. Westinghouse states that the consequences of such an event could possibly be more limiting than results presented in Safety Analysis Reports, however, Westinghouse also states that the severity of the results can be limited by operator actions together with operating characteristics of the safety systems. Further, Westinghouse has recommended to their customers that they review their systems to determine whether any unreviewed safety questions exist.

This Information Notice is provided as an early notification of a possibly significant matter. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If NRC evaluations so indicate, further licensee actions may be requested or required. If you have questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

No written response to this Information Notice is required.

1076 081