


**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

--	--	--	--	--	--	--



(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	0	F	S	V	1	2	0	0	-	0	0	0	0	0	0	3	4	1	1	2	0	4			5				
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE						30	CAT				58

CON'T

REPORT SOURCE L 6 0 5 0 0 0 2 6 7 7 1 0 0 5 7 9 8 1 0 3 1 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0800 hours on October 5, 1979, with plant at 35% thermal power and 84 MWe, reactor  
0 3 | dewpoint per Primary Coolant log was -5°F with average core outlet temperature of  
0 4 | 1,169°F. This is outside the allowable value specified in LCO 4.2.11, Figure 4.2.11-1,  
0 5 | and is reportable per Technical Specification AC 7.5.2(b)2. No accompanying occur-  
0 6 | rence. No affect on public health or safety. Similar occurrences reported in RO  
0 7 | 76-06, 77-02, 77-13, 78-16, 78-39, and 79-31.

08 \_\_\_\_\_ 80

0	9	SYSTEM CODE		C	B	11	CAUSE CODE		E	12	CAUSE SUBCODE		B	13	COMPONENT CODE					V	A	L	V	E	X	14	COMP. SUBCODE		E	15	VALVE SUBCODE		D	16
7	8			9	10				11				12							13						19				20				
17		LER/RO REPORT NUMBER		EVENT YEAR		7	9	21	22	SEQUENTIAL REPORT NO.		0	4	3	24	26	OCCURRENCE CODE		0	3	28	29	REPORT TYPE		L	30	REVISION NO.		0	32				
						23			27																									
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER																		
A	18	Z	19	Z	20	Z	21	0	0	0	0	Y	23	N	24	A	25	V	0	8	5	26												
33	34	35	36	37	40	41	42	43	44	47																								

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The increase in moisture was a result of bypassing the helium dryer due to cross-tower  
1 1 leakage. Cause of leakage was torn teflon seat on the disc of one of the reacti-  
1 2 vation valves. The disc on the air operated Veilan valve was replaced, along with two  
1 3 helium dryer effluent filters. Dryer was returned to service and reactor dewpoint  
1 4 followed a decreasing trend until acceptable range was reached.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
1	5	E	(28)	0	3	5	(29)	N/A	A	(31)	Personnel Observation	(32)

ACTIVITY CONTAINED IN RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 N/A N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION (39)				
1	7	0	0	0	(37)	Z	(38)	N/A	

7	8	9	11	12	13	80
PERSONNEL INJURIES						
NUMBER		DESCRIPTION		(41)		

[illegible]

TYPE		DESCRIPTION	
1	9	Z	(42) N/A

1271 273

PUBLICITY  
 ISSUED DESCRIPTION (45)  
 2 0 N (44) N/A  
 7911060 447  
 NRC USE ONLY

NAME OF PREPARER

J. W. Gahm

PHONE: (303) 785-2253

NRC USE ONLY

7911060 447

1271 293

0-9