

APPENDIX III
DATA 1977 REFUELING
REACTOR BUILDING LEAK RATE TESTING

7912040404

1408 259

~~7910100477~~

7910100514

P

APPENDIX E DATA 1977 REFUELING

REACTOR BUILDING LOCAL LEAK RATE TESTING

04/12/77

THIS LIST INCLUDES ALL PENETRATIONS AND VALVES WHICH ARE REQUIRED TO BE LEAK TESTED BY PRESENT TECH SPEC AND WHICH WERE PROMISED IN THE SEPTEMBER 75 LETTER FROM MET ED TO THE NRC

TECH SPEC
TYPE B/C SP 1303-11.18

POOR ORIGINAL

VALVE/ PENETRATION	SCHEDULED DATE	1977 "AS FOUND" LEAKAGE (SCCM)	DATE LAST TEST	TARGET CRITERIA (SCCM)	"AS LEFT" LEAKAGE (SCCM)
AH-V1A/18	18 MARCH	>2000*	04/12/77	1500	02243
AH-V1C/D	18 MARCH	0933	04/02/77	1500	00933
CA-V1	REFUELING	00022	03/26/77	0150	00022
CA-V2	REFUELING	00080	03/26/77	0600	00080**
CA-V3	REFUELING	00125	03/26/77	0150	00125
CA-V4A	REFUELING	00080	03/26/77	0150	00080
CA-V4B	REFUELING	00080	03/26/77	0150	00080**
CA-V5A	REFUELING	03550*	04/07/77	0600	0022**
CA-V5B	REFUELING	06200*	04/07/77	0600	2000
CA-V13	REFUELING	00080	03/26/77	0150	0080
CA-V189	REFUELING	00022	03/20/77	0600	0022
CF-V24	REFUELING	00080	03/24/77	0075	0080**
CF-V25	REFUELING	00022	03/25/77	0075	0022**
CF-V12A	REFUELING	00080	03/24/77	0225	0080**
CF-V12B	REFUELING	00084	03/24/77	0225	0084
CF-V19A	REFUELING	03100	04/02/77	0300	3100
CF-V19B	REFUELING	00050	03/24/77	0300	0050**
CF-V20A	REFUELING	00080	03/25/77	0300	0080
CF-V20B	REFUELING	00022	03/25/77	0300	0022
CM-V1	REFUELING	00080	03/26/77	0100	0080**
CM-V2	REFUELING	14000*	03/30/77	0100	0080
CM-V3	REFUELING	00080	03/26/77	0100	0080**
CM-V4	REFUELING	00080	03/26/77	0100	0080
DH-V64	REFUELING	00022	03/22/77	0075	0022**
DH-V65	REFUELING	00140	03/22/77	0225	0140
HP-V1	REFUELING	01600*	03/30/77	0400	0150
HP-V6	REFUELING	01800*	03/21/77	0400	0110**

1408 258

POOR ORIGINAL

F.T.T. EAST	REFUELING	N.A.	04/12/77	0000	N.A.
F.T.T. WEST	REFUELING	N.A.	04/12/77	0000	N.A.
IC-V2	REFUELING	01120	04/09/77	0800	01120
IC-V3	REFUELING	24000*	04/01/77	0800	00022**
IC-V4	REFUELING	>34000*	04/01/77	0800	04500
IC-V5	REFUELING	00155	03/23/77	0400	00155
MJ-2a	REFUELING	00025	03/20/77	0225	00025
MU-2a	REFUELING	00022	03/20/77	0225	00022
MU-V3	REFUELING	00022	03/20/77	0900	00022**
MU-V18	REFUELING	01300	03/17/77	0900	01300
MU-V20	REFUELING	00022	03/21/77	0600	00022**
MU-V25	REFUELING	00022	03/21/77	0150	00022
MU-V26	REFUELING	00022	03/22/77	0600	00022**
MU-V116	REFUELING	04300	03/22/77	0225	04300
NS-V4	REFUELING	00725	03/27/77	0800	00725
NS-V15	REFUELING	01190	03/27/77	0800	01190
NS-V35	REFUELING	00800	03/27/77	0800	00800
RB-V2A	REFUELING	01180	03/25/77	0800	01180
RB-V7	REFUELING	>42500*	04/11/77	0800	11200
SF-V23	REFUELING	00022	03/19/77	0600	00022
WDG-V3/4	REFUELING	25000*	04/10/77	0400	04850
WDL-V303	REFUELING	00022	03/27/77	0800	00022**
WDL-V304	REFUELING	00379	03/27/77	0800	00379
WDL-V534	REFUELING	00115	03/31/77	1600	00115**
WDL-V535	REFUELING	00135	03/31/77	1600	00135
PERS ACCESS	MAY 17/NOV 17	01152	12/21/75	1400	01152
EMER ACCESS	MAY 13/NOV 13	01604	12/19/75	1400	01604
PENETR 104	REFUELING	00000	04/11/77	0000	00000
PENETR 105	REFUELING	00000	03/25/77	0000	00000
PENETR 106	REFUELING	00000	03/25/77	0000	00000
PENETR 210	REFUELING	00000	04/06/77	0000	00000
PENETR 211	REFUELING	00000	04/06/77	0000	00000

TOTAL LEAKAGE	>175332	NA	28350	47157
LEAKAGE/PENETRATION TOTAL	>171024	NA	NA	43507
ACCEPTANCE CRITERIA	111599	NA	NA	111599
NITROGEN/AIR				

NOTES: THESE LEAK RATES NOT CORRECTED FOR INST. ERROR.

* REPAIR PERFORMED

** THIS LEAKAGE NOT INCLUDED IN LEAKAGE/PENETRATION TOTAL

POOR ORIGINAL

1408 252
260