

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C T M N S | 2 0 0 - 0 0 0 0 - 0 0 0 | 3 4 1 1 1 1 | 4 5  
7 8 9 14 15 20 26 30 37 CAT EN 5

CON'T  
01 | REPORT SOURCE | 1 | 6 | 0 5 | 0 0 | 0 3 | 3 6 | 7 | 0 3 | 0 3 | 7 9 | 8 | 0 8 | 3 0 | 7 9 | 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | During steady-state power operation, the seismic bracing for cells 18 and 31 in  
03 | the 201B battery was removed to allow for replacement of these cells. This  
04 | resulted in the battery being declared inoperable in accordance with Section  
05 | 3.8.2.3.b of the Technical Specifications. The cells were replaced, the seismic  
06 | bracing reinstalled and the battery declared operable within approximately 3 hours.  
07 |  
08 |

09 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
7 8 9 10 11 12 13 15 16 20  
E C 11 | B 12 | A 13 | B A T T R Y 14 | 7 15 | 7 16  
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
7 8 21 22 23 24 26 27 28 29 30 31 32  
7 9 | - | 0 2 3 | / | L | - | 0 |

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NRPD-A FORM NO. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
33 34 35 36 37 40 41 42 43 44 47  
A 18 | C 19 | Z 20 | Z 21 | 0 0 0 0 22 | N 23 | Y 24 | A 25 | C 1 7 3 35

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
10 | The cells had to be replaced as a result of a reduction in individual cell voltages  
11 | although the cells were still operable. This condition was the subject of an informa-  
12 | tional letter to the Office of Inspection and Enforcement on 2/20/79. Both the  
13 | 201A and 201B batteries will be replaced as soon as new cells are available. This  
14 | is expected to occur in the next several weeks.

15 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION  
7 8 9 10 12 13 44 45 46 60  
E 28 | 1 0 0 20 | NA 39 | B 31 | Surveillance Testing 32  
16 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE  
7 8 9 10 11 44 45 60  
Z 33 | Z 34 | NA 35 | NA 36  
17 | PERSONNEL EXPOSURES NUMBER | TYPE | DESCRIPTION  
7 8 9 11 12 13 60  
0 0 0 37 | Z 38 | NA 39  
18 | PERSONNEL INJURIES NUMBER | DESCRIPTION  
7 8 9 11 12 60  
0 0 0 40 | NA 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | DESCRIPTION  
7 8 9 10 60  
Z 42 | NA 43  
20 | PUBLICITY ISSUED | DESCRIPTION  
7 8 9 10 60  
H 44 | NA 45  
7909100 3/8  
NRC USE ONLY  
68 69 60

POOR ORIGINAL

934 073