



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cornova, Illinois 61242
Telephone 309/654-2241

NAB

NJK-79-305

August 21, 1979

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reference: Quad-Cities Nuclear Power Station
Docket No. 50-254, DPR-29, Unit 1
Appendix A, Sections Table 3.2-1 and 6.6.8.2.a

Enclosed please find Reportable Occurrence Report No. RO 79-25/03L for Quad-Cities Nuclear Power Station. This report is submitted to you in accordance with the requirements of Technical Specification 6.6.8.2.a as an engineered safety feature instrument setting which was found to be less conservative than those established by the Technical Specification but which did not prevent the fulfillment of the functional requirement of the affected system.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/JCV/cmd

cc: R. J. Janeczek

933313

7909120412

AUG 27 1979

Aug 27 1979