

TR



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

September 11, 1979

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Attention: Mr. Boyce H. Grier, Director

Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334
Response to IE Bulletin 79-14 (30 Day Report)


Dear Mr. Grier:

Supplementing our response of July 30, 1979 to IE Bulletin 79-14, we are transmitting herewith the balance of information as required for the 60 day report. The list indicates the method that was used or will be used to verify the seismic design input with the as-built condition. Also included on the attached list are the source data for the valve and valve operators for the remaining 20 percent of the seismically analyzed problems which were left out of the 30 day report.

A review of the results of the as-built verification inspection performed by Duquesne Light Company was conducted by Stone & Webster. It was concluded by S&W that the results of the inspection serve to verify the validity of the "As-Built" piping isometrics.

We trust that the information submitted satisfies the requirements up to and including the 60 day report of IE Bulletin 79-14.

Very truly yours,


C. N. Dunn
Vice President, Operations

cc: United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

1149 074

7910220200