

UNIT Three Mile Island

DATE June 8, 1976

COMPLETED BY L. L. Lawyer

TEL. NO. 215-929-3601

DAILY PLANT POWER OUTPUT

MONTH MAY

<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>	<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>
1	<u>- 9</u>	21	<u>-39</u>
2	<u>-12</u>	22	<u>-41</u>
3	<u>-11</u>	23	<u>-42</u>
4	<u>-10</u>	24	<u>-42</u>
5	<u>-11</u>	25	<u>-42</u>
6	<u>-11</u>	26	<u>-25</u>
7	<u>-11</u>	27	<u>141</u>
8	<u>-13</u>	28	<u>265</u>
9	<u>-15</u>	29	<u>492</u>
10	<u>-15</u>	30	<u>592</u>
11	<u>-15</u>	31	<u>625</u>
12	<u>-14</u>		
13	<u>-13</u>		
14	<u>-14</u>		
15	<u>-13</u>		
16	<u>-14</u>		
17	<u>-22</u>		
18	<u>-27</u>		
19	<u>-27</u>		

1505 261

7910810 628

SUMMARY:

UNIT NAME Three Mile Island - Unit 1
 DATE June 8, 1976
 COMPLETED BY L. L. Lawyer
 TEL. NO. 929-3601 Ext. 111

REPORT MONTH MAY

PLANT SHUTDOWNS

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
2	2/20/76	S	620.8	C	A	Completion of Refueling
3	5/27/76	F	7	G	C	<p>During power escalation nuclear instrumentation indicated power was 46% while actual power, as calculated by a reactor heat balance, was 25%. Nuclear Instrumentation power range channel NI-6 was calibrated to 25% power while power range channel NI-5 was controlling Integrated Control System's (ICS) functions. After NI-6 calibration was completed, ICS control was switched from NI-5 to NI-6 prior to changing the control rod drive system control to the manual position. Since demand was at 46% before the switch, the ICS system "saw" that reactor power had dropped lower than demand (i.e. 25% vs. 46%) and started pulling control rods to increase power. Reactor Protection System (RPS) channels A&C tripped on overpower at 50% power (RPS trip setpoints had been set to 50% power for reactor physics tests purposes).</p>

(1) REASON:
 A-EQUIPMENT FAILURE (EXPLAIN)
 B-MAINT. OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING AND
 LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR
 (BY DATE)

(2) METHOD:
 A-MANUAL
 B-MANUAL SCRAM
 C-AUTOMATIC SCRAM

1505 261²

UNIT NAME Three Mile Island
 DATE June 8, 1976
 COMPLETED BY L. L. Lawyer
 TEL. NO. 929-3601 Ext. 111

OPERATING STATUS

1. REPORTING PERIOD: 0001, 760501 THROUGH 2400, 760531
 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL Mwt 2535 MWe-NET 792 (MAXIMUM DEPENDABLE CAPACITY - MDC)
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): None
4. REASONS FOR RESTRICTIONS (IF ANY): NA

	THIS MONTH	YR-TO-DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>184.6</u>	<u>1369.7</u>	<u>11382.3</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON-LINE	<u>116.2</u>	<u>1293.7</u>	<u>11054.6</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL POWER GENERATED (MWH)	<u>176,436</u>	<u>3,087,021</u>	<u>26,918,621</u>
10. GROSS ELECTRICAL POWER GENERATED (MWH)	<u>56,570</u>	<u>1,040,794</u>	<u>9,071,208</u>
11. NET ELECTRICAL POWER GENERATED (MWH)	<u>37,825</u>	<u>953,572</u>	<u>8,472,907</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>24.8</u>	<u>37.6</u>	<u>74.3</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>15.6</u>	<u>35.5</u>	<u>72.2</u>
14. UNIT CAPACITY FACTOR (3)	<u>6.4</u>	<u>33.0</u>	<u>69.9</u>
15. FORCED OUTAGE RATE (4)	<u>5.7</u>	<u>3.9</u>	<u>8.8</u>

16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH): None

17. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA

18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): NOT APPLICABLE

(1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON-LINE}}{\text{GROSS HOURS IN REPORTING PERIOD}} * 100$

(3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MDC (MWe - net)} * \text{GROSS HOURS IN REPORTING PERIOD}}$

(4) FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON-LINE} + \text{FORCED OUTAGE HOURS}} * 100$