

UNIT Three Mile Island - Unit 1

DATE 5/8/75

COMPLETED BY L. L. Lawyer

TEL. NO. 929-3601 Ext. 567

DAILY PLANT POWER OUTPUT

MONTH April, 1975

<u>DAY</u>	<u>AVERAGE DAILY MWe-net *</u>	<u>DAY</u>	<u>AVERAGE DAILY MWe-net *</u>
1	<u>722</u>	21	<u>806</u>
2	<u>801</u>	22	<u>808</u>
3	<u>801</u>	23	<u>800</u>
4	<u>807</u>	24	<u>798</u>
5	<u>481</u>	25	<u>796</u>
6	<u>-16</u>	26	<u>802</u>
7	<u>-13</u>	27	<u>803</u>
8	<u>-17</u>	28	<u>801</u>
9	<u>-38</u>	29	<u>800</u>
10	<u>-23</u>	30	<u>798</u>
11	<u>-12</u>	31	<u> </u>
12	<u>-16</u>		
13	<u>-37</u>		
14	<u>36</u>		
15	<u>618</u>		
16	<u>735</u>		
17	<u>801</u>		
18	<u>803</u>		<u>1505 325</u>
19	<u>796</u>		
20	<u>804</u>		

*Average MWe greater than 792 due to winter
operating condition

7910310 706

UNIT NAME Three Mile Land Unit 1
DATE 5/8/75

COMPLETED BY L. L. Lawyer

TEL. NO. (215) 929-3601 Ext. 56

O P E R A T I N G S T A T U S

1. REPORTING PERIOD: 0001,750401 THROUGH 2400,750430
2. GROSS HOURS IN REPORTING PERIOD: 720
2. CURRENTLY AUTHORIZED POWER LEVEL MWe 2535 MWe-NET 792 (MAXIMUM DEPENDABLE CAPACITY = MDC)
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY): None
4. REASONS FOR RESTRICTIONS (IF ANY): None

	THIS MONTH	YR-TO-DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL	<u>518.7</u>	<u>2672.0</u>	<u>5254.8</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON-LINE	<u>506.3</u>	<u>2611.1</u>	<u>5171.4</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL POWER GENERATED (MWH) . . .	<u>1,232,010</u>	<u>6,462,793</u>	<u>12,659,195</u>
10. GROSS ELECTRICAL POWER GENERATED (MWH) . . .	<u>414,560</u>	<u>2,206,661</u>	<u>4,316,331</u>
11. NET ELECTRICAL POWER GENERATED (MWH) . . .	<u>385,084</u>	<u>2,072,362</u>	<u>4,050,174</u>
12. REACTOR AVAILABILITY FACTOR (1)	<u>72.0%</u>	<u>92.8%</u>	<u>90.9%</u>
13. UNIT AVAILABILITY FACTOR (2)	<u>70.3%</u>	<u>90.7%</u>	<u>89.4%</u>
14. UNIT CAPACITY FACTOR (3)	<u>67.5%</u>	<u>90.9%</u>	<u>88.4%</u>
15. FORCED OUTAGE RATE (4)	<u>29.7%</u>	<u>9.3%</u>	<u>6.6%</u>

16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH): June, 1975 - 11 days
May 31 to June 10
Control Rod Interchange

17. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: Not Applicable

18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): NOT APPLICABLE

1. REACTOR AVAILABILITY FACTOR= HOURS REACTOR WAS CRITICAL *100
GROSS HOURS IN REPORTING PERIOD

1505 :26

2. UNIT AVAILABILITY FACTOR= HOURS GENERATOR ON-LINE *100
GROSS HOURS IN REPORTING PERIOD

3. UNIT CAPACITY FACTOR= NET ELECTRICAL POWER GENERATED *100
MDC (MWe - net) * GROSS HOURS IN REPORTING PERIOD

4. FORCED OUTAGE RATE= FORCED OUTAGE HOURS *100
NET OPERATING HOURS + FORCED OUTAGE HOURS

SUMMARY: On 4/1/75 the Unit was still in the process of returning to full power operation after the turbine trip in March. The Unit then operated in full power for approximately 3.5 days until Rod 6 in control rod group 4 dropped into the core. Unit cooldown was required to fix the failure. On 4/9/75 an attempt was made to take the reactor critical but Rod 7 in control rod group 5 could not be withdrawn. The Unit had to be cooled down again to replace Group 5 Rod 7 stator. On 4/14/75 the Unit was returned to service and remained at full power for the remainder of the month.

UNIT NAME Three Mile Island Unit 1

DATE 5/8/75

COMPLETED BY L. L. Lawyer

TEL. NO. (215) 929-3601 Ext. 567

REPORT MONTH April, 1975

PLANT SHUTDOWNS

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	COMMENTS
3	4/5/75	F	213.7	A	A	Control Rod 6 in Group 4 dropped into the core due to a faulty cable connector located on the reactor vessel head near the Stator. The rod could not be withdrawn so the plant was shutdown. (Nuclear Equipment)

- (1) REASON:
 A-EQUIPMENT FAILURE (EXPLAIN)
 B-MAINT. OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING AND
 LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR
 (EXPLAIN)
 H-OTHER

- (2) METHOD:
 A-MANUAL
 B-MANUAL SCRAM
 C-AUTOMATIC SCRAM

1505 327