

## UNITED STATES NUCLEAR REGULATORY COMMISSION

tic

REGION III
799 ROOSEVELT ROAD
GLEN FLLYN, ILLINOIS 60137

NOV 20. 1975 19

Docket No. 50-255

Consumers Power Company
ATTN: Mr. R. B. DeWitt
Vice President
Nuclear Operations
212 West Michigan Avenue
Jackson, MI 49201

Gentlemen:

The enclosed IE Bulletin No. 79-26 is forwarded to you for information.

No written response is required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

In James G. Keppler
Director

Enclosure: IE Bulletin No. 79-26

cc w/encl:
Mr. J. G. Lewis, Manager
Central Files
Director, NRR/DPM
Director, NRR/DOR
PDR
Local PDR
NSIC
TIC
Ronald Callen, Michigan Public
Service Commission
Myron M. Cherry, Chicago

1504 166

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

SSINS: 6820 Accession No.: 7910250475

November 20, 1979

IE Bulletin No. 79-26

PORON LOSS FROM BWR CONTROL BLADES

Description of Circumstances:

The General Electric Company (GE) has informed us of a failure mode for control blades which can cause a loss of boron poison material. Hot cell examinations of both foreign and domestic blades have revealed cracks near the upper end of stainless steel tubing and loss of boron from the tubes. The cracks and boron loss have so far been confined to locations in the poison tubes with more than 50 percent Boron-10 ( $B^{10}$ ) local depletion. Observed crack sizes range from a quarter to a half inch in length and from one to two mils in width.

GE has postulated that the cracking is due to stress corrosion induced by solidification of boron carbide ( $B_4$ C) particles and swelling of the compacted  $B_4$ C as helium and lithium concentrations grow. Once primary coolant penetrates the cladding (i.e., the cracking has progressed through the cladding wall and the helium-lithium pressures are sufficient to open the crack), boron is leached out of the tube at locations with more than 50 percent  $B^{10}$  local depletion (local depletion is considered to be twice the average depletion). It was further found with similar cracking but with less than 50 percent local depletion of  $B^{10}$ , that leaching did not occur even though primary coolant had penetrated the cladding.

The cracking and boron loss shorten the design life of the control blade. According to the GE criteria the end of design life is reached when the reactivity worth of the blade is reduced by 10 percent, which corresponds to 42 percent  $B^{10}$  depletion averaged over the top quarter of the control blade. Because of the leaching mechanism, GE has reduced the allowance for  $B^{10}$  depletion averaged over

the top quarter of the control blade fr

The safety significance of boron loss i scram reactivity. Although shutdown ca

1504 167

DUPLICATE DOCUMENT

Entire document proviously entered into system under:

ANO 7910250475

o. of pages: