



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

Docket Nos. 50-352  
50-353


NOV 26 1973

Philadelphia Electric Company  
Attention: Mr. V. S. Boyer  
Vice President  
Engineering and Research  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Gentlemen:

The enclosed Circular No. 79-23 is forwarded to you for information. No written response is required. If you have any questions related to the subject, please contact this office.

Sincerely,

  
Boyce H. Grier  
Director

Enclosures:

1. IE Circular No. 79-23
2. List of Recently Issued IE Circulars

CONTACT: S. D. Ebnetter  
(215-337-5296)

049

Q 7912110 075

ENCLOSURE 1

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS: 6830  
Accessions No:  
7910250496

IE Circular No. 79-23  
Date: November 26, 1979  
Page 1 of 1

MOTOR STARTERS AND CONTACTORS FAILED TO OPERATE

Gould, Inc., Electrical Products Group, reported to the NRC on September 11, 1979 potential defects in certain NEMA size 3, Starters and Contactors. A possible binding or seizure of the carrier assembly, within the support plate of the stationary contact assembly, is caused by an undersized dimension of the support legs.

Starters and contactors with date code 7822 to 7935, model and serial numbers A10, A11, A12, A13, A14, A20, A21, A22, and P10 are involved. Faulty units were manufactured and distributed between June 1, 1978 and August 30, 1979. The attached listing of nuclear plants, which have received some of this motor control equipment, represents a preliminary check of shipment records. This listing, however, may not be complete.

Gould, Inc., will recall uninstalled items for retrofit and has retrofit kits available for field installation.

Based on the above, licensees are advised to verify all motor starter and contactor shipments received from Gould, Inc., between June 1, 1978 and August 30, 1979, and assure that applicable model and serial number components are corrected by retrofit and subsequent electrical operation tests.

No written response to this Circular is required.

If you desire additional information regarding this matter, contact the Director of the appropriate NRC Regional Office.

Attachment:  
Listing of Nuclear Plants

050

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO 7910250496

No. of pages: 4