

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C | 0 | F | S | V | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 2 | 0 | 4 | 5

CON'T  
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 7 | 7 | 1 | 1 | 0 | 9 | 7 | 9 | 8 | 1 | 2 | 0 | 6 | 7 | 9 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
02 | On November 9, 1979, with the reactor shutdown for scheduled maintenance, engineering  
03 | personnel observed that boiler feed snubber BFS-412 was inoperable. Since reactor  
04 | had been operated at power during the surveillance interval, this constitutes opera-  
05 | tion in a degraded mode of LCO 4.3.10 and is reportable per Fort St. Vrain Technical  
06 | Specification AC 7.5.2(b)2. No affect on public health and safety.  
07 |  
08 |

09 | SYSTEM CODE | Z | Z | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | S | U | P | O | R | T | 14 | COMP. SUBCODE | D | 15 | VALVE SUBCODE | Z | 16

10 | Empty hydraulic oil reservoir on ITT Grinnel boiler feed snubber BFS-412 rendered  
11 | the snubber inoperable. Oil reservoir was refilled and snubber returned to service.  
12 | Present surveillance interval is 124 days ± 25%. No change is required as a result  
13 | of this occurrence.  
14 |

15 | FACILITY STATUS | G | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Engineering Observation | 32

16 | ACTIVITY RELEASED | Z | 33 | CONTENT | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36

17 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

18 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | DESCRIPTION | N/A | 43

20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45

1542 156  
79121 20 341  
J. W. Gahm  
NRC USE ONLY  
785-2253