



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION IV  
611 RYAN PLAZA DRIVE, SUITE 1000  
ARLINGTON, TEXAS 76012

CENTRAL FILES  
PDR:HQ  
LPDR  
~~TIC~~  
NSIC

November 20, 1979

Docket Nos. 50-313  
50-368

Arkansas Power and Light Company  
ATTN: Mr. William Cavanaugh III  
Vice President of Generation  
and Construction  
P. O. Box 551  
Little Rock, Arkansas 72203

Gentlemen:

The enclosed IE Bulletin No. 79-26 is forwarded to you for information.  
No written response is required. If you desire additional information re-  
garding this matter, please contact this office.

Sincerely,

*K. V. Seyfrit*  
Karl V. Seyfrit  
Director

Enclosures:

1. IE Bulletin No. 79-26
2. List of Recently Issued  
IE Bulletins

cc: James P. O'Hanlon, Plant Manager  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

1540 336

Q 912120 550

IE Bulletin No. 79-26  
Date: November 20, 1979  
Page 1 of 4

BORON LOSS FROM BWR CONTROL BLADES

Description of Circumstances:

The General Electric Company (GE) has informed us of a failure mode for control blades which can cause a loss of boron poison material. Hot cell examinations of both foreign and domestic blades have revealed cracks near the upper end of stainless steel tubing and loss of boron from the tubes. The cracks and boron loss have so far been confined to locations in the poison tubes with more than 50 percent Boron-10 ( $B^{10}$ ) local depletion. Observed crack sizes range from a quarter to a half inch in length and from one to two mils in width.

GE has postulated that the cracking is due to stress corrosion induced by solidification of boron carbide ( $B_4C$ ) particles and swelling of the compacted  $B_4C$  as helium and lithium concentrations grow. Once primary coolant penetrates the cladding (i.e., the cracking has progressed through the cladding wall and the helium-lithium pressures are sufficient to open the crack), boron is leached out of the tube at locations with more than 50 percent  $B^{10}$  local depletion (local depletion is considered to be twice the average depletion). It was further found with similar cracking but with less than 50 percent local depletion of  $B^{10}$ , that leaching did not occur even though primary coolant had penetrated the cladding.

The cracking and boron loss shorten the design life of the control blade. According to the GE criteria the end of design life is reached when the reactivity worth of the blade is reduced by 10 percent, which corresponds to 42 percent  $B^{10}$  depletion averaged over the top quarter of the control blade. Because of the leaching mechanism, GE has reduced the allowance for  $B^{10}$  depletion averaged over the top quarter of the control blade from the 42 percent value to 34 percent.

The safety significance of boron loss is its impact on shutdown capability and scram reactivity. Although shutdown capability is demonstrated by shutdown margin tests after refueling, the calculated control blade worths used in the tests are based on the assumption that no boron loss has occurred. Reduction in scram reactivity due to boron loss could increase the severity of Critical Power Ratio (CPR) reductions during the plant transients and could increase the consequences of control rod drop accidents.

Because the locations of limiting Line Average Planar LHGR (APLHGR) are not in the region where monitoring is not affected by boron loss.

1540 337

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO

7910250475

No. of pages:

5