

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
NuScale Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, August 20, 2019

Work Order No.: NRC-0506

Pages 1-65

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

NUSCALE SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

TUESDAY

AUGUST 20, 2019

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B10, 11545 Rockville Pike, at 1:00 p.m., Walter
Kirchner and Ronald Ballinger, Co-Chairs, presiding.

COMMITTEE MEMBERS:

WALTER L. KIRCHNER, Co-Chair

RONALD G. BALLINGER, Co-Chair

JOSE MARCH-LEUBA, Member

PETER RICCARDELLA, Member*

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MICHAEL SNODDERLY

ALSO PRESENT:

BRUCE BAVOL, NRO

SARAH FIELDS, Public Participant*

NICHOLAS KLYMYSHYN, PNNL

LARRY LINIK, NuScale

BRETT MATTHEWS, Framatome

SCOTT MOORE, Executive Director, ACRS

MATTHEW PRESSON, NuScale

CHRIS VAN WERT, NRO

*Present via telephone

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Page

Opening Remarks

Walter Kirchner, ACRS 4

NuScale Topical Report, "NuScale
 Applicability of AREVA Method for Evaluation of Fuel
 Assembly Structural Response to Externally Applied
 Forces."

Matthew Presson, Brett Matthews, and Larry Linik,
 NuScale 7

Safety Evaluation of "NuScale
 Applicability of AREVA Method for Evaluation of Fuel
 Assembly Structural Response to Externally Applied
 Forces."

Bruce Bavol, Chris Van Wert, and Nicholas Klymyshyn
 NRO 41

Opportunity for Public Comment 62

Adjourn 65

P R O C E E D I N G S

(12:59 p.m.)

CO-CHAIR KIRCHNER: This meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, NuScale Subcommittee. I'm Walt Kirchner, chairman of the NuScale Subcommittee. I've succeeded Mike Corradini, who you remember fondly, I'm sure.

I want to interrupt myself here and just thank you, NuScale, for hosting our visit last month. That was very informative. So if you would, pass that on to your team.

Member Ron Ballinger will co-chair this meeting with me today. Members in attendance are Jose March-Leuba and our consultant, Stephen Schultz.

Mike Snodderly is the designated federal official for this meeting.

The subcommittee will review the staff's evaluation of NuScale Topical Report TR0716-50351, NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces.

Today we have members of the NRC staff and NuScale to brief the subcommittee.

The ACRS was established by statute and is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 governed by the Federal Advisory Committee Act, FACA.
2 The NRC implements FACA in accordance with its
3 regulations, found in Title 10 of the Code of Federal
4 Regulations, Part 7.

5 The committee can only speak to its
6 published letter reports. We hold meetings to gather
7 information and perform preparatory work that will
8 support our deliberations at a full committee meeting.
9 The rules for participation in all ACRS were announced
10 in the Federal Register on June 13, 2019.

11 The ACRS section of the U.S. NRC public
12 website provides our charter, by-laws, agendas, letter
13 reports, and full transcripts of all full and
14 subcommittee meetings, including slides presented
15 there. The meeting notice and agenda for this meeting
16 were posted there.

17 Portions of this meeting can be closed, as
18 needed, to protect proprietary information pursuant to
19 5 U.S.C. 552(b)(c)(4).

20 As stated in the Federal Register notice
21 and in the public meeting notice posted to the
22 website, members of the public who desire to provide
23 written or oral input to the subcommittee may do so
24 and should contact the designated federal official
25 five days prior to the meeting, as practicable. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have also set aside ten minutes for comments from
2 members of the public attending or listening to our
3 meetings. We have not received written comments or
4 requests for time to make oral statements for members
5 of the public regarding today's meeting.

6 A transcript of the meeting is being kept
7 and will be made available on the ACRS section of the
8 U.S. NRC public website.

9 We request that participants in this
10 meeting please use the microphones located throughout
11 the meeting room when addressing the subcommittee.
12 Participants should first identify themselves and
13 speak with enough volume and clarity so that they can
14 be readily heard.

15 A telephone bridge line has been
16 established for the public to listen to the meeting.
17 To minimize disturbances, the public line will be kept
18 in a listen-in-only mode. To avoid further
19 disturbance, I request that attendees put their
20 electronic devices, like cell phones, in the off or
21 noise-free mode.

22 We will now proceed with the meeting and
23 I'll call on Matthew Presson of NuScale to begin
24 today's presentations.

25 And before I ask you to start, Matthew, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 also have Pete Riccardella, the chairman of the full
2 committee on the line. And do we have any other
3 members present?

4 Hearing none, okay, Matthew, can I ask you
5 also to introduce those participants who are on the
6 call-in lines from NuScale and Framatome as well?

7 MR. PRESSON: Yes.

8 CO-CHAIR KIRCHNER: Thank you.

9 MR. PRESSON: I can definitely do that.
10 Thank you, Walt, and good afternoon.

11 I am Matthew Presson, the licensing
12 project manager for the NuScale AREVA Fuel Seismic
13 Applicability Topical Report. This report covers the
14 applicability of Framatome's methods for fuel located
15 in a NuScale power module and compares those against
16 the approved ANP-10337 Topical Report.

17 Next slide. Our presenters for today are
18 Larry Linik with NuScale Fuels Engineering and Brett
19 Matthews, the Framatome technical lead for the NuScale
20 Fuel Design Project. We also have listeners with
21 NuScale out in Corvallis and I believe some of the
22 Framatome participants as well.

23 CO-CHAIR KIRCHNER: Okay, if they join in,
24 then we will ask them to identify themselves.

25 Okay, thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRESSON: But the bulk of the
2 presentation will be provided by Brett.

3 CO-CHAIR KIRCHNER: Excellent, thank you.
4 Proceed.

5 MR. PRESSON: Yes, next slide. And here,
6 we will pass it over to Brett.

7 MR. MATTHEWS: Okay. Thank you, Matthew.
8 So to start the presentation, I will review the
9 agenda, what I'm going to go over. And the first
10 thing we'll get to is --

11 CO-CHAIR KIRCHNER: Brett, can you pull
12 that microphone just closer to you?

13 MR. MATTHEWS: Sure. Sure, is that
14 better? Okay.

15 So I'll start with an overview of ANP-
16 10337. So this is Framatome's topical defining the
17 methodology for our evaluation of the fuel response in
18 response to external excitations, external loads, such
19 as seismic LOCA events.

20 This was the subject. I want to remind
21 everyone this was a subject of an ACRS meeting I think
22 about a year and a half back, March 2018, if I'm not
23 mistaken. So we'll start with that overview and
24 refresh some of the content that we went over in that
25 last meeting. Specifically, I will address the scope

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the generic applicability of that topical and then
2 move into a design overview of the NuScale fuel
3 design. The trade name here that we will be using in
4 the presentation IS NuFuel-HTP2. This design overview
5 will highlight some of the key differences between the
6 NuScale fuel design and an existing 17 by 17 PWR fuel
7 design.

8 With those differences in mind, we'll talk
9 about the process to assess the applicability to
10 NuScale, and then I will jump to the relevant points
11 from that applicability review and discuss what we're
12 doing in response to those items, and then I'll wrap
13 up with some conclusions.

14 So next slide, please. So to start with
15 the overview of NAP-10337, the fundamental focus of
16 this methodology is the evaluation of the fuel safety
17 functionality in response to or during and post-
18 earthquake and pipe breaks. So unfortunately, we've
19 got a PDF here, so we're not seeing the animation that
20 I built in but I did have this cartoon, which is just
21 a nice visual for us to kind of center our discussion
22 around. There are some things that we can reflect
23 back on to this simple cartoon as we get into the
24 presentation.

25 What I'm showing here is actually a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 representation of a 7-fuel assembly row from the
2 NuScale reactor and the simulation, if we were able to
3 run it, would actually be the animation from an actual
4 simulation that we performed for the NuScale
5 certification.

6 So some things to point out. First of
7 all, I guess on this screen, they are showing up as
8 kind of a maroon, kind of smaller maroon rectangles.
9 You'll see that each fuel assembly in that row has
10 three of those. Those are representing the
11 intermediate spacer grids on the fuel. And in
12 animation, you'll see these things sway back and forth
13 and start to interact with each other.

14 These spacer grids -- the spacer grid, of
15 course, is a key component in the fuel assembly
16 design. One of its many functions is to transmit the
17 interactions between fuel assemblies and between the
18 fuel assembly and the baffle or the heavy reflector.

19 So all interaction -- the fuel assembly is
20 designed for all interactions to occur at those spacer
21 grid locations and that's a key component in this
22 methodology because we really want to focus in on the
23 magnitude of those impact loads and the ability of
24 that component to withstand those impact loads. So
25 that's the first thing that we look at.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The other thing that you would see, if you
2 can imagine the animation here, in response to the
3 seismic motion, you'll see the fuel assemblies begin
4 to kind of sway back and forth. And the deflection
5 shapes that those fuel assemblies take on is another
6 important piece that we extract from this analysis.

7 So in response to that motion, because a
8 seismic event is a relatively low frequency event, at
9 least relative to the natural frequencies of the fuel
10 assembly, you primarily see a response from the fuel
11 in the first mode. So you would see this C-shaped bow
12 kind of swaying back and forth and, eventually or
13 periodically, there may be interaction between the
14 fuel assemblies. And at those points of interactions,
15 you can have kind of a brief higher mode response from
16 the fuel assembly, as the fuel assembly kind of rings
17 in response to that.

18 CO-CHAIR BALLINGER: Correct if I'm
19 swaying or straying into proprietary but -- and I
20 meant to reconfirm this before the meeting, but the
21 distance between the spacer grids in this design, how
22 close are they to the distance between spacer grids in
23 the standard PWR AREVA design?

24 MR. MATTHEWS: I believe that spacing is
25 very similar, if not the same.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CO-CHAIR BALLINGER: I thought it was very
2 similar.

3 MR. MATTHEWS: Okay, yes. Yes.

4 CO-CHAIR BALLINGER: Yes, okay. Thanks.

5 MR. MATTHEWS: So in summary, what this
6 evaluation, at least the lateral portion of this, we
7 -- the big outcome of this -- these simulations that
8 we perform and the evaluation that we do is to
9 evaluate the impact loads at those grid locations and
10 then, also, look at the stresses in the fuel assembly
11 components as a result of those deflections.

12 Advance to slide 5, please. Back one,
13 slide 5.

14 Okay, I want to review the regulatory
15 criteria, the regulatory framework for this
16 methodology. So very briefly, the kind of structure
17 that we are operating within, there are a few sections
18 to -- from 10 CFR Part 50 that we should reference;
19 there's Appendix A, which of course gives us the
20 generic design criteria that we have to satisfy;
21 Appendix S, which addresses design for earthquakes,
22 safe-shutdown to earthquakes; and then Part 50.46,
23 which gives us the requirements that we have to
24 satisfy for pipe breaks and LOCA events.

25 The relevant regulatory guidance that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in play here is the Standard Review Plan, Chapter 4.2,
2 specifically Appendix A. That addresses the necessary
3 guidance for the evaluation of external loads for fuel
4 assembly response in response to external loads.

5 All of this regulatory framework, though,
6 for what we do basically boils down to three main
7 items that we are trying to check in this evaluation.
8 Number one is that we want to ensure that we maintain
9 a coolable geometry for the fuel assembly, as it's
10 interacting with its neighboring fuel assemblies.

11 We want to make sure that we maintain
12 control rod insertability so the control rod or the
13 guide tubes in the fuel assembly maintain an
14 insertable path.

15 And number three is maintaining fuel rod
16 integrity. And this is both the coolability issue, we
17 want to avoid fuel line fragmentation that could
18 create flow blockage, but we also want to protect the
19 structural integrity of that cladding to maintain that
20 barrier to fissile material.

21 So page 6, please. So continuing on with
22 our overview, this -- a big part of this methodology
23 is actually simulating this dynamic event, simulating
24 the fuel response to these external loads, and we do
25 this by inputting time history inputs at the core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 boundaries. These are applied as the source of
2 excitation. So the core boundaries that we're talking
3 about in this case would be the upper and lower core
4 plate between which the fuel is sandwiched in-between.
5 So the motion there is going to excite the fuel. And
6 also in the lateral model, the motion of the baffle
7 plates or the reflector, that movement can change
8 interaction with the fuel as well.

9 These time history inputs, this is really
10 a -- I say time history in quotes here but we're
11 really talking about the core motion history, as it
12 marches through time. That's what we input to this
13 model. Those inputs are derived from upstream models
14 of the reactor vessel internals. So you have to
15 realize that this analysis that we're doing on the
16 fuel, it's at the end of the line of a long stream of
17 analyses that is performed in evaluating the overall
18 plant response to a seismic event, starting with the
19 definition of the ground motion, the definition of the
20 soil structure interaction, and how that propagates to
21 the building. Eventually, this propagates down to the
22 center of the core and we're the last -- we're the
23 last analysis in that long line of events.

24 The other thing I want to share here, I've
25 got two schematics, a lateral schematic and a vertical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 schematic of the models that we use. A couple of
2 points I want to make here and our methodology, what's
3 defined in 10337, we separate out and we analyze
4 separately the response of the fuel in the three
5 independent directions. So X, Y, and Z are all
6 analyzed separately and then combined at the end for
7 a 3D combination of the fuel response.

8 But here, you can see a simple lateral
9 schematic and vertical schematic. But the other thing
10 I wanted to drive home with this graphic is that when
11 you pull the skin away and you look at the skeleton
12 underneath those models, it's a fairly simply
13 structural representation of the fuel. We're using
14 basic elements, beam elements, springs, dampers, and
15 gap elements to build these models.

16 So moving ahead to slide 7, so kind of
17 building on that thought that the fuel is represented
18 using simple and generic structural models, the models
19 themselves are, like I said, at a very high level.
20 They are simple generic models. What's really
21 important in this methodology is how we define the
22 model parameters that we use to perform those
23 simulations.

24 And the sources for defining these model
25 parameters comes from one of three places. Most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 parameters in the model are based directly on
2 information that we would pull from design documents
3 like engineering drawings, specifications. So these
4 are parameters like geometry, the OD and inner
5 diameter of the tubes, fuel rod cladding, guide tubes;
6 material properties like Young's modulus or the yield
7 strength, these are parameters that we can read
8 directly off of a drawing or a material spec and feed
9 directly into the model. That's where most of the
10 parameters come from.

11 There are some model parameters that we
12 can't read directly from a design document but these
13 are based specifically or they are based directly on
14 design-specific characterization testing. So an
15 example here would be like the stiffness of the
16 assembly, of the completed assembly, the lateral
17 stiffness, or the frequency of that assembly. That's
18 not something that is going to jump out at you from a
19 design document. But we can build a prototype of the
20 assembly. We can test it and we can interrogate it to
21 get that information.

22 I will note ANP-10337 defines a full
23 characterization protocol to get these parameters to
24 feed the models. That full characterization protocol
25 has been applied to NuScale. And I will make a note

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 here that NRC was able to observe some of that in an
2 audit and actually observed part of that NuScale
3 testing.

4 The third source of parameters are
5 parameters accounting for fluid effects, specifically
6 three fluid effects: added mass, the coupling mass
7 effect, and fluid damping. These three parameters are
8 unique in that they are defined independent of the
9 design in ANP-10337. And so I am foreshadowing a
10 little bit but this is something we are going to talk
11 about. Because they are defined independent of
12 design, that's something that we are going to have to
13 address in the applicability and I will get to that in
14 future slides.

15 But largely, the modeling is really
16 largely transparent to the fuel design. That's one of
17 the key takeaways from this is that it's really a
18 fairly simple -- what's at the core of this method is
19 a fairly simple and generic representation of the
20 fuel.

21 CO-CHAIR BALLINGER: Okay. I've got
22 probably a dumb question but you said that this
23 analysis is at the end point of an overall seismic
24 analysis.

25 Now in a standard PWR, the vessel is on a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concrete pedestal and it's tied directly to the base
2 mat and everything to the plant. In this case, it's
3 not true, right? Because now the vessel is sitting on
4 the bottom of the pool and the ground motion is
5 transmitted to the pool structure itself. And so
6 you're saying that difference between a standard PWR,
7 which is more like hard-wired to the structure and
8 this analysis has been accounted for in developing the
9 input spectrum, which might involve some tilt, some
10 moments and stuff like that, because the vessel is
11 sitting on the bottom of the pool.

12 MR. LINIK: Yes, that's correct.

13 CO-CHAIR BALLINGER: Okay.

14 MR. LINIK: It starts out with the
15 building seismic and they send the boundary conditions
16 from that to the supports of the module. Then they do
17 the module analysis, which gives us the core plate
18 time histories.

19 And so it's not resting on the base mat.
20 It's supported by corbels up, what, about two-thirds
21 of the way, halfway up?

22 CO-CHAIR BALLINGER: Yes.

23 MR. LINIK: And the bottom of the module
24 is constrained in the X-Y direction.

25 CO-CHAIR BALLINGER: Yes, but was there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 any difference between the resulting spectrum to the
2 fuel between what you had to do and a standard PWR?

3 MR. LINIK: I'll leave that to Brett.

4 MR. MATTHEWS: I would say in my
5 experience the spectra are a little unique. So the
6 process for how we go from the soil motion to the
7 core, the transfer of functions that are involved
8 there are unique for NuScale and that results in a
9 unique spectrum from what we would typically see in a
10 PWR.

11 CO-CHAIR KIRCHNER: But not market.

12 MR. LINIK: Not significantly different.
13 Actually, when we get to the closed session, I've got
14 an example of a spectra that I can share with you.

15 CO-CHAIR KIRCHNER: Okay.

16 MEMBER MARCH-LEUBA: Yes but so the
17 question, of course, is the staff's Safety Evaluation
18 Report is approving this methodology. And then if you
19 decide to build NuScale in Hawaii, you have a
20 different response than California. Right? And you
21 have to redo that part of the analysis. You need to
22 make an example for a particular location, right?

23 MR. LINIK: Yes, that's correct.

24 Okay.

25 MR. MATTHEWS: Slide 8. We're ready to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 move on.

2 So a comment about, since we're going to
3 talk about applicabilities in NuScale, I'll take a
4 moment here to talk about the original applicability
5 of the topical and how that was defined.

6 The Topical ANP-10337 was really created
7 with the intention of being generically applicable to
8 PWR designs. Really the reason why we felt confident
9 in doing that, there are a couple of things to point
10 out, relatively simple concepts. One is that PWR fuel
11 designs share the same basic construction. That's
12 allowing the same general type of representation. So
13 we don't care if -- we don't care about the
14 differences between -- I should say we don't have
15 specific models for 14 by 14 versus a 17 by 17. We do
16 care about the differences and those get translated
17 into the model. But at the end of the day, the
18 representation is the same, regardless of the details
19 of the structure.

20 The other thing is that the PWR operating
21 environments, they are all very similar, very similar
22 pressures, temperatures, flow rates. When we look at
23 the fleet of PWR reactors out there, there's not a
24 wide range of difference.

25 One criterion, however, is noted for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicability in this base method and that has to do
2 with how we represent the impact behavior of the
3 spacer grids. So if you recall back to that graphic,
4 the spacer grids are the main points of contact. So
5 modeling the nuance of how that impact load gets
6 transferred from one fuel assembly to another can
7 sometimes get kind of tricky, particularly when we
8 start to talk about the deformation behavior of the
9 spacer grid. There are going to be some
10 nonlinearities that make their way into that problem.

11 So --

12 MEMBER MARCH-LEUBA: What is special with
13 the NuFuel-HTP2 versus a 17 by 17? The same spacers,
14 same lattice?

15 MR. MATTHEWS: That is correct. It's
16 actually -- so we'll talk about that in an upcoming
17 slide. I think it's one of the next slides. But the
18 spacer grid that is being used for NuScale is actually
19 identical to -- actually, I have it on this slide
20 here, that NuScale uses the exact same spacer grid
21 that is demonstrated in the base topical.

22 So we'll talk about limitations and
23 conditions regarding spacer grid modeling and this
24 note regarding applicability but we're not doing, in
25 that regard in how we model the impact behavior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 between fuel assemblies, we're not doing anything
2 different for the NuScale application. And we can do
3 that because we haven't changed the hardware. It's
4 the exact same component.

5 MEMBER MARCH-LEUBA: Does the model
6 account for the formation of the grids if they
7 actually impact?

8 MR. MATTHEWS: It does account for some.
9 That's a detail that we can discuss later but there is
10 some accounting of deformation in there.

11 CO-CHAIR KIRCHNER: This may be something
12 for a close session but what about the difference with
13 your -- I'll try not to go too far -- with your baffle
14 arrangement versus that of a conventional PWR?
15 Because you have a -- I'm trying not to stray into
16 what might be proprietary. You have your reflector,
17 your heavy stainless steel reflector surrounding the
18 core versus baffle plates and a dead water zone in a
19 PWR.

20 So are there any significant tolerance or
21 other differences there in the mechanical design for
22 the NuScale core versus being the longer, taller core
23 of a PWR?

24 MR. MATTHEWS: So with respect to how we
25 model those boundaries, there is no difference between

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what we're doing for NuScale and what we do for a
2 10337 or the base topical. That is conservatively
3 modeled to be a rigid structure that doesn't have any
4 compliance. So in the way that we model it, we would
5 conservatively model it the same for NuScale or an
6 existing PWR.

7 CO-CHAIR KIRCHNER: Okay, so Framatome
8 would model it as a rigid boundary condition for a
9 conventional PWR and you are doing the same here for
10 the NuScale core.

11 MR. MATTHEWS: That is correct.

12 CO-CHAIR KIRCHNER: Thank you.

13 MR. MATTHEWS: So the last point here,
14 there are limitations with regards to applicability.
15 There are limitations and conditions that were imposed
16 through the SER. I'm actually going to go through
17 those on the next slide. We'll walk through those.

18 Slide 9, please. So RAI 9555 requested
19 that these L&Cs be addressed in applicability to
20 NuScale. So I'm paraphrasing these but I'll walk
21 through them very briefly.

22 The first L&C has to do with a
23 demonstration of critical grid behavior from dynamic
24 impact testing. So as I mentioned on the previous
25 slide, we're using the using the same exact hardware

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for the spacer grid. The behavior has not changed
2 from the base topical. So that is satisfied with the
3 use of the same hardware.

4 The same thing for item number two. Item
5 2 deals with limits on maximum allowable spacer grid
6 deformation. Again, we're not changing the hardware.
7 We're not changing the limits in the application for
8 NuScale.

9 Number 3 deals with or defines controls
10 and quality requirements on the engineering software
11 that we use to implement this methodology. Again,
12 there's no change for NuScale. We're using the same
13 engineering software that was certified with the base
14 topical.

15 MR. SCHULTZ: So a software associated
16 with the overall evaluation was not required to be
17 changed in order to implement the NuScale design and
18 the evaluation?

19 MR. MATTHEWS: No, the hard -- or the
20 software itself, no.

21 MR. SCHULTZ: All right.

22 MR. MATTHEWS: There are detail parameters
23 that we'll talk about where we're going to make some
24 adjustments but the software itself remains the same.

25 MR. SCHULTZ: Okay, thank you.

1 MR. MATTHEWS: Uh-huh.

2 So number 4, in the previous slide we
3 talked about our vision for generic applicability of
4 this and the NRC, when they reviewed the topical, they
5 caught this and said yes, we can accept that for the
6 operating fleet because the operating fleet that's out
7 there now is fairly well-defined but, looking forward
8 to tomorrow's reactor, we don't know that it's going
9 to fall in that same category.

10 So there's L&C number 4 that limits the
11 use of this method to applications consistent with the
12 operating fleet that was in place at the time that
13 this was approved. And this comes into play. This is
14 something that obviously raises a question for the
15 NuScale application, which we're talking about now.

16 L&C number 5 limits applicability of the
17 lateral damping values to existing fuel designs.
18 You'll recall in a previous slide I mentioned that
19 there are three parameters in the methodology
20 associated with fluid effects. Damping is one those
21 that is defined in the base topical independent of the
22 fuel design. And again, kind of the same thought that
23 you're comfortable with extending that to generic use
24 based on existing fuel designs and the existing fleet
25 that's out there but L&C number 5 limits that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicability to be reviewed for future designs.

2 So again, this is something we're going to
3 come back and address for NuScale.

4 So number 4 and 5, in particular, are the
5 two L&Cs that I want to pull out here and we can
6 reflect on later on when we get into the
7 applicability.

8 Number 6 requires a fuel rod stress
9 assessment under faulty conditions, which we do for
10 NuScale.

11 Number 7 requires the use of the most
12 limiting stress criteria when bounding analyses are
13 performed for rodded and non-rodded locations.
14 Basically, this says that we're going to verify
15 control rod insertability for those rodded locations,
16 which we do for NuScale.

17 Number 8 specifies that a 3D combination
18 of load should be considered for non-grid components,
19 which we do. We recombine the X, Y, and Z components
20 to derive a 3D stress state, accounting for all of the
21 deformation and impact loads in those directions.

22 And number 9 is another spacer grid
23 modeling limitation. It's a limitation on the
24 applicability of the spacer grid impact modeling
25 which, again, much like we said for numbers 1 and 2,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we're meeting that because we haven't changed the
2 hardware. We're using the same modeling, same
3 hardware as we use in the base topical.

4 All right, slide 10, please. So now I'd
5 like to shift gears and talk about what is unique in
6 the NuScale design. Again, the trade name here,
7 NuFuel-HTP2. So the NuFuel-HTP2 design is based on
8 Framatome's existing and proven U.S. 17 by 17 PWR
9 technology. It's a design that we have a lot of
10 operating experience behind.

11 And when you look at the graphic on the
12 right, it doesn't show up too clearly on this screen,
13 but one thing that I will note is that if you were to
14 be able to cut a cross-section of this assembly at any
15 location from the filter plate up to the top of the
16 hold-down spring, you're not going to be able to
17 distinguish this from Framatome's existing 17 by 17
18 PWR technology. The 2D design is exactly the same.
19 So the dimensions, the spacer grid features,
20 everything is exactly the same as the 17 by 17.

21 Obviously, where we're different is in the
22 axial layout. This design is a little more than half
23 the length of a standard or existing 17 by 17 design.
24 As a result of that, there are fewer spacer grids on
25 this design. You can see in this figure there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 five spacer grids in the fuel design. There are four
2 Zircaloy-4 HTP grids, one at the top most location and
3 then three intermediate locations. And then there is
4 an Inconel 718 lower spacer grid.

5 Now, I want to pause here and talk about
6 something in the modeling that we use in this
7 methodology. I don't know if you caught this but in
8 the cartoon that I showed on that first slide, you
9 only saw three spacer grids present. There are five
10 grids in the design. We only model three.

11 Those end grids, the upper most and the
12 lower most end grid in this methodology, because of
13 their proximity to the top nozzle and the bottom
14 nozzle, they get rolled into that boundary, that fixed
15 boundary condition. In reality, these spacer grids,
16 the way they end up getting modeled in our
17 methodology, there is a rotational degree of freedom
18 with some stiffness there at those spacer grid
19 locations. In reality, those end grids are so close
20 to the ends that there's not -- they're really not
21 contributing a lot to the dynamic response of the fuel
22 assembly.

23 MEMBER MARCH-LEUBA: How tightly are they
24 rolled so touch to the upper and lower plates? I mean
25 are they allowed to slide up and down on this stretch?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MATTHEWS: There is some sliding that
2 can occur between the fuel rods and the spacer grids.

3 MEMBER MARCH-LEUBA: It can and it does
4 over the cycle.

5 MR. MATTHEWS: Yes.

6 MEMBER MARCH-LEUBA: I mean they almost
7 are --

8 MR. MATTHEWS: And it can change. It will
9 evolve over the cycle. That is true.

10 MEMBER MARCH-LEUBA: So but that's a tight
11 -- it's more as a perfect coupling. There is no
12 rattle, no --

13 MR. MATTHEWS: That's correct. It's more
14 complicated than a tight -- yes, a tight coupling.

15 MEMBER MARCH-LEUBA: And this might be
16 sharpening the pencil too much but does the
17 temperature differences make a difference? Because
18 NuScale fuel runs a lot colder than Westinghouse but
19 the clad is hotter --

20 MR. MATTHEWS: Yes.

21 MEMBER MARCH-LEUBA: -- because of the low
22 heat transfer coefficient.

23 MR. MATTHEWS: Yes.

24 MEMBER MARCH-LEUBA: So you have a hot M5
25 and cold UO2. Does it make a difference?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MATTHEWS: Those temperature
2 differences do factor into our modeling when we're
3 setting material properties.

4 So we do account for those differences in
5 temperature directly.

6 MEMBER MARCH-LEUBA: Okay, thank you.

7 MR. SCHULTZ: Brett, you said that those
8 grids are close to the top and bottom nozzles. How
9 close, roughly? It looks like an inch.

10 MR. MATTHEWS: So I don't have the exact
11 number. Yes, and you're in the right order of
12 magnitude. I think the bottom spacer it's a little
13 more than an inch.

14 MR. SCHULTZ: Yes, right.

15 MR. MATTHEWS: And at the top to allow for
16 shoulder gaff, you've probably got two or three inches
17 between that top grid and the top nozzle.

18 MR. SCHULTZ: And analytical
19 demonstrations of them have shown that -- your
20 statement, they're unaffected. They unaffected the
21 overall response.

22 MR. MATTHEWS: That is correct, yes.

23 MR. SCHULTZ: It's been demonstrated by
24 NuScale and by NRC as well.

25 MR. MATTHEWS: That is correct. And I've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got some -- I'll probably address this again in the
2 closed session. I've got some more details as to what
3 we did to show that.

4 MR. SCHULTZ: Good. Thank you.

5 MR. MATTHEWS: Okay. So I think we can
6 move on to slide 11.

7 So continuing on with the comparison, this
8 is a table just comparing some key parameters between
9 the NuFuel-HTP2 design and the existing Framatome 17
10 by 17 design. It's a very boring table because, when
11 you go down through the columns, there is not a lot of
12 difference. Like I said on the previous slide, if you
13 were to take a cross-sectional slice through this,
14 you're not going to be able to tell one from the
15 other.

16 Where you do see differences in this table
17 or in the axial layout. So the overall fuel assembly
18 height, obviously, the NuFuel design, 94 inches versus
19 roughly 160 inches for the existing design. There is
20 a little bit of a difference in the grid span link.
21 So existing 17 by 17 product has a span length of
22 20.6. We're just a couple of percent off of that for
23 NuScale at 20.1, however, it is within the range of
24 grid span lengths that we evaluated and designed for
25 in other designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And that grid span length is fed directly
2 into the model as well. The spacing between the grids
3 is modeled directly.

4 And then obviously, with the reduction in
5 height of the fuel assembly, the total active fuel
6 stack is different as well.

7 But what I've highlighted here that I
8 really want to carry forward and talk about
9 applicability is the big difference here, which is the
10 reduction in height. And as we saw on the previous
11 slide, too, reduction in the number of spacer grids.

12 Moving ahead to slide 12, so when we look
13 at the operating environment for the fuel, we see more
14 differences here than what we see in terms of the fuel
15 that's operating in that environment. I will say most
16 of these parameters, are inconsequential. They don't
17 enter into the simulation that we're performing. So
18 for things like thermal power, that doesn't really
19 make its way into the representation of the fuel in
20 terms of its dynamic response.

21 We talked about the temperatures. And you
22 can see here that the NuScale, the core temperature is
23 a little bit lower than the operating environment for
24 an existing 17 by 17. That does get directly
25 represented in the model.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The big thing that jumps out at us,
2 though, the big thing that we need to carry forward
3 and talk about is the change in the coolant velocity
4 in the core. NuScale being a natural circulation
5 plant, much lower flow rates, 3.1 feet per second
6 versus 16 feet per second and, correspondingly, the
7 Reynolds number shows that difference as well.

8 Okay, so slide 13 --

9 CO-CHAIR BALLINGER: The linear heat rate,
10 that's average, right?

11 MR. MATTHEWS: Can we go back one slide?

12 CO-CHAIR BALLINGER: It can't be peak.

13 MR. LINIK: It's average.

14 CO-CHAIR BALLINGER: It's average.

15 MR. MATTHEWS: Yes, that is average.

16 CO-CHAIR BALLINGER: Thank you.

17 MR. MATTHEWS: So let me say a few words
18 about the process to assess applicability of this
19 topical to NuScale. So we started the process with a
20 review of the regulatory criteria for NuScale Fuel
21 Design. And this -- we're operating within the same
22 framework as the base topical, as existing PWRs, so,
23 10 CFR 50 Appendix A, Appendix S, 10 CFR 50.46. The
24 same regulatory guidance applies. So we're working in
25 the same design space here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The second step is to do what we just did,
2 which is a comparison of the parameters that are
3 important to the seismic LOCA response of the fuel.
4 Like I said, we just went through that exercise. The
5 big thing that jumps out at us that we need to address
6 applicability is the difference in fuel assembly link.
7 What does that mean for the continued validity and
8 application of the modeling that we define in 10337?
9 And along with that, the reduction in the number of
10 spacer grids, since we are reducing the number of
11 rotational degrees of freedom that we have in that
12 model. And then, finally, the coolant flow. It's a
13 different -- slightly different environment from what
14 we're currently operating in.

15 So with those differences in mind, we take
16 those forward into a detailed review of ANP-10337,
17 including the L&Cs, applying this filter of the
18 differences that we have between the two fuel designs.
19 And I have a note here that we literally structured
20 the applicability topical around this process. It's
21 literally structured around a chapter-by-chapter
22 review of ANP-10337.

23 So for this presentation, I'm not going to
24 go through that chapter-by-chapter review but I will
25 jump ahead on slide 14 and jump to the three main

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 points that we addressed in this review. So issue
2 number one, the big question that we have to answer or
3 that we do answer in this applicability topical is:
4 Does the model architecture and characterization
5 testing protocol from ANP-10337 adequately represent
6 the NuScale fuel design with its shorter length and
7 fewer spacer grids? And the answer that we arrive at
8 is yes, we can continue to do that and no
9 modifications are needed.

10 In short, again, we will get into the
11 details -- more details in the closed session but in
12 short, we are able to show that we're still able to
13 accurately capture the dynamic characterization of the
14 fuel, as shown in the testing. We're still able to
15 reproduce that in these models, at least for the
16 content that is important for what we're trying to
17 simulate.

18 So issue number 2 is that ANP-10337P-A
19 establishes lateral fuel assembly damping parameters.
20 The cooling flow rate is typical for existing PWRs.
21 Are these values valid in the NuScale design? No,
22 they're not.

23 We end up deriving NuScale-specific
24 damping values for this application that do not credit
25 the presence of flowing coolant. And what that does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for the definition of these design -- or the
2 definition of these parameters, it results in a lower
3 damping value, which is generally more conservative.
4 It's going to reflect less energy dissipation due to
5 this mechanism and generally going to lead to more
6 energy reflected in the impact loads between fuel
7 assemblies.

8 Issue number 3, RAI 9225 questions the
9 need for evaluation of the fuel during refueling,
10 specifically, while it is stored in the reactor flange
11 tool. When we look at this evaluation, we arrived at
12 the conclusion that we needed an explicit analysis to
13 look at the fuel response when it's in this condition.
14 So we add that analysis. It is above and beyond what
15 is defined in or implied with the use of ANP-10337 and
16 we discuss the continued applicability of ANP-10337
17 for that condition as well.

18 MEMBER MARCH-LEUBA: So specifically an
19 adjusted driving force or there is any chance -- is
20 just a driving force on the flanges or does that
21 change the input.

22 MR. MATTHEWS: So it is a different
23 driving force from what is in the ANP because there is
24 a separate analysis --

25 MEMBER MARCH-LEUBA: Different --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MATTHEWS: -- propagating that motion
2 through this tool. So, it is a unique set of input.

3 MEMBER MARCH-LEUBA: So you don't consider
4 an empty, partially-loaded fuel and then it could move
5 a lot more maybe?

6 MR. LINIK: No. In the closed session,
7 we'll have a graphic that displays how the fuel is
8 captured while it's in the RFT. We can discuss it
9 then.

10 MEMBER MARCH-LEUBA: Okay.

11 MR. MATTHEWS: Okay. So that brings me to
12 my conclusions.

13 So ANP-10337 defines a methodology that is
14 applicable to NuScale with two modifications. The
15 first is that we define a NuScale-specific damping
16 value, instead of using the blanket value from ANP-
17 10337. And we add an additional seismic evaluation in
18 which the core is residing in the reactor flange tool,
19 above and beyond what is implied with the ANP-10377.

20 CO-CHAIR KIRCHNER: Brett, does that -- is
21 that -- does that conclude your presentation?

22 MR. MATTHEWS: That concludes my --

23 CO-CHAIR KIRCHNER: Okay.

24 MR. SCHULTZ: Brett, just to revisit that
25 last conclusion point, the first one of them, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 damping values, you mentioned on the previous slide
2 that that pertains to the differences in load
3 characteristics.

4 MR. MATTHEWS: Right.

5 MR. SCHULTZ: I thought there was also
6 other testing that was done or other evaluation that
7 was done, mechanical testing evaluations, to get those
8 values, demonstrate those values for the NuScale fuel.

9 MR. MATTHEWS: That is correct.

10 MR. SCHULTZ: Okay.

11 MR. MATTHEWS: There is additional -- and
12 I can shed more light on that in the closed session.

13 MR. SCHULTZ: Right. But I just wanted to
14 get in this session that that testing and evaluation
15 has been done.

16 MR. MATTHEWS: Yes, that is correct.

17 MR. SCHULTZ: Okay, thank you.

18 MEMBER MARCH-LEUBA: This might show my
19 ignorance. Do you do any spent fuel evaluation, fuel
20 located in the spent fuel pool?

21 MR. LINIK: That's not done in the fuels
22 group analysis. The dose group analysis does analyze
23 the fuel in the spent fuel pool.

24 MEMBER MARCH-LEUBA: For seismic?

25 MR. LINIK: I believe so, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: And they use a
2 different tool?

3 MR. LINIK: I'm not familiar with that.
4 I haven't been part of that review.

5 MEMBER MARCH-LEUBA: It would make sense
6 to use the same tool but we'll ask the staff. Maybe
7 they know.

8 CO-CHAIR BALLINGER: This may be another
9 fine point for the closed session but the issue of
10 irradiation effects on the grids, the difference
11 between unirradiated and irradiated is the spring
12 relaxation that occurs in the grids. And so has that
13 spring relaxation itself been factored into the
14 seismic analysis?

15 MR. MATTHEWS: Yes.

16 CO-CHAIR BALLINGER: Okay, so you've
17 gotten that fine. Good. Thank you.

18 CO-CHAIR KIRCHNER: Brett, what about the
19 dimensional clearance between the outer rows, the fuel
20 assemblies, and the baffle or, in your case, that
21 would be then the reflector? Is that nominally the
22 same? Because it would seem to me that would factor
23 into any transfer of loads laterally and/or damping
24 calculations.

25 MR. MATTHEWS: So is your question is it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the same as existing --

2 CO-CHAIR BALLINGER: Yes, PWRs.

3 MR. MATTHEWS: Like we mentioned earlier,
4 I think those gap dimensions are very similar. I
5 don't have them off the top of my head but I believe
6 it's very similar to existing plants.

7 MR. LINIK: I don't know the number off
8 the top of my head either, but I would assume it's
9 probably different but not drastically so.

10 CO-CHAIR KIRCHNER: Okay. And you treat
11 then, that outer boundary condition as a rigid wall,
12 essentially, for any load transfer.

13 MR. LINIK: That is correct.

14 CO-CHAIR KIRCHNER: Any further questions?

15 Okay, with that, then -- yes, Pete, have
16 you --

17 MR. SNODDERLY: He has been un-muted and
18 I haven't seen an IM from him.

19 CO-CHAIR KIRCHNER: This is Pete
20 Riccardella.

21 MR. SNODDERLY: Yes, Pete, so you're
22 unmuted and I haven't seen an IM from you. So Walt is
23 asking if you have any questions. I don't hear him.

24 CO-CHAIR KIRCHNER: Okay. Well, he can
25 catch up with us after the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So with that, thank you very much and
2 we'll change out, take a -- not a break but just a
3 pause for a moment here and ask the staff to come
4 forward, please.

5 (Pause.)

6 CO-CHAIR KIRCHNER: Bruce, if you're
7 ready, please introduce yourself and your team.

8 MR. BAVOL: Okay. Good afternoon. My
9 name is Bruce Bavol. I am a project manager for the
10 NuScale design for the NRC. This is the portion where
11 the staff is going to be presenting their review of
12 TR-0716-50351, Revision 0.

13 Next slide, please. The NRC Technical
14 Review Team consists of Becky Karas, Branch Chief of
15 the Reactor Systems Branch. She is not here today.
16 To my left, Chris Van Wert was the primary reviewer
17 for this topical report and with the assistance of
18 Pacific Northwest Laboratories' Nicholas Klymyshyn.

19 Next slide, please. The staff review time
20 line, I provided a couple of bullets here, the first
21 bullet being the reference to the advanced copy of the
22 safety evaluation for this particular topical report.
23 I also provided the -A reference for the ANP-10337P-A.

24 The staff plans to brief the Advisory
25 Committee, full committee, on September 5th and issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 its final SER, if everything goes well, late October
2 2019, and then plans to publish the -A approved
3 version early in 2020.

4 MEMBER MARCH-LEUBA: We can sort of get
5 our plans to finish the whole NuScale SER in December
6 2019.

7 MR. BAVOL: Yes.

8 MEMBER MARCH-LEUBA: You want to publish
9 this afterwards?

10 MR. BAVOL: Well we figure with once the
11 Advisory Committee final full committee is complete,
12 that is just an administrative process for the safety
13 evaluation, where NuScale has an opportunity to
14 combine all the documents into a final --

15 MEMBER MARCH-LEUBA: So there is no issue
16 with timing there?

17 MR. BAVOL: There is no issue with timing.

18 MEMBER MARCH-LEUBA: Thank you.

19 MR. BAVOL: You're welcome.

20 Next slide, please. And with that, I'll
21 turn it over to Chris, where he'll go over the scope
22 of the staff review.

23 MR. VAN WERT: All right. Well, thank you
24 very much and good afternoon.

25 A lot of what you hear here is going to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 very similar to what you just heard but I wanted to
2 sort out by just kind of giving you an idea of the
3 scope of the staff's review and show you what's
4 included and what's not included within the review.

5 So what is included? The evaluation
6 includes the comparison of the NuScale design versus
7 the reference methodology, the ANP-10337 that you
8 heard about earlier. So we're looking at fuel design
9 changes. We're also looking at comparison of the
10 conditions limitations on the underlying methodology
11 in comparison with the NuScale design.

12 We also looked at some modifications that
13 were made to the reference methodology. What this
14 review does not include is the underlying methodology
15 itself but, also, the analysis based on this
16 methodology. That will be covered in the technical
17 report associated with Chapter 4 and you should be
18 hearing about that in October or -- Chapter 4 -- soon.
19 Within a couple months.

20 So the actual analysis with the results is
21 covered in the Chapter 4 review. Next slide.

22 So you already heard about it, so I'll try
23 to breeze through this a little bit quickly. But the
24 generic methodology covers things such as radiation
25 effects. It defines acceptance criteria. It talks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about horizontal and vertical dynamic loading. And it
2 looks at the evaluation of grid impact forces against
3 the allowable limits, amongst a few others there.

4 It also is demonstrating compliance with
5 GDC 2 and Appendix S. It does follow -- is consistent
6 with the guidance provided in SRP Section 4.2,
7 Appendix A. And it has nine conditions limitations
8 which are imposed on it in the staff's SE associated
9 with the approved version of the topical report.

10 Next slide. So, again, high level. The
11 NuFuel fuel design versus the standard Framatome 17 by
12 17 HTP design is very, very similar. They are all --
13 they're both using M5 fuel pins, Zirc-4 guide tubes,
14 HTP grids, HMP bottom grid. The two main differences
15 are length and then also the number of grids.

16 As you already saw, the grid span is
17 slightly different. I think the numbers were shown
18 so, at least I can say them, 206 versus 20.1 grid span
19 difference. Since it is slightly shorter, it goes to
20 the NuScale fuel assembly a little bit stiffer design.

21 Next slide. So there are a couple of
22 modifications, some of them being pretty obvious. The
23 first one is dealing with the shorter length and the
24 reduced number of grids. Because of that, the model
25 which is presented in the methodology topical report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had to be modified to represent NuScale. We looked at
2 that and determined that it was representative of the
3 NuScale fuel design and it was also consistent with
4 development of the model that is in the underlying
5 methodology. Therefore, the staff was fine with that.

6 We already discussed axial coolant flow
7 damping and that the --

8 CO-CHAIR KIRCHNER: Chris, can I interrupt
9 here?

10 MR. BAVOL: Yes, please.

11 CO-CHAIR KIRCHNER: I want to reflect back
12 on Steve Shultz's question. So basically when you say
13 the model was modified, you're talking about the input
14 deck that goes into the methodology but the actual
15 source code is not modified for the change in length.

16 MR. VAN WERT: Correct.

17 CO-CHAIR KIRCHNER: Do you see what I'm
18 saying?

19 MR. VAN WERT: Yes, kind of --

20 CO-CHAIR KIRCHNER: So the methodology is
21 generic enough --

22 MR. VAN WERT: Correct. Correct.

23 CO-CHAIR KIRCHNER: -- that you just
24 change input deck, essentially.

25 MR. VAN WERT: But if you look at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methodology, it does supply graphs of the models. If
2 you look at ANP-10337, you'll see and you can count
3 the number of grids. If you look at the NuScale one,
4 it obviously has fewer grids.

5 But you are correct.

6 CO-CHAIR KIRCHNER: All right.

7 MR. VAN WERT: It's the inputs in the
8 models there.

9 CO-CHAIR KIRCHNER: Thank you.

10 MR. VAN WERT: Uh-huh.

11 And talk a little bit about axial coolant
12 flow. Again, NuScale has a much lower flow rate. And
13 so that's conservatively just ignored for them. But
14 they do specific testing on the new fuel, fuel design,
15 as far as the pluck tests and whatnot that are
16 described in the methodology. They do those specific
17 to the NuScale fuel assembly design and get damping
18 values specific to them.

19 The staff reviewed that and audited the
20 testing and finds it acceptable.

21 Next slide. And the last one to discuss
22 is regarding the mode shapes and how they are used.

23 If you look at the underlying methodology,
24 it says that you must evaluate and characterize the
25 first five mode shapes for the fuel assembly. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 then it also states that it only uses the first three
2 within the model.

3 It was pointed out that for the NuScale
4 fuel assembly, it was just a little bit stiffer. The
5 way the testing would be performed, it was harder to
6 actually measure and characterize the higher mode
7 shapes. However, they could get the first three,
8 which are important for the modeling. Those are the
9 only three that were required by the methodology.

10 It was also noted that with the shift, due
11 to the stiffness and you compare to, which you'll
12 probably see in the closed session, if you compare it
13 to the amplitude of the different frequencies, it
14 pushed it in a region for modes 4 and 5 in an area
15 that's less important.

16 Staff -- well, PNNL in the confirmatory,
17 I can't take credit for it but PNNL confirmatory
18 analyses confirmed which modes were important for this
19 analysis. Therefore, the staff was fine with it.

20 MEMBER MARCH-LEUBA: You said a moment ago
21 that on the original LTR or SER, only three modes are
22 required, not five, but they choose to --

23 MR. VAN WERT: For the modeling, it's
24 three. For the characterization, it requires -- I
25 don't know if it requires or not but it says to look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at five.

2 MEMBER MARCH-LEUBA: Just curious. Where
3 the computing power has improved from a factor ten or
4 a hundred since the previous SER was issued, why not
5 go with five and don't have to think about it?

6 MR. VAN WERT: Well, if you look at the
7 importance of them, usually it's the first and third
8 there that have any impact on the results.

9 MEMBER MARCH-LEUBA: Why not do all five?
10 I mean I just --

11 MR. KLYMYSHYN: It's more of a testing.

12 MEMBER MARCH-LEUBA: Put your green light
13 on.

14 MR. KLYMYSHYN: Yes. Hi, it's more of a
15 testing issue that trying to characterize it with
16 fifth mode might have been impossible or difficult to
17 do or impossible.

18 MEMBER MARCH-LEUBA: Oh, you mean it's not
19 analytical but --

20 MR. KLYMYSHYN: It's not an analytical
21 issue. It's a mechanical testing issue.

22 MEMBER MARCH-LEUBA: Oh.

23 MR. KLYMYSHYN: The model is a finite
24 element model made of beams and beam elements, and
25 springs, and dampers, and that sort of thing. So the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 model has the capacity to behave in the fifth mode if
2 it actually occurs.

3 MEMBER MARCH-LEUBA: So in the computer,
4 you overstate the fifth mode.

5 MR. KLYMYSHYN: Correct, yes.

6 MEMBER MARCH-LEUBA: If you were, then it
7 soft.

8 MR. KLYMYSHYN: Yes.

9 MEMBER MARCH-LEUBA: It was only
10 experimental. You just can't flex it that way.

11 MR. KLYMYSHYN: Yes.

12 MEMBER MARCH-LEUBA: Only makes sense.
13 Make sure it won't do it there.

14 MR. KLYMYSHYN: Right.

15 MR. VAN WERT: Next slide. So then here
16 we've -- similar to what Brett just presented, we kind
17 of went one-by-one down through the nine limits --
18 limitations and conditions. And the staff you know
19 evaluated the disposition provided by NuScale.

20 So several of these refer to grid behavior
21 and you will get a similar disposition out of it in
22 that it's the same grids. So the first one and the
23 second one are both related to it, either grid
24 behavior or the deformation applicability limits. And
25 for both of those, it's the same grid and so it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicable.

2 For the third one, it's related to the
3 code that is used for the analysis. And NuScale uses
4 the same version of CASAC as the underlying
5 methodology. So, therefore, that condition is met.

6 Number four is related to that it is kind
7 of limited to the current fleet. And that was more or
8 less the purpose of the applicability topical report,
9 to address any of the differences and explain why it's
10 okay. So we reviewed their information. We also had
11 confirmatory -- independent confirmatory analyses and
12 we determined that it was acceptable.

13 We already talked a little bit about
14 damping. Again, they've provided NuScale-specific
15 tests and results. We reviewed that and we're fine
16 with that. And they also conservatively ignored any
17 flow damping credit.

18 MEMBER MARCH-LEUBA: Okay, so --

19 MR. VAN WERT: Yes.

20 MEMBER MARCH-LEUBA: -- which is it? You
21 make the flow zero or you measure damping and use it?

22 MR. VAN WERT: What was that?

23 MEMBER MARCH-LEUBA: I have two things.
24 That you ignore the flow effect on damping --

25 MR. VAN WERT: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: -- make it zero. And
2 then I hear something that they used NuScale-specific
3 damping.

4 MR. VAN WERT: Yes. So there's a couple
5 of different dampings. There's flow damping, which is
6 a credit that you can take but there's also damping
7 that you know you can think of damping in air. If you
8 pluck it in air or if you pluck it in water, you get
9 difference results.

10 So they do testing --

11 MEMBER MARCH-LEUBA: So they take credit
12 for the static water --

13 MR. VAN WERT: Yes.

14 MEMBER MARCH-LEUBA: -- damping but not
15 for the flowing water.

16 MR. VAN WERT: Correct. Anything you want
17 to add to that or is that --

18 MR. KLYMYSHYN: I think that's it. You
19 got it.

20 MR. VAN WERT: Okay, we can go to the next
21 slide.

22 So number 6 is related to fuel rod
23 evaluation and NuScale provides the evaluation, as
24 requested. Control rod locations, they used the
25 control rod location stress limits and, therefore,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that meets this limit as well.

2 3D loads, a lot of the limitations, I
3 should say, in our disposition are related to how they
4 implement it, which is kind of tied to the technical
5 report associated with Chapter 4 but we had both of
6 the documents in hand. So, we're seeing how they are
7 addressing it. So we are able to say that they meet
8 these conditions limitations, even though that review
9 is ongoing. I just want to be clear with that.

10 As far as the grid deformation model,
11 again, it's the same grid and the limit is not
12 exceeded.

13 Do you have questions on these? Okay. Go
14 on to the next one, then.

15 So in conclusions -- or in summary, we did
16 conclude that, after evaluating the differences, that
17 the NuScale fuel assembly meets the conditions
18 limitations associated with referenced methodology and
19 also that the modifications that were made are
20 appropriate for the NuScale fuel design.

21 And in summary, then, the staff finds that
22 the AREVA or Framatome methodology is acceptable for
23 use for NuScale, given the modifications as outlined
24 in their topical report.

25 Any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CO-CHAIR KIRCHNER: Thank you, Chris.

2 MR. VAN WERT: Thank you very much.

3 CO-CHAIR KIRCHNER: Ron, any questions,
4 further questions now?

5 CO-CHAIR BALLINGER: I'll wait until the
6 proprietary --

7 CO-CHAIR KIRCHNER: Okay.

8 CO-CHAIR BALLINGER: I'll wait until the
9 proprietary session.

10 CO-CHAIR KIRCHNER: Very good. Jose?

11 MEMBER MARCH-LEUBA: No, I have no further
12 questions.

13 CO-CHAIR KIRCHNER: Is Pete still there?
14 You can't tell? While we're waiting, Steve.

15 PARTICIPANT: Peter, are you still there?

16 MEMBER RICCARDELLA: I am here but I --

17 MEMBER MARCH-LEUBA: Everybody turn your
18 green lights off.

19 MEMBER RICCARDELLA: Can everybody hear
20 me?

21 PARTICIPANT: Yes, now we can.

22 MEMBER RICCARDELLA: Okay, I've been on
23 for both presentations. There's an echo. Okay?

24 I'm on. I've been listening to both
25 presentations and I have no comments. And I will dial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in for the closed portion of the meeting. I have the
2 slides.

3 CO-CHAIR KIRCHNER: Thank you, Pete.
4 Steve.

5 MR. SCHULTZ: Yes, here, Chris, I just
6 wanted to understand. The evaluations that were done
7 by the staff in terms of confirmatory analyses, was
8 that particularly focused on the limitation number 4
9 or were there other areas that you would consider? It
10 seemed in the safety evaluation there were two or
11 three different places where you talked about either
12 confirmatory analyses or audits that were performed by
13 the staff that NuScale had done.

14 MR. VAN WERT: So we did perform them for
15 a couple different reasons. One of them we didn't
16 present in here but it was alluded to in Brett's
17 presentation, in that the RFT location we did have one
18 specific confirmatory run that we had Nick do for
19 that.

20 But in general, we always -- not always
21 but we often do confirmatory runs to help just inform
22 our RAIs. Do you want to talk a little bit more about
23 like --

24 MR. KLYMYSHYN: Sure.

25 MR. VAN WERT: -- about the number and how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you did them?

2 MR. KLYMYSHYN: So Framatome uses the
3 CASAC code. It's a proprietary in-house bionomic
4 code. And PNNL, we used LS-DYNA, a general purpose
5 finite element code.

6 We essentially recreated their CASAC model
7 in LS-DYNA and ran a few cases just to make sure that
8 we got the same similar kind of results. And when we
9 see that in review, it helps deal with a lot of
10 questions or concerns just having PNNL do it, do our
11 own version of it. And when they line up very well,
12 that gives us a good feeling about how the other
13 pieces of the review are going.

14 So it kind of had a general purpose
15 analysis. We looked at the horizontal models and the
16 vertical model, and did a comparison to what Framatome
17 came up with, and we agreed fairly well.

18 MR. SCHULTZ: In the closed, there's going
19 to be some more detailed results presented. And when
20 we look at that, perhaps you can chime in as to what
21 your relative comparisons demonstrated there.

22 MR. VAN WERT: Okay.

23 MR. SCHULTZ: In other words, to give us
24 a better feel when you say close is close enough --

25 MR. VAN WERT: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SKILLMAN: -- what that really
2 means when we look at their detailed -- some of their
3 detailed calculations, not each and every one.

4 I appreciate that. Thank you.

5 MR. VAN WERT: Yes, and we'll talk about
6 it more later but, again, for I guess because we're in
7 open session, so people hear, we don't have slides
8 presenting our confirmatory runs against theirs for
9 the closed session here, since that's really tied more
10 to the tech report associated with Chapter 4, but we
11 are able to talk to it.

12 MR. SCHULTZ: Good. That's what I was
13 looking for. I wasn't looking for the detailed
14 comparisons but I also wanted to appreciate, if you
15 will, who did what. And we'll talk to NuScale and
16 AREVA about who did what there, too.

17 Thank you, sir.

18 MR. VAN WERT: Thank you.

19 MR. BAVOL: And real quick, this is Bruce.
20 I just wanted to mention that Chapter 4, Chris had
21 mentioned it just a moment ago, is due to the members
22 mid-November, tentatively scheduled now for Phase 4 in
23 November.

24 MEMBER MARCH-LEUBA: That will be the
25 final Chapter 4, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BAVOL: That will be the Phase 4 --
2 well, okay, yes. And the one we're going to have the
3 subsequent subcommittee --

4 MEMBER MARCH-LEUBA: I just came back from
5 vacation. We're still doing Phase 3, right?

6 MR. SNODDERLY: No, so we just completed
7 Phase -- this is Mike Snodderly --

8 MEMBER MARCH-LEUBA: Oh, Phase 4.

9 MR. SNODDERLY: We just completed Phase 3.
10 And we're just piloting now our Phase 4.5 review with
11 Chapter 17 and Matt Sunseri. And we'll discuss that
12 at the September full committee meeting.

13 But for Chapter 4, it will come in in
14 November. It will be given to Ron Ballinger. Ron
15 will review it and make a recommendation to the
16 committee about what, if any follow-up items that will
17 be briefed during one of the issue-specific meetings
18 that we plan to conduct in the April/May/June time
19 frame.

20 MEMBER MARCH-LEUBA: And we still have
21 plans to do a cross-chapter review by methodologies
22 instead of chapter-by-chapter, correct?

23 MR. SNODDERLY: Correct, that's the plan.

24 CO-CHAIR BALLINGER: I have a question
25 that I -- it just came up to my mind. Maybe it's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 closed session question. But whenever I hear somebody
2 say we ran the same model that they ran and we got
3 very similar results, I am immediately suspicious.

4 And so the question that I have is: How
5 much uncertainty is there? Is there pretty much good
6 overlap in the uncertainty? In other words, if you
7 deviate a little bit, does something weird happen so
8 that we have a fortuitous, if you want to look at it
9 that way, connection there that everything is fine,
10 when we don't really have a good connection?

11 MR. KLYMYSHYN: I'd say that in addition
12 to just trying to replicate their results, we also did
13 some limited sensitivity studies, changing damping
14 values to see how significant they were because the
15 damping is different in this case. And what we came
16 up with, it's very -- it doesn't have a lot of
17 consequence.

18 CO-CHAIR KIRCHNER: Actually, I can read
19 the words. I don't think these are proprietary. The
20 results are not unusually sensitive to the choice of
21 the damping value from the SER.

22 CO-CHAIR BALLINGER: Yes, but we're
23 talking about the applicability of the method, as
24 opposed to the results, right? So that was my
25 question related to -- so you were able to compare

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 your sensitivity results from Framatome's sensitivity
2 results?

3 MR. KLYMYSHYN: I think it just compared
4 to their final results.

5 CO-CHAIR BALLINGER: Okay.

6 MR. VAN WERT: And I think Brett can
7 probably speak to it a little bit more but, if you go
8 back to the underlying methodology, they covered their
9 entire PWR fleet. And so you can see a little bit how
10 sensitive or insensitive different parameters are,
11 based on the differences between the different plants.
12 NuScale is just one more step along that path.

13 And I will point to Brett to answer that
14 later.

15 CO-CHAIR BALLINGER: So you're
16 interpolating and you're not extrapolating.

17 MR. VAN WERT: Well I imagine, especially
18 for NuScale, their flow rate is going to be outside
19 the bounds of the operating fleet. The stiffness will
20 be more still than the others but that works in their
21 favor a little bit.

22 I'm trying to think of any other important
23 parameters, as far as whether or not its interpolated.

24 Temperatures within general parameters,
25 the grid is identical.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CO-CHAIR BALLINGER: Okay.

2 MR. VAN WERT: I think for the most part
3 -- you know I would say the stiffer assembly due to
4 the shortness and then also the flow rates are outside
5 of the normal bounds but they handled the -- the
6 stiffness gives it a little bit conservative. And
7 then the lack of use of flow damping conservatively
8 takes care of that issue.

9 CO-CHAIR BALLINGER: Now one last
10 question, at least for me. With respect to now
11 allowing -- not accounting for flow, that's a
12 conservative assumption. Do you know how much of a
13 conservative assumption that actually is?

14 MR. VAN WERT: It's not much.

15 CO-CHAIR BALLINGER: That's what I -- I
16 didn't think it was going to be a heck of a lot.

17 MR. VAN WERT: When you're looking at
18 three point -- no, no, it's not much. But instead of
19 them trying take credit for it and us trying to figure
20 out how certain do they know the values, they just --

21 CO-CHAIR BALLINGER: But it would be more
22 significant for a standard PWR or something like that.

23 MR. VAN WERT: Yes, if there was a reactor
24 coolant pump, it would be significant.

25 MR. SCHULTZ: And Nicholas, you said that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the confirmatory analysis you did was not CASAC. It
2 was a different method that was employed.

3 MR. KLYMYSHYN: Yes. Yes, we used the
4 commercial finite element software LS-DYNA.

5 MR. SCHULTZ: Thank you.

6 MEMBER MARCH-LEUBA: And speaking -- some
7 of this becomes important when uncertainties start to
8 pop up. And there may not be such a thing as a
9 typical safe-shutdown earthquake but for a typical
10 safe-shutdown earthquake, how much margin do you have
11 to limit? I mean are we this close to limiting in
12 which there are certain indicators or are we that
13 close to limiting? Or we can wait until --

14 MR. VAN WERT: Since that gets towards
15 numbers, that might be a better one for closed session
16 and that would give me time to look at the report.

17 MEMBER MARCH-LEUBA: But in their
18 position, you can see a lot or very little.

19 MR. KLYMYSHYN: There was a lot of margin.

20 MEMBER MARCH-LEUBA: That's a good answer.

21 MR. KLYMYSHYN: Okay.

22 MEMBER MARCH-LEUBA: But if you have so
23 much margin, then the uncertainty is -- don't really
24 make any sense.

25 CO-CHAIR KIRCHNER: Okay, let us turn to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 public comment.

2 Let me look in the audience. Anyone from
3 the public wish to make a comment? Seeing no one
4 present wishing to make a comment, we are going to
5 connect the bridge line.

6 MR. SNODDERLY: Is there anyone from the
7 public on the bridge line?

8 MS. FIELDS: Yes.

9 MR. SNODDERLY: Hello. Is that Sarah
10 Fields?

11 MS. FIELDS: Yes, it is.

12 MR. SNODDERLY: Okay. Does anyone on the
13 bridge line want to make a comment?

14 MS. FIELDS: Yes, I do. This is more a
15 generic comment on the whole retail application in NRC
16 and ACRS review process.

17 The design certification is built for a
18 cross-unit reactor that would produce 50 megawatts of
19 energy per unit, for a total of 600 megawatts energy.
20 However, from statements made by NuScale and the Utah
21 Associated Municipal Power System, or UAMPS, which is
22 the entity that is expected to submit, so a new
23 application using the NuScale. The intent is to
24 manufacture, construct, and operate a reactor with a
25 20 percent power uprate. Rather, it would be 60

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 megawatts of energy per unit, for a total of 720.

2 I don't know how this 20 percent power
3 uprate will -- would affect this current design and
4 how it would affect NRC staff and ACRS' review of that
5 design. But the clear intent is to have that 20
6 percent power uprate by the time that manufacturing
7 and construction, and operation.

8 NuScale and UAMPS have not been forthright
9 with respect to how they would obtain a 20 percent
10 power uprate, whether it would be to a NuScale
11 application for certification, amended application, or
12 whether it would be part of the COL application. My
13 understanding is the NRC has never approved a 20
14 percent power uprate at the initial COL stage.

15 But I just wanted to put that out there
16 because I'm concerned at the lack of forthrightness on
17 the part of NuScale and UAMPS as to how they would
18 obtain that power uprate and the fact that they
19 strictly, in a number of public statements, state that
20 it will be a 720-megawatt energy reactor.

21 Thank you.

22 CO-CHAIR KIRCHNER: Thank you for your
23 comment.

24 Bruce? All right, this is Bruce Bavol
25 from the NRO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BAVOL: Hi, Ms. Fields, this is Bruce
2 Bavol, project manager for the NRC. I'd like to
3 direct you to the public website. On September 25th,
4 there's going to be a public meeting scheduled that
5 will go over future plans for the increased power for
6 this design. So that might be a good starting place
7 for your question.

8 CO-CHAIR KIRCHNER: Bruce, one more time,
9 the date for that public hearing?

10 MR. BAVOL: That was September 25th of
11 this year.

12 CO-CHAIR KIRCHNER: September 25th. And
13 that would be here at the NRC.

14 MR. BAVOL: That's correct. It will be a
15 bridge line public meeting.

16 CO-CHAIR KIRCHNER: Thank you.

17 MS. FIELDS: And are there going to be any
18 public meetings in Utah?

19 MR. BAVOL: The public meeting bridge line
20 is really a kickoff for NuScale and the NRC to discuss
21 this power increase that you're talking about.

22 And everybody is welcome to join in. That
23 bridge line information is available on the NRC
24 website.

25 MS. FIELDS: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BAVOL: You're welcome.

2 CO-CHAIR KIRCHNER: Thank you for your
3 comment.

4 Any further comments from the public?

5 Hearing none, we will close the bridge
6 line and we will go to a closed session.

7 So we are going to take a break at this
8 point. And we have a new clock. We would like
9 everyone back at 2:30.

10 (Whereupon, the above-entitled matter went
11 off the record at 2:15 p.m.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

August 15, 2019

Docket No. PROJ0769

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Titled “ACRS NuScale Subcommittee Presentation: NuScale Topical Report, NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces,” PM-0819-66620, Revision 0

The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on reactor Safeguards (ACRS) NuScale Subcommittee Meeting open session on August 20, 2019. The materials support NuScale’s presentation of Topical Report, “NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces.”

The enclosure to this letter is the non proprietary version of the presentation titled “ACRS NuScale Subcommittee Presentation: NuScale Topical Report, NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces,” PM-0819-66620, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Matthew Presson at 541-452-7531 or at mpresson@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, OWFN-8H12
Samuel Lee, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Bruce Baval, NRC, OWFN-8H12

Enclosure: “ACRS NuScale Subcommittee Presentation: NuScale Topical Report, NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces,” PM-0819-66620, Revision 0

Enclosure:

“ACRS NuScale Subcommittee Presentation: NuScale Topical Report, NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces,”
PM-0819-66620, Revision 0

ACRS Subcommittee Presentation

NuScale Topical Report

NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces

OPEN SESSION

August 20, 2019



Presenters

Larry Linik
Fuels Engineer


Brett Matthews
Framatome Technical Lead for
NuScale Fuel Design Project

Agenda

- Overview of ANP-10337PA
- Scope of Generic Applicability of ANP-10337PA
- NuFuel-HTP2™ Design Overview
- Process to Assess Applicability to NuScale
- Relevant Points from NuScale Applicability Review
- Conclusions

Overview of ANP-10337PA

- Fundamental Focus: Evaluation of fuel safety functions during earthquakes and pipe breaks.



Note: Deflections from this simulation were amplified for this animation.

- Simulations evaluate impact loads at grid locations and stresses in fuel assembly components.

Overview of ANP-10337PA

Regulatory Criteria and Guidance

Regulatory Criteria (10 CFR)

- 10 CFR Part 50, Appendix A
- 10 CFR Part 50, Appendix S
- 10 CFR Part 50.46

Regulatory Guidance

- SRP 4.2, Appendix A




- 1) Coolable Geometry**
- 2) Control Rod Insertability**
- 3) Fuel Rod Integrity**


Overview of ANP-10337PA

- “Time History” inputs at the core boundaries are applied as sources of excitation
 - Derived from upstream models of reactor vessel internals

Lateral Schematic



Vertical Schematic



Overview of ANP-10337PA

- Fuel is represented using simple and generic structural models.
- Model parameters definition:
 - Most parameters are based directly on information from design documents (geometry, material properties, etc.)
 - Some model parameters are based on design-specific characterization testing
 - The full ANP-10337PA characterization protocol has been applied to NuScale
 - An NRC audit was performed during part of the NuScale testing
 - Parameters accounting for fluid effects (added mass, coupling mass, and fluid damping) are defined independent of design

➤ Modeling is Largely Transparent to Fuel Designs

Overview of ANP-10337PA

Original Applicability

- Intended to be generically applicable to PWR designs
 - PWR fuel designs share the same basic construction, thus allowing a simple, generic, structural representation
 - PWR operating environments are all very similar
- One criteria is noted for applicability
 - Verification of modeling assumption to represent the impact behavior of spacer grids
 - NuScale uses the exact same spacer grid demonstrated in the ANP-10337PA sample problem
- Limitations & Conditions were imposed through the SER and these will be reviewed later


Requests for Additional Information

- RAI 9555 requests that L&Cs from ANP-10337PA be addressed
- The SER for ANP-10337PA imposes nine L&Cs:
 - #1: Demonstration of critical grid behavior from dynamic impact testing.
 - #2: Limits on maximum allowable spacer grid deformation.
 - #3: Defines controls and quality requirements on engineering software used to implement ANP-10337PA.
 - #4: Limits use to applications consistent with operating fleet.
 - #5: Limits applicability of lateral damping values to existing fuel designs.
 - #6: Requires a fuel rod stress assessment under faulted conditions.
 - #7: Requires the use of most limiting stress criteria when bounding analyses are performed for rodded and non-rodded core locations.
 - #8: Specifies that a 3-D combination of loads should be considered for non-grid components.
 - #9: Limitation in applicability of spacer grid impact modeling.

NuFuel-HTP2™ Design Overview

- NuFuel-HTP2™ based on Framatome's proven US 17x17 PWR technology
- NuFuel-HTP2™ design features
 - Four Zircaloy-4 HTP™ upper and intermediate spacer grids
 - Inconel 718 HMP™ lower spacer grid
 - Mesh filter plate on bottom nozzle
 - Zircaloy-4 MONOBLOC™ guide tubes
 - Quick-disconnect top nozzle
 - Alloy M5® fuel rod cladding

>>Proven features with US Operating Experience



Design Comparison

NuFuel-HTP2™ vs Framatome 17x17

Parameter	NuFuel-HTP2™ Fuel Design	Framatome 17x17 PWR
Fuel rod array	17 x 17	17 x 17
Fuel rod pitch (inch)	0.496	0.496
Fuel assembly pitch (inch)	8.466	8.466
Fuel assembly height (inch)	94	160
Spacer grid span length (inch)	20.1	20.6
Number of guide tubes per bundle	24	24
Dashpot region ID (inch)	0.397	0.397
Dashpot region OD (inch)	0.482	0.482
ID above transition (inch)	0.450	0.450
OD above transition (inch)	0.482	0.482
Number of fuel rods per bundle	264	264
Cladding OD (inch)	0.374	0.374
Cladding ID (inch)	0.326	0.326
Length of total active fuel stack (inch)	78.74	144
Fuel pellet OD (inch)	0.3195	0.3195
Fuel pellet theoretical density (%)	96	96

Operating Parameter Comparison NuScale vs Framatome 17x17

Parameter	NuScale Design Value	Framatome 17x17 PWR Value
Rated Thermal Power (MWt)	160	3455
System Pressure (psia)	1850	2280
Core Inlet Temperature (F)	503	547
Core Tave (F)	547	584
Average Coolant Velocity (ft/s)	3.1	16
Core Average Re Number	76,000	468,000
Linear Heat Rate (kW/ft)	2.5	5.5
Fuel Assemblies in Core	37	193
Fuel Assembly Loading (KgU)	249	455
Core Loading (KgU)	9,213	87,815
Nominal Cycle Length (EFPD)	694	520
Maximum Fuel Assembly Discharge Burnup (GWd/mtU)	<50	>50

Process to Assess Applicability

- 1) Review regulatory criteria for NuScale fuel design
 - Same framework as ANP-10337PA
- 2) Comparison of parameters that are important to seismic/LOCA response (NuScale vs. Existing PWRs)
 - Fuel Assembly Length
 - Number of spacer grids
 - Coolant flow
- 3) Detailed review of ANP-10337PA content, including SER L&Cs, with consideration to differences

*The applicability topical is structured around a chapter-by-chapter review of ANP-10337PA

Relevant Points from the Review

Issue #1: Does the model architecture and characterization testing protocol from ANP-10337PA adequately represent the NuScale fuel design with shorter length and fewer spacer grids?

“Yes. No modifications are needed.”

Issue #2: ANP-10337PA establishes lateral fuel assembly damping parameters that credit flow rates typical for existing PWRs. Are these values valid in the NuScale design?

“No. NuScale-specific damping values are derived.”

Issue #3: RAI 9225 questions the need for evaluation of the fuel during refueling, specifically, while it is stored in the Reactor Flange Tool (RFT).

“An analysis is performed for the RFT using ANP-10337PA.”

Conclusions

ANP-10337PA defines a methodology that is applicable to NuScale with the following modifications:

- Fuel assembly damping values specific to the NuScale design
- An additional seismic evaluation in which the core is residing in the Reactor Flange Tool (RFT)

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804

Richland Office

1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Arlington Office

2300 Clarendon Blvd., Suite 1110
Arlington, VA 22201

London Office

1st Floor Portland House
Bressenden Place
London SW1E 5BH
United Kingdom
+44 (0) 2079 321700

<http://www.nuscalepower.com>

 [Twitter: @NuScale_Power](https://twitter.com/NuScale_Power)



Presentation to the ACRS Subcommittee
Staff Review of NuScale Topical Report

TR-0716-50351, REVISION 0

**“NUSCALE APPLICABILITY OF AREVA
METHOD FOR THE EVALUATION OF FUEL ASSEMBLY
STRUCTURAL RESPONSE TO EXTERNALLY APPLIED FORCES”**

Presenters:

Chris Van Wert – Senior Reactor Systems Engineer, Office of New Reactors
Bruce Bavol - Project Manager, Office of New Reactors

August 20, 2019
(Open Session)

NRC Technical Review Areas/Contributors

- REACTOR SYSTEMS NUCLEAR PERFORMANCE & CODE REVIEW BRANCH / NRO:
Rebecca Karas (BC)
- ADVANCED REACTOR TECHNICAL BRANCH / NRO:
Chris Van Wert
- Pacific Northwest National Laboratory (PNNL):
Nicholas Klymyshyn

Staff Review Timeline

TR-0716-50351, “NUSCALE APPLICABILITY OF AREVA METHOD FOR THE EVALUATION OF FUEL ASSEMBLY STRUCTURAL RESPONSE TO EXTERNALLY APPLIED FORCES”

- NuScale submitted Topical Report (TR)-0716-50351, “NuScale Applicability of AREVA Method for the Evaluation of Fuel Assembly Structural Response to Externally Applied Forces,” Revision 0, on September 30, 2016, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16274A469).
- NuScale submitted ANP-10337P-A, “PWR Fuel Assembly Structural Response to Externally Applied Dynamic Excitations,” Revision 0, on April 30, 2018 (ADAMS Accession No. ML18144A816)
- Staff plans to brief advisory committee on reactor safeguards (ACRS) full committee on September 5, 2019.
- Staff plans to issue its final SER in late October 2019.
- Staff plans to publish the “-A” (approved) version of the TR in early 2020.

Scope of the Staff Review

- The staff's review included:
 - Evaluation of the NuScale design versus the reference methodology topical report (ANP-10337P-A)
 - Comparison of the NuScale fuel assembly design versus the designs covered by the methodology
 - Evaluation of the limitations and conditions
 - Evaluation of modifications to the referenced methodology
- The staff's review did *not* include:
 - The underlying methodology (covered by topical report ANP-10337P-A)
 - The docketed analysis of the NuScale fuel assembly design (covered by technical report TR-0816-51127-P)

Summary of ANP-10337P-A, “PWR Fuel Assembly Structural Response to Externally Applied Dynamic Excitations”

- Presents a generic methodology to evaluate PWR assembly structural response to externally applied forces
 - Considers irradiation effects
 - Establishes protocol for benchmark testing
 - Defines acceptance criteria
 - Horizontal and vertical dynamic finite element models
 - Structural analysis of limiting 3D deflection
 - Evaluation of grid impact forces against allowable limits
- Used for demonstrating compliance with GDC 2 and 10 CFR Part 50 Appendix S
- Consistent with guidance provided in SRP Section 4.2 Appendix A
- Contains 9 conditions and limitations

NuScale Fuel Design

- Based on Framatome 17 by 17 HTP design
 - M5 fuel pin cladding
 - Zirc-4 guide tubes
 - HTP™ grids
 - HMP™ bottom grid
- Differences
 - ~1/2 length
 - Five grids (vs. seven)

Modifications to Methodology

- ANP-10337P-A fuel assembly model has been modified for the NuScale fuel assembly design
 - Shorter length
 - Fewer grids

The staff finds that the dimensional modifications to the model from ANP-10337P-A accurately represent the NuScale design and are consistent with the general methodology

- Axial coolant flow damping is ignored
 - ANP-10337 uses fixed generic damping values that credit axial flow damping and require justification on the basis of test data. NuScale modifies the methodology to propose a different set of damping values specific to the NuScale design and are justified with test data.

The staff finds that by providing test results on the NuScale fuel assembly, NuScale is following the methodology from ANP-10337P-A. Additionally, NuScale ignores any potential flow damping which the staff finds conservative and acceptable.

Modifications to Methodology

- Fuel assembly characterized for the first three mode shapes instead of five
 - The typical mechanical testing protocols defined in ANP-10337P-A were written for typical full length fuel, which would naturally have more relevant flexural mode shapes than a shorter assembly with fewer grid spacers.

The staff finds that the use of three mode shapes for NuScale to be acceptable based on the comparison of the primary mode shapes versus the fuel assembly motion spectrum. The staff also notes that while ANP-10337P-A requires the characterization of the first five mode shapes, only the first three are used in the model.

Limitations and Conditions

L&C #	Topic	Summary of Disposition
1	Grid Behavior	The NuScale grid design is exactly the same grid design used as an example in ANP-10337.
2	Grid Deformation Applicability Limits	The NuScale grid design is exactly the same grid design used as an example in ANP-10337.
3	CASAC	The NuScale evaluation is performed using a version of CASAC that is consistent with this L&C.
4	Current Fleet	The NuScale design is a significant change from the current fleet, but the technical information and analysis documented in reports and RAI responses, as well as PNNL independent confirmatory analysis, addresses all concerns.
5	Damping	NuScale proposed and justified specific horizontal damping values that differ from the generic damping values.

Limitations and Conditions

L&C #	Topic	Summary of Disposition
6	Fuel Rod Evaluation	NuScale performed fuel rod evaluation that meets this L&C.
7	Control Rod Locations	NuScale used the control rod location stress limits to meet this L&C.
8	3D Loads	NuScale performed 3D analysis of loads to meet this L&C.
9	Grid Deformation Model Limits	The NuScale grid design is exactly the same grid design used as an example in ANP-10337. The grid deformation limit on the impact model is not exceeded.

Staff SER Conclusions

- The staff concludes that the NuScale fuel assembly meets the conditions and limitations associated with the referenced methodology topical report ANP-10337P-A
- The staff concludes that the modifications to the approved methodology are appropriate for the NuScale design are acceptable
- The staff finds that the use of ANP-10337P-A is acceptable for NuScale given the modifications outlined in TR-0716-50351-P.

Questions?