

TELECOPY MESSAGE

72

TO: President & Chief Operating  
Chairman, SRC Officer  
Manager of Nuclear Operations

TO: Director of Regulatory Operation  
USNRC Region I  
531 Park Avenue  
King of Prussia, Pennsylvania 19406

DATE/TIME: October 5, 1979

DATE/TIME: October 5, 1979

FROM: James A. FitzPatrick Nuclear Power Plant  
P.O. Box 41  
Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE  
DOCKET NO. 50-333  
LICENSE NO. DPR-59  
ASSIGNED OR NO. 79-164  
LER NO. 79-071

EVENT DATE: Thursday, October 4, 1979

REPORT DATE: Friday, October 5, 1979

EVENT DESCRIPTION: Inoperable Pipe Support

The pipe support is on the return piping from the cross tie into the Reactor Building Closed Loop Cooling System. This support has no safety significance. If the support and piping failed under earth quake conditions, the ability to achieve cold shutdown is unimpaired.

COMPONENTS INVOLVED:

MIS-124 Emergency Service Water System

CAUSE AND REMEDIAL ACTION:

Pipe Stress Reanalysis shows one piping run inoperable. Manger will be repaired within seven (7) days required by the Show Cause Reprise.

FACILITY STATUS:


& THERMAL POWER 96%

Routine Startup \_\_\_\_\_  
Routine Shutdown \_\_\_\_\_  
Steady State Power X \_\_\_\_\_  
Load Change \_\_\_\_\_

Shutdown \_\_\_\_\_  
Refueling \_\_\_\_\_  
Other \_\_\_\_\_  
Not Applicable \_\_\_\_\_

A written follow-up report will be sent within two weeks.

POOR ORIGINAL

  
JOHN D. LEONARD, JR.  
RESIDENT MANAGER  
JAMES A. FITZPATRICK NUCLEAR PO.

1235 270

7910310/44