

CENTRAL FILES  
PDR:HQ  
LPDR  
PIC  
NSIC



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION IV  
611 RYAN PLAZA DRIVE, SUITE 1000  
ARLINGTON, TEXAS 76012

October 1, 1979

Docket No. 50-285

Omaha Public Power District  
ATTN: W. C. Jones, Division Manager -  
Production Operations  
1623 Harney Street  
Omaha, Nebraska 68102

Gentlemen:

The enclosed IE Information Notice provides information with regard to an analysis that identifies an event that could result in overpressurization of containment at a pressurized water reactor.

Sincerely,

*Karl V. Seyfrit*  
Karl V. Seyfrit  
Director

Enclosures:

- 1. Information Notice 79-24
- 2. List of IE Information Notices Issued in the Last Six Months

cc: S. C. Stevens, Manager  
Fort Calhoun Station  
Post Office Box 98  
Fort Calhoun, Nebraska 68102

1283 104

7911010 493

SSINS: 6870  
Accession No:  
7908220123

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D. C. 20555

IE Information Notice No. 79-24  
Date: October 1, 1979  
Page 1 of 1

OVERPRESSURIZATION OF CONTAINMENT OF A PWR PLANT AFTER A MAIN STEAM LINE BREAK

Virginia Electric and Power Co. submitted a report dated September 7, 1979, that identified a deficiency in the original analysis of containment pressurization as a result of a steam line break for North Anna Power Station, Units 3 and 4.

Stone and Webster Engineering Corporation performed a reanalysis of containment pressure following a main steam line break and determined that, if the auxiliary feedwater system continued to supply feedwater at runout conditions to the steam generator that had experienced the steam line break, containment design pressure would be exceeded in approximately 10 minutes. The long-term blowdown of the water supplied under runout conditions by the auxiliary feedwater system had not been considered in the earlier analysis. The corrective action is now under review by the owner, architect engineer, and NSSS supplier.

This IE Information Notice is provided as an early notification of a possibly significant matter that is still under review by the NRC staff. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If NRC evaluations so indicate, further licensee actions may be requested or required.

No written response to this Information Notice is required. If you have any questions regarding this matter please contact the Director of the appropriate NRC Regional Office.

DUPLICATE

. 1283 105

LISTING OF IE INFORMATION NOTICES  
ISSUED IN 1979

Information Notice No.	Subject	Date Issued	Issued To
79-10	Nonconforming Pipe Support Struts	4/16/79	All power reactor facilities with a Construction Permit (CP)
79-11	Lower Reactor Vessel Head Insulation Support Problem	5/7/79	All Holders of Reactor Operating Licenses (OLs) Construction Permits (CPs)
79-12	Attempted Damage to New Fuel Assemblies	5/11/79	All fuel facilities, research reactors, and power reactors with an Operating Licensee (OL) or a Construction Permit (CP)
79-13	Indication of Low Water Level in the Oyster Creek Reactor	5/29/79	All Holders of Operating License (OL) or Construction Permit (CP)
79-14	NRC Position of Electrical Cable Support Systems	6/11/79	All Power Reactor facilities with a Construction Permit (CP) and applicants
79-15	Deficient Procedures	6/7/79	All Holders of Reactor Operating Licenses (OLs) and Construction Permits (CPs)
79-16	Nuclear Incident at Three Mile Island	6/22/79	All Research Reactors and Test Reactors with Operating Licenses (OLs)
79-17	Source Holder Assembly Damage From Misfit Between Assembly and Reactor Upper Grid Plate	6/20/79	All Holders of Reactor Operating Licenses (OLs) and Construction Permits (CPs)

IE Information Notice No. 79-24  
October 1, 1979

79-18	Skylab Reentry	7/5/79	All holders of Reactor Operating Licenses (OLs)
79-19	Pipe Cracks in Stagnant Borated Water Systems at PWR Plants	7/17/79	All Holders of Reactor Operating Licenses (OLs) and Construction Permits (CPs)
79-20	NRC Enforcement Policy NRC Licensed Individuals	8/14/79	All Holders of Reactor Operating Licenses (OLs) and Construction Permits (CPs), Research Reactors, Test Reactors Licensees with Licensed Operators
79-21	Transportation and Commercial Burial of Radioactive Material	9/7/79	All power and research reactors with Operating License (OL)
79-22	Qualification of Control Systems	9/14/79	All power reactor facilities with an Operating Licenses (OL) and Construction Permits (CP)
79-23	Emergency Diesel Generator Lube Oil Coolers	9/26/79	All power reactor facilities with an Operating License (OL) or Construction Permit (CP)

Enclosure  
Page 2 of 2

1283 107