| | LICENSEE EVENT REPORT |
|---------------------|--|
| | CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) |
| 0 1 | N C B E P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58 |
| CON'T 0 1 7 8 | REPORT L 6 0 5 0 - 0 3 2 5 7 1 0 0 5 7 9 8 1 1 0 1 7 9 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 During normal operation, an attempt to start the Reactor Building Exhaust and Supply |
| 0 3 | fan "C" resulted in tripping the breaker from sub-station E-5 to MCC 1XG. This motor |
| 0 4 | control center supplies power to "A" SLC pump, which was declared inoperable. |
| 0 5 | [Technical Specification 3.1.5, 6.9.1.9b |
| 0 6 | |
| 0 7 | |
| 0 8 | 80 |
| 0 9 7 8 | SYSTEM CAUSE SUBCODE COMPONENT CODE SUBCODE SU |
| 10 | X 18 Z 19 Z 20 Z 20 O 0 0 0 0 N 23 Y 24 N 25 G 0 8 0 26 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 The breaker was reset and MCC 1XG was re-energized. The starting and running current for the fans were checked with no abnormalities noted. This is considered an isolated |
| | event and no further action is required. |
| 1 3 | |
| 114 | |
| 7 8 | FACILITY STATUS OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 0 9 8 29 NA A 44 45 46 80 |
| | ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 I 2 33 Z 34 NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 NA NA 80 |
| 1 7 7 8 | NUMBER TYPE DESCRIPTION (39) O O O O O O O O O O O O O O O O O O O |
| 19 | LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 7 42 NA 9 10 80 |
| 207 8 | PUBLICITY ISSUED DESCRIPTION (45) 7911 090 495 NRC USE ONLY 10 NAME OF PREPARER A. C. Tollison, Jr. PHONE: 919-457-9521 2 |