

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 0 | H | D | B | S | 1 | 2 | 0 | 0 | - | 0 | 0 | N | P | F | - | 0 | 3 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | - | 0 | 3 | 4 | 6 | 7 | 1 | 0 | 0 | 1 | 7 | 8 | 8 | 1 | 0 | 2 | 7 | 7 | 8 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | At 0625 hours on 10/1/78, during performance of surveillance testing, the calculated
0 3 | value for unidentified Reactor Coolant System (RCS) leakage exceeded the 1 GPM limit
0 4 | by 0.08 GPM. This placed the unit in the Action Statement of Technical Specification
0 5 | (T.S.) 3.4.6.2. At 0730 hours on 10/1/78, the increased leakage was identified by a
0 6 | measurement of the Reactor Coolant Pumps standpipe leak-off. This reduced the uniden-
0 7 | tified leakage to 0.54 GPM, and removed the unit from the Action Statement of T.S.
0 8 | 3.4.6.2. The small leakages were processed through the normal containment sump.

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO. | ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | Increased Reactor Coolant Pump seal leakage is the cause of this occurrence. Investi-
1 1 | gation into the possibility of installing more accurate seal leakage indication is
1 2 | continuing per Facility Change Request 78-357.
1 3 |
1 4 |

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION | LOCATION OF RELEASE | ACTIVITY RELEASED | AMOUNT OF ACTIVITY | PERSONNEL EXPOSURES | PERSONNEL INJURIES | LOSS OF OR DAMAGE TO FACILITY | PUBLICITY ISSUED