



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

January 17, 1979

1-019-9

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Reportable Occurrence Report
Number 50-313/78-32
(File: 0520)

Gentlemen:

In accordance with Arkansas Nuclear One-Unit 1 Technical Specification 6.12.3.1, we have attached the subject report concerning the violation of Reactor integrity by opening the outer door of the Emergency Escape Hatch while the inner door was open. This report is being submitted within 30 days of the occurrence because it was only recently reclassified to a 14 day report as discussed with the site inspector.

Very truly yours,

Daniel H. Williams
Manager, Licensing

DHW:REI:ce
Attachment

cc: ✓ Mr. John G. Davis, Acting Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Norman M. Haller, Director
Office of Management Information
& Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

790124 0197

S A002 5/1