



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D.C. 20555

DISTRIBUTION:
 Docket
~~XXXX~~
 RIngram
 ORB#4 Rdg.

Docket No. 50-289

Docketing and Service Section
 Office of the Secretary of the Commission

SUBJECT: METROPOLITAN EDISON COMPANY

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s); Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s). Amdt. No. 24
- Other: Referenced documents have been provided PDR.

Division of Operating Reactors, ORB#4
 Office of Nuclear Reactor Regulation

Enclosure:
 As Stated

1452 250-2

OFFICE →	ORB#4:DOR					
SURNAME →	RIngram:dn			7910220	553	
DATE →	3/7/77					P

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-289

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 24 to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power and Light Company and Pennsylvania Electric Company (the licensees), which revised Technical Specifications for operation of the Three Mile Island Nuclear Station, Unit No. 1 (the facility) located in Dauphin County, Pennsylvania. The amendment is effective as of its date of issuance.

This amendment changes the provisions of the Technical Specifications relating to the method for checking radiation monitors and the interval between calibrations for certain radiation monitors.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

1452 251


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated December 12, 1975, (2) Amendment No. 24 to License No. DPR-50, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Government Publications Section, State Library of Pennsylvania, Box 1601 (Education Building), Harrisburg, Pennsylvania.

A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 3rd day of March 1977.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

1452 252