

METROPOLITAN EDISON COMPANYJERSEY CENTRAL POWER & LIGHT COMPANYPENNSYLVANIA ELECTRIC COMPANYNOTICE OF PROPOSED ISSUANCE OF AMENDMENT  
TO FACILITY OPERATING LICENSE

POOR ORIGINAL

The Nuclear Regulatory Commission (the Commission) is considering the issuance of an amendment to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power & Light Company & Pennsylvania Electric Company for operation of Three Mile Island Nuclear Station, Unit No. 1 (the facility), located in Dauphin County, Pennsylvania.

The amendment would result in a less restrictive variable low pressure trip setpoint of the Reactor Protective System for the condition of four reactor coolant pumps operating. This change results from the elimination of the reactor internals vent valve flow penalty which the Commission has determined to be no longer required.

Prior to issuance of the proposed license amendment, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

By Sept. 7, 1976, the licensees may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendment to the subject facility operating license. Petitions for leave to intervene must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene

7910220 575  
1452 291

must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action. Such petitions must be filed in accordance with the provisions of this FEDERAL REGISTER Notice and Section 2.714, and must be filed with the Secretary of the Commission, U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555 and G. F. Trowbridge, Esquire, Shaw, Pittman, Potts & Trowbridge, 1800 M Street, N. W., Washington, D.C. 20036, the attorney for the licensees.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or licensing board designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate order issued regarding the disposition of the petitions.


1452 292

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendment dated July 7, 1976, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Government Publications Section, State Library of Pennsylvania, Box 1610, (Education Building), Harrisburg, Pennsylvania.

Dated at Bethesda, Maryland, this 23rd day of July 1976

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

POOR ORIGINAL

1452 293