

MEETING SUMMARY

Licensee: Omaha Public Power District (OPPD)

Facility: Fort Calhoun, Unit No. 1

Summary of Meeting: Held on October 23, 1979 to discuss proposal for feedwater nozzle inspection.

Representatives of OPPD and W met with the staff to discuss OPPD's proposal for feedwater nozzle inspection from the hot shutdown condition. Attendees are listed in Attachment 1.

The licensee discussed the testing which has been performed in support of the subject proposal. The tests in general included:


1. A feasibility test using cracked samples.
2. A cold simulation at a mockup.
3. A hot simulation at a mockup.

The licensee and W representatives described the test as being a qualitative technique which could detect cracking greater than 1/16 inch depth. Because of calibration inaccuracies at the hot shutdown temperatures, actual UT indications evaluation was stated to not be practical at this time.

The licensee stated that their plan was to shut down 10/26 and conduct UT in hot shutdown. The licensee committed that:

1. If indications are found, evaluations will be performed at cold shutdown in accordance with bulletin 79-13 provisions.
2. The hot examinations will be performed by an operator qualified equally to the operator who performed the demonstration.
3. The examinations will include safe-end to nozzle and safe-end to pipe welds on both main feedwater nozzles.
4. If no indications are found the full inspection will be performed at cold shutdown in January 1980 refueling.

A subsequent telecon on October 25, 1979 with Mr. Morris of OPPD identified a change in shutdown schedule to October 31, 1979, which is within the original commitment.


Edward L. Jordan, Assistant Director
for Technical Programs, ROI, IE

Enclosure: Attachment 1

cc: N. C. Moseley V. S. Noonan
W. J. Collins R. A. Hermann
A. Schwencer W. S. Hazelton
P. Erickson

1294 ⁰⁴⁴ ~~045~~

7911080013

Attachment 1

MEETING ATTENDEES - OCTOBER 23, 1979 FORT CALHOUN FEEDWATER
NOZZLE INSPECTION PLANS

- | | |
|------------------|---|
| 1. E. L. Jordan | NRC:IE:HQ |
| 2. R. C. Kellogg | OPPD |
| 3. K. J. Morris | OPPD |
| 4. E. R. Pade | Westinghouse - Nuclear Technology
Division |
| 5. R. A. Hermann | NRC:DOR:EB |
| 6. E. L. Conner | NRR:OOR:ORB-4 |

1294 ⁰⁴⁵~~046~~

Meeting Summary for Fort Calhoun

Docket Files
NRC PDR
✓ Local PDR
ORBI Reading
NRR Reading
H. Denton
E. Case
D. Eisenhut
G. Zech
B. Grimes
W. Gammill
L. Shao
J. Miller
R. Vollmer
T. J. Carter
A. Schwencer
J. Ziemann
P. Check
G. Lainas
D. Davis
T. Ippolito
R. Reid
V. Noonan
D. Crutchfield
G. Knighton
D. Brinkman
Project Manager
ELD
N. Moseley
RIV: G. Madsen
 T. Westerman
C. Parrish/P. Kreutzer
ACRS (16)
NRC Participants
J. Buchanan
TERA
Licensee
Short Service List

1294 046
~~044~~

