



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Dockets Nos. 50-269/270/287

September 10, 1976



Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President
Steam Production
Post Office Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

The Commission has issued the enclosed Amendment No. 32 to License No. DPR-38; Amendment No. 32 to License No. DPR-47 and Amendment No. 29 to License No. DPR-55 for the Oconee Nuclear Station, Units Nos, 1, 2 and 3. The amendments consist of changes to the Technical Specifications and are in response to your application dated August 20, 1976.

The amendments require that spent fuel assemblies stored in designated areas of the Oconee spent fuel pools be decayed a minimum of 43 days prior to spent fuel cask movement.

Copies of the Safety Evaluation, Environmental Impact Appraisal and the Federal Register Notice are also enclosed.

Sincerely,

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:

1. Amendment No. 32 to DPR-38
2. Amendment No. 32 to DPR-47
3. Amendment No. 29 to DPR-55
4. Safety Evaluation and Environmental Impact Appraisal
5. Federal Register Notice

cc w/enclosures:
See next page

1336 001

Duke Power Company

- 2 -

September 10, 1976

cc: Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. Troy B. Conner
Conner & Knotts
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691

Honorable Reese A. Hubbard
County Supervisor of Oconee County
Walhalla, South Carolina 29621

Office of Intergovernmental
Relations
116 West Jones Street
Raleigh, North Carolina 27603

1336 002