

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 + Area Code 517 788-0550

December 14, 1979

Mr James G Keppler Office of Inspection and Enforcement Region III US Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

DOCKET 50-255 - LICENSE DPR-20 -PALISADES PLANT - SPECIAL NONRADIO-ACTIVE ENVIRONMENTAL MONITORING REPORT

Attached is an NPDES Noncompliance Notification issued by Consumers Power Company on December 5, 1979. It is being submitted to you in accordance with Technical Specification 6.9.3.1.D.

David P Hoffman (Signed)

David P Hoffman Nuclear Licensing Administrator

NPDES Noncompliance Notification (3 pages attached)

CC: Director, Office of Nuclear Reactor Regulation Director, Office of Inspection and Enforcement

C003 5 111 DU0508 1600 160

GOPY

File No P10.2.1 Incident No PAL-79-10-NC34

NPDES NONCOMPLIANCE NOTIFICATION Possible Noncompliance With Daily Average/Maximum Limitation December 5, 1979

Plant: Palisades	Permit No MI-0001457
Outfall @escription: Turbine Sump Oil Separator	Outfall No 800218
Parameter: Oil/Grease	Parameter No 00556
1. Date of Incident: 10-31-79	

2. Identification of specific effluent limitation exceeded:

Monthly average limitation of 15 mg/l for oil and grease.

3. Description of Incident:

For the month of October, five samples were collected with a daily average of 21.9 mg/l.

4. Apparent Cause:

The problem was apparently caused by a failure of the oil separator or improper operation.

5. If not immediately corrected, the anticipated time the condition is expected to continue:

NA

 Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:

The separator was restored to proper operation and subsequent analysis shows results in the 1-10 mg/l range after 11/1/79.

7. Additional Comments:

NA

8. Signed: R L Fobes Rould & Foles

1608 170

7912180592

File No P10.2.1 Incident No PAL-79-10-NC33

NPDES NONCOMPLIANCE NOTIFICATION Possible Noncompliance With Daily Average/Maximum Limi: tion December 5, 1979

Plant: Palisades		Permit No MI-0001457
Outfall Description:	Turbine Sump Oil Separator	Outfall No 800218
Parameter: Oil/Grea	se	Parameter No 00556

- 1. Date of Incident: 10-15, 23, 29-79
- 2. Identification of specific effluent limitation exceeded:

Daily maximum limitation of 20 mg/l for oil and grease.

3. Description of Incident:

Date	Oil/Grease (Mg/1)	Volume (Gallons)
10/15/79	41	9,000
10/23/79	29	5,000
10/29/79	24.1	3,000

4. Apparent Cause:

The problem was apparently caused by failure of the oil separator or improper operation.

If not immediately corrected, the anticipated time the condition is expected to continue:

NA

 Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:

The separator was restored to proper operation and subsequent analysis shows results in the 1-10 mg/l range after 11/1/79.

7. Additional Comments:

NA

8. Signed: R L Fobes Romald Z Fotes

POOR ORIGINAL

1608 171

7912180598

File No P10.2.1 Incident No PAL-79-10-NC32

NPDES NONCOMPLIANCE NOTIFICATION Possible Noncompliance With Daily Average/Maximum Limitation December 5, 1979

Plant:PalisadesPermit No MI-0001457Outfall Description:Laundry Wastes Prior to DilutionOutfall No 800174Parameter:Phosphorus - TotalParameter No 00665

- 1. Date of Incident: 10-20-79
- 2. Identification of specific effluent limitation exceeded:,

Daily maximum total phosphorus limitation of 2.0 mg/l.

3. Description of Incident:

On 10/20/79 a total of 5,000 gallons of laundry water with a total phosphorus concentration of 2.58 mg/l was released.

4. Apparent Cause:

A change in the type and quantity of detergent used occurred at this time.

If not immediately corrected, the anticipated time the condition is expected to continue:

NA

 Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:

Adjustments were made in the quantity of soap used. A possible problem with the testing reagents is also being evaluated.

7. Additional Comments:

NA

8. Signed: R L Fobes Rorald Z Fobes

1608 172

7912180605