



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

Docket Nos. 50-317  
50-318

DEC 06 1979


Baltimore Gas and Electric Company  
ATTN: Mr. A. E. Lundvall, Jr.  
Vice President, Supply  
P. O. Box 1475  
Baltimore, Maryland 21203

Gentlemen:

The enclosed Information Notice provides information with regard to reporting of defects and noncompliance, in accordance with Part 21 of Title 10, Chapter 1, Code of Federal Regulations.

This Information Notice is provided as notification of a significant matter. Although no specific action or response is requested, it is expected that recipients will review the information for possible applicability. If you have questions regarding this matter, please contact this office.

Sincerely,

  
for Boyce H. Grier  
Director

Enclosures:

1. IE Information Notice No. 79-30
2. List of Recently Issued IE Information Notices

CONTACT: S. D. Ebnetter  
(215-337-5283)

cc w/encs:

R. M. Douglass, Manager, Quality Assurance  
L. B. Russell, Chief Engineer  
W. Gibson, General Supervisor, Operational QA  
R. C. L. Olson, Senior Engineer  
K. H. Sebra, Principal Engineer

1662 302

7912810 205

Q

ENCLOSURE 1

SSINS: 6870

Accession No: 7910250502

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

DUPLICATE

IE Information Notice No. 79-30

Date: December 6, 1979

Page 1 of 2

REPORTING OF DEFECTS AND NONCOMPLIANCES, 10 CFR PART 21

Background

Section 21.1, Title 10, Code of Federal Regulations, Chapter 1, Part 21, states, "The regulations in this part establish procedures and requirements for implementation of Section 206 of the Energy Reorganization Act of 1974. That Section requires any individual director or responsible officer of a firm constructing, owning, operating or supplying the components of any facility or activity which is licensed or otherwise regulated pursuant to the Atomic Energy Act of 1954, as amended, or the Energy Reorganization Act of 1974, who obtains information reasonably indicating: (a) that the facility, activity or basic component supplied to such facility or activity fails to comply with the Atomic Energy Act of 1954, as amended, or any applicable rule, regulation, order, or license of the Commission relating to substantial safety hazards or (b) that the facility, activity, or basic component supplied to such facility or activity contains defects which could create a substantial safety hazard, to immediately notify the Commission of such failure to comply or such defect, unless he has actual knowledge that the Commission has been adequately informed of such defect or failure to comply."

Discussion

Recent inspections performed by NRC Office of Inspection and Enforcement personnel reveal a general misunderstanding of 10 CFR Part 21 requirements in cases where a licensee or nonlicensee has selected to rely on other reporting requirements such as 50.55(e) and Regulatory Guide 1.16 as the means to adequately inform the Commission of a matter reportable under Part 21. In this area inspection findings have consistently shown that many activities covered by Part 21 have not been appropriately considered in procedures and other instructions currently being implemented. Specifically, the provisions of 21.21(a)(1), 21.21(a)(2), 21.21(b)(3) and 21.51 are not being adequately addressed.

Compliance with each element of the rule is necessary to assure proper handling of matters subject to consideration and reporting under Part 21. Your attention is directed to Section 21.51 which requires that each individual or organization subject to 10 CFR Part 21 prepare records sufficient to assure compliance with the requirements of that part.

1662 303

Enclosure 1

IE Information Notice No. 79-30

Date: December 6, 1979

Page 2 of 2

All holders of NRC licenses or permits issued pursuant to 10 CFR Part 50, architect-engineers, contractors and suppliers subject to Part 21 requirements should ensure that management control systems are established to assure that all requirements of 10 CFR Part 21 are met, with particular emphasis on the specific areas discussed above.

1662 304

ENCLOSURE 2

IE Information Notice No. 79-30  
Date: December 6, 1979  
Page 1 of 1

RECENTLY ISSUED IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued to
79-21	Transportation and Commercial Burial of Radioactive Material	9/7/79	All Power and Research Reactors with OLs
79-22	Qualification of Control Systems	9/14/79	All Power Reactor Facilities with an OL or CP
79-23	Emergency Diesel Generator Lube Oil Coolers	9/26/79	All Power Reactor Facilities with an OL or CP
79-24	Overpressurization of Containment of a PWR Plant After a Main Steam Line Break	10/1/79	All Power Reactor Facilities with an OL or CP
79-25	Reactor Trips at Turkey Point Unit 3 and 4	10/1/79	All Power Reactor Facilities with an OL or CP
79-26	Breach of Containment Integrity	11/5/79	All Power Reactor Facilities with an OL or CP
79-12A	Attempted Damage to New Fuel Assemblies	11/9/79	All Fuel Facilities, Research Reactors and Power Reactors with an OL or CP
79-27	Steam Generator Tube Ruptures at Two PWR Facilities	11/16/79	All Power Reactor Facilities with an OL or CP
79-28	Overloading of Structural Elements Due to Pipe Support Loads	11/16/79	All Power Reactor Facilities with an OL or CP
79-29	Loss of Nonsafety Related Reactor Coolant System Instrumentation During Operation	11/19/79	All Power Reactor Facilities with an OL or CP

1662 305