

### REFUELING INFORMATION

The following refueling information is included in the Monthly Report as requested in a letter to Mr. G. C. Andognini dated January 18, 1978:

For your convenience, the information supplied has been enumerated so that each number corresponds to equivalent notation utilized in the request.

1. The name of this facility is Pilgrim Nuclear Power Station, Docket No. 50-293.
2. Scheduled date for next Refueling Shutdown: January 1980
3. Scheduled date for restart following refueling: April 1980
- 4.
5. Due to their similarity, requests 4, 5 & 6 are responded to collectively.
6. The fuel, which is presently expected to be loaded during the next scheduled refueling outage, is of the new P8x8R design, consisting of approximately 64 P8DRB282 assemblies and 120 P8DRB265 assemblies. The licensing submittal and proposed Technical Specification changes are expected to be submitted on or about December 21, 1979.
7. (a) There are 580 fuel assemblies in the core.  
(b) There are 580 fuel assemblies in the spent fuel pool.
8. (a) The station is presently licensed to store 2320 spent fuel assemblies. The actual spent fuel storage capacity is 1770 fuel assemblies at present.  
  
(b) The planned spent fuel storage capacity is 2320 fuel assemblies
9. With present spent fuel in storage, the spent fuel pool now has the capacity to accommodate an additional 1190 fuel assemblies.

1656 336

7912310 474