

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

716 Edney Building

January 2, 1980

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

POOR ORIGINAL

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BFRO-50-259/7935

The enclosed report provides details concerning high-pressure coolant
injection system stop valve FCV-73-18 which would not stay open during
surveillance testing with the unit at steady-state power of 91 percent.
This report is submitted in accordance with Browns Ferry unit 1 Technical
Specification 6.7.2.a.3.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20535

Mr. Bill Lavalles
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

A002
S/11

1706 337

S