

Georgia Power Company
230 Peachtree Street
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

TTC



Georgia Power
the southern electric system

Power Generation Department

December 21, 1979

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street, N. W.
Atlanta, Georgia 30303

REFERENCE:
RII: JPO
50-321, 50-366
I&E Bulletin 79-25

Attention: Mr. James P. O'Reilly

Gentlemen:

Georgia Power Company hereby submits the following information in response to your letter dated November 2, 1979, which transmitted I&E Bulletin 79-25, "Failures of Westinghouse BFD Relays in Safety-Related Systems".

A review of safety-related systems at Plant Hatch has determined that there are no BFD/NBFD type relays in use or planned for use in safety-related systems at Plant Hatch.

If you have any questions or comments in this regard, please contact my office.

Very truly yours

W. A. Widner

W. A. Widner
General Manager Nuclear Generation

JAB/mb

xc: Director of the Office of Inspection and Enforcement
Director of the Division of Operating Reactors, Office of
Nuclear Reactor Regulation

1769 165

OFFICIAL COPY

8001180188

790540