



7E

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

Docket Nos. 50-317  
50-318

JAN 14 1960


Baltimore Gas and Electric Company  
ATTN: Mr. A. E. Lundvall, Jr.  
Vice President, Supply  
P. O. Box 1475  
Baltimore, Maryland 21203

Gentlemen:

Enclosed is IE Bulletin 79-01B which requires action by you with regard to your power reactor facility with an operating license.

Should you have questions regarding this Bulletin or the actions required of you, please contact this office.

Sincerely,

  
Boyce H. Grier  
Director

Enclosures:

1. IE Bulletin No. 79-01B with Attachments
2. List of Recently Issued IE Bulletins

CONTACT: S. D. Ebnetter  
(215-337-5296)

cc w/encls:

R. M. Douglass, Manager, Quality Assurance  
L. B. Russell, Chief Engineer  
W. Gibson, General Supervisor, Operational QA  
R. C. L. Olson, Senior Engineer  
K. H. Sebra, Principal Engineer

1827 261

8001290

362

ENCLOSURE 1

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS No.: 6820  
Accessions No.:  
7910250528

IE Bulletin No. 79-01B  
Date: January 14, 1980  
Page 1 of 4

ENVIRONMENTAL QUALIFICATION OF CLASS IE EQUIPMENT

Description of Circumstances:

IE Bulletin No. 79-01 required the licensee to perform a detailed review of the environmental qualification of Class IE electrical equipment to ensure that the equipment will function under (i.e. during and following) postulated accident conditions.

The NRC staff has completed the initial review of licensees' responses to Bulletin No. 79-01. Based on this review, additional information is needed to facilitate completion of the NRC evaluation of the adequacy of environmental qualification of Class IE electrical equipment in the operating facilities. In addition to requesting more detailed information, the scope of this Bulletin is expanded to resolve safety concerns relating to design basis environments and current qualification criteria not addressed in the facilities' FSARS. These include high energy line breaks (HELB) inside and outside primary containment, aging, and submergence.

Attachment 4, "GUIDELINES FOR EVALUATING ENVIRONMENTAL QUALIFICATION OF CLASS IE ELECTRICAL EQUIPMENT IN OPERATING REACTORS", provides the guidelines and criteria the staff will use in evaluating the adequacy of the licensee's Class IE equipment evaluation in response to this Bulletin.

In general, the reporting problems encountered in the original responses and the additional information needed can be grouped into the following areas:

1. All Class IE electrical equipment required to function under the postulated accident conditions, both inside and outside primary containment, was not included in the responses.
2. In many cases, the specific information requested by the Bulletin for each component of Class IE equipment was not reported.
3. Different methods and/or formats were used in providing the written evidence of Class IE electrical equipment qualifications. Some licensees used the System Analysis Method which proved to be the most effective approach. This method includes the following:
  - a. Identification of the protection systems that are required to function under postulated accident conditions are defined as those systems that are protected from both LOCA and/or HELB inside and outside the primary containment.

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO

No. of pages:

7910250528

44

1829 262