



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JAN 14 1980

In Reply Refer To:

RII:JPO

50-321, 50-366

Georgia Power Company
Attn: J. H. Miller, Jr.
Executive Vice President
270 Peachtree Street, N.W.
Atlanta, Georgia 30303

Gentlemen:

Enclosed is IE Bulletin No. 79-01B which requires action by you with regard to your power reactor facility(ies) with an operating license.

Enclosure 5 to IE Bulletin 79-01B, entitled "Interim Staff Position on Environmental Qualifications of Safety-Related Electrical Equipment", will be forwarded at a later date.

Should you have questions regarding this Bulletin or the actions required of you, please contact this office.

Sincerely,

James P. O'Reilly
Director

Enclosures:

1. IE Bulletin No. 79-01B
with Enclosures
2. List of Recently Issued
IE Bulletins

1824 229

8001290

431

JAN 14 1980

Georgia Power Company

-2-

cc w/encl:

M. Manry, Plant Manager
Post Office Box 442
Baxley, Georgia 31513

C. E. Belflower
Site QA Supervisor
Post Office Box 442
Baxley, Georgia 31513

W. A. Widner, General Manager
Nuclear Generation
Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30303

1826 230

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

SSINS No.: 6820
Accessions No.:
7910250528

January 14, 1980

IE Bulletin No. 79-01B

ENVIRONMENTAL QUALIFICATION OF CLASS IE EQUIPMENT

Description of Circumstances:

IE Bulletin No. 79-01 required the licensee to perform a detailed review of the environmental qualification of Class IE electrical equipment to ensure that the equipment will function under (i.e. during and following) postulated accident conditions.

The NRC staff has completed the initial review of licensees' responses to Bulletin No. 79-01. Based on this review, additional information is needed to facilitate completion of the NRC evaluation of the adequacy of environmental qualification of Class IE electrical equipment in the operating facilities. In addition to requesting more detailed information, the scope of this Bulletin is expanded to resolve safety concerns relating to design basis environments and current qualification criteria not addressed in the facilities' FSARS. These include high energy line breaks (HELB) inside and outside primary containment, aging, and submergence.

Enclosure 4, "GUIDELINES FOR EVALUATING ENVIRONMENTAL QUALIFICATION OF CLASS IE ELECTRICAL EQUIPMENT IN OPERATING REACTORS", provides the guidelines and criteria the staff will use in evaluating the adequacy of the licensee's Class IE equipment evaluation in response to this Bulletin.

In general, the reporting problems encountered in the original responses and the additional information needed can be grouped into the following areas:

1. All Class IE electrical equipment required to function under the postulated accident conditions, both inside and outside primary containment, was not included in the responses.
2. In many cases, the specific information requested by the Bulletin for each component of Class IE equipment was not reported.
3. Different methods and/or formats were used in providing the written evidence of Class IE electrical equipment qualifications. Some licensees used the System Analysis Method which proved to be the most effective approach. This method includes the following:
 - a. Identification of the protection under postulated accident conditions are defined as the from both LOCA and/or HELB inside and outside the primary containment.

1829 251

DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO 7910250528

No. of pages: 44