



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
101 MARIETTA ST., N.W., SUITE 3100  
ATLANTA, GEORGIA 30303

JAN 14 1980

In Reply Refer To:  
RII:JPO  
50-416

Mississippi Power and Light Company  
Attn: N. L. Stampley  
Vice President of Production  
P. O. Box 1640  
Jackson, Mississippi 39205

Gentlemen:

Enclosed is IE Bulletin No. 79-01B which requires action by you with regard to your power reactor facility(ies) with an operating license.

Enclosure 5 to IE Bulletin 79-01B, entitled "Interim Staff Position on Environmental Qualifications of Safety-Related Electrical Equipment", will be forwarded at a later date.

Should you have questions regarding this Bulletin or the actions required of you, please contact this office.

Sincerely,

James P. O'Reilly  
Director

Enclosures:

1. IE Bulletin No. 79-01B  
with Enclosures
2. List of Recently Issued  
IE Bulletins

1820 349

8001200

435

JAN 14 1980

Mississippi Power and  
Light Company

-2-

cc w/encl:  
C. K. McCoy  
Plant Manager  
Post Office Box 756  
Port Gibson, Mississippi 39150

1829 350

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS No.: 6820  
Accessions No.:  
7910250528

January 14, 1980

IE Bulletin No. 79-01B

ENVIRONMENTAL QUALIFICATION OF CLASS IE EQUIPMENT

Description of Circumstances:

IE Bulletin No. 79-01 required the licensee to perform a detailed review of the environmental qualification of Class IE electrical equipment to ensure that the equipment will function under (i.e. during and following) postulated accident conditions.

The NRC staff has completed the initial review of licensees' responses to Bulletin No. 79-01. Based on this review, additional information is needed to facilitate completion of the NRC evaluation of the adequacy of environmental qualification of Class IE electrical equipment in the operating facilities. In addition to requesting more detailed information, the scope of this Bulletin is expanded to resolve safety concerns relating to design basis environments and current qualification criteria not addressed in the facilities' FSARS. These include high energy line breaks (HELB) inside and outside primary containment, aging, and submergence.

Enclosure 4, "GUIDELINES FOR EVALUATING ENVIRONMENTAL QUALIFICATION OF CLASS IE ELECTRICAL EQUIPMENT IN OPERATING REACTORS", provides the guidelines and criteria the staff will use in evaluating the adequacy of the licensee's Class IE equipment evaluation in response to this Bulletin.

In general, the reporting problems encountered in the original responses and the additional information needed can be grouped into the following areas:

1. All Class IE electrical equipment required to function under the postulated accident conditions, both inside and outside primary containment, was not included in the responses.
2. In many cases, the specific information requested by the Bulletin for each component of Class IE equipment was not reported.
3. Different methods and/or formats were used in providing the written evidence of Class IE electrical equipment qualifications. Some licensees used the System Analysis Method which proved to be the most effective approach. This method includes the following:
  - a. Identification of the protection under postulated accident conditions are defined as those from both LOCA and/or HELB inside and outside the primary containment.

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO

7910250528

No. of pages:

44

1821 354