

LER NO. 79-51/3L
DOCKET NO. 50-318
EVENT DATE 12/28/79
REPORT DATE 01/25/80
ATTACHMENT

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS: (CONTINUED)

Technicians involved in radiation monitoring system maintenance have been cautioned to insure connectors in the system are securely detented when they are rejoined after maintenance.

1836 043