



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JAN 14 1980

Docket No. 50-339

Mr. W. L. Proffitt  
Senior Vice President - Power  
Operations  
Virginia Electric & Power Company  
P. O. Box 26666  
Richmond, Virginia 23261

Dear Mr. Proffitt:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOR THE REVIEW OF THE NORTH ANNA  
POWER STATION, UNIT 2 FINAL SAFETY ANALYSIS REPORT (FSAR)

As a result of our continuing review of the North Anna FSAR, we find that we need additional information to complete our evaluation. The specific information required is listed in the enclosure.

Our review schedule is based on the assumption that this additional information will be available for our review by January 25, 1980. If you cannot meet this date, please inform us within seven days after receipt of this letter so that we may revise our schedule accordingly.

Please contact us if you desire any discussion or clarification of the enclosed request.

Sincerely,

*Olan D. Parr*  
Olan D. Parr, Chief  
Light Water Reactors Branch No. 3  
Division of Project Management

Enclosure:  
Request for Additional  
Information

cc w/enclosure:  
See next page

1845 321

8001310 384

A

Mr. W. L. Proffitt

- 2 -

JAN 14 1980

cc: Mr. Anthony Gambaradella  
Office of the Attorney General  
11 South 12th Street - Room 308  
Richmond, Virginia 23219

Richard M. Foster, Esq.  
Musick, Williamson, Schwartz  
Leavenworth & Cope, P. C.  
P. O. Box 4579  
Boulder, Colorado 80306

Michael W. Maupin, Esq.  
Hunton, Williams, Gay & Gibson  
P. O. Box 1535  
Richmond, Virginia 23212

Mrs. June Allen  
412 Owens Drive  
Huntsville, Alabama 35801

Mrs. James Torson  
501 Leroy  
Socorro, New Mexico 87801

Mrs. Margaret Dietrich  
Route 2, Box 568  
Gordonsville, Virginia 22942

William H. Rodgers, Jr., Esq.  
Georgetown University Law Center  
600 New Jersey Avenue, N. W.  
Washington, D. C. 20001

Mr. Peter S. Hepp  
Executive Vice President  
Sun Shipping & Dry Dock Company  
P. O. Box 540  
Chester, Pennsylvania 19013

Mr. R. B. Briggs  
Associate Director  
110 Evans Lane  
Oak Ridge, Tennessee 37830

Clarence T. Kipps, Jr., Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Carroll J. Savage, Esq.  
1700 Pennsylvania Avenue, N.W.  
Washington, D. C. 20006

Mr. James C. Dunstan  
State Corporation Commission  
Commonwealth of Virginia  
Blandon Building  
Richmond, Virginia 23209

Alan S. Rosenthal, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Michael C. Farrar, Esq.  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Michael S. Kidd  
U.S. Nuclear Regulatory Commission  
P. O. Box 128  
Spotsylvania, Virginia 22553

Dr. Paul W. Purdom  
Department of Civil Engineering  
Drexel University  
Philadelphia, Pennsylvania 19104

1845 22

Mr. W. L. Proffitt

- 3 -

JAN 14 1980

cc: Dr. Lawrence R. Quarles  
Apartment No. 51  
Kendal-at-Longwood  
Kennett Square, Pennsylvania 19348

Mr. Irwin B. Kroot  
Citizens Energy Forum  
P. O. Box 138  
McLean, Virginia 22101

James B. Dougherty, Esq.  
Potomac Alliance  
1416 S Street, N.W.  
Washington, D. C. 20009

W. R. Cartwright, Station Manager  
P. O. Box 402  
Mineral, Virginia 23117

W. L. Stewart, Manager  
P. O. Box 315  
Surry, Virginia 23883

1845 323

ENCLOSURE

Request for Additional Information

North Anna Power Station, Unit 2

Docket No. 50-339

14.0 Initial Tests

14.6 It has come to our attention that although some applicants had committed to Regulatory Guide 1.68, they did not intend to conduct full-load tests of some 4160-480 volt transformers supplying power to vital buses. Your test description in FSAR Chapter 14 does not contain sufficient detail for us to determine if you intend to conduct such a test. It is our position that full-load tests of vital buses must be conducted including all sources of power supplies to the buses. Modify your test description to indicate that this testing will be conducted in accordance with Regulatory Guide 1.68. State your intent to comply with our requirements.

1845 324