

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

0	1
2	8

REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 1 0 5 8 0 8 0 1 3 0 8 0 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During normal plant operation, an I&C technician noticed that an isolation valve for pressure switch 2-E11-PS-N010D was shut. This switch supplies a high drywell pressure signal to ADS. Pressure switches 2-E11-PS-N010A,B&C were operable and would have provided an ADS initiation signal on high drywell pressure.

Technical Specifications 3.3.3, 6.9.1.9b

08 Technical Specifications 3.3.3, 6.9.1.9b 8

SYSTEM CODE I E 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE S 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 0 21 22		SEQUENTIAL REPORT NO. 0 0 5 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REV. SION NO. 0 31			
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 40		ATTACHMENT SUBMITTED Y 23	
NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER B 0 6 9 44 47							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 After receiving authorization from the Shift Foreman, the isolation valve was

1 1 opened. It is not known how the valve was shut. PT 11.1.4P, which checks the

1 2 calibration of this instrument, was performed on 12/27/79, and a sign-off for

1 3 returning the valve to the open position was signed off. I&C and Electrical

1 4 personnel have been counselled on the necessity to follow procedures and to

8 9
FACILITY STATUS (28) 1 5 C
% POWER 0 1 8 (29) N/A
OTHER STATUS (30)
METHOD OF DISCOVERY (31) 31
DISCOVERY DESCRIPTION (32) Technician Surveillance
3 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 2 33 4 34 N/A 44

LOCATION OF RELEASE (36)
N/A 45 46

PERSONNEL EXPOSURES										
NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	(37)	Z	(38)	N/A		

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	4	0000	40
		N/A	1927 214

1		2		3		4		5		6		7		8		9		10		11		12	
LOSS OF OR DAMAGE TO FACILITY (43)																							
TYPE		DESCRIPTION																					
1	9	7	(42)	N/A																			

2 0 N 44 N/A 8002060638 NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521

LER CONTINUATION -- RO NO. 2-80-5

Facility: BSEP Unit No. 2

Event Date: 1-5-80

ensure that all instrumentation is properly returned to service.