

## LICENSEE EVENT REPORT

CONTROL BLOCK:                      (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	B	V	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4	5
7	8	9	LICENSEE CODE						14	15	LICENSE NUMBER						25	26	LICENSE TYPE				30	57	CAT	58	

0	1	L	6	5	0	0	0	3	3	4	7	0	1	0	3	7	9	8	0	2	0	2	7	9	9
7	8	REPORT SOURCE		60	61	DOCKET NUMBER						68	69	EVENT DATE				74	75	REPORT DATE				80	

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1802 hours, with 1A Charging Pump inoperable, a reactor trip and safety injection

03 | occurred. During the recovery, it was observed the 1C Charging Pump had low

04 | discharge pressure. The plant was cooled to Operational Mode 5 and a surveillance

05 | test performed. The discharge pressure was approximately 2350 psig versus the

06 | required 2402 psig. The pump was declared inoperable. The 1C Charging Pump was

07 | tested and returned to service at 0900 hours on 1/13/79.

0	8																									80
7	8																									80

0	9	S	F	11	E	12	B	13	P	U	M	P	X	X	14	B	15	Z	16									
7	8	SYSTEM CODE		9	10	CAUSE CODE		11	CAUSE SUBCODE		12	COMPONENT CODE				13	COMP. SUBCODE		19	VALVE SUBCODE		20						

  

17	7	9	EVENT YEAR		21	22	0	0	3	23	24	26	27	0	2	28	29	L	30	31	0	32		
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENCE REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.														

  

A	18	Z	19	Z	20	Z	21	0	0	0	0	22	N	23	Y	24	N	25	P	0	2	5	26
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The incident resulted from a faulty rotating element in the pump. A new rotating

11 | element was installed and the pump was tested satisfactorily on 1/13/79.

12 |

13 |

14 |

1	5	G	28	0	0	0	29	N/A	30	A	31	Operator observation												32									
7	8	FACILITY STATUS		9	10	% POWER		12	13	OTHER STATUS		44	45	METHOD OF DISCOVERY												46	DISCOVERY DESCRIPTION						80

1	6	Z	33	Z	34	N/A						35	N/A												36
7	8	ACTIVITY RELEASED OF RELEASE		9	10	AMOUNT OF ACTIVITY						44	LOCATION OF RELEASE												80

1	7	0	0	0	37	Z	38	N/A						39	
7	8	PERSONNEL EXPOSURES NUMBER		9	10	TYPE		11	DESCRIPTION						41

1	8	0	0	0	40	N/A						41
7	8	PERSONNEL INJURIES NUMBER		9	10	DESCRIPTION						41

1	9	Z	42	N/A						43		
7	8	LOSS OF OR DAMAGE TO FACILITY TYPE		9	10	DESCRIPTION						43

2	0	N	44	N/A						45		
7	8	PUBICITY ISSUED DESCRIPTION		9	10	7902090324						45

NAME OF PREPARER J. A. WerlingPHONE: 412-643-1258

NRC USE ONLY