

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

FREDERICK R. CLARK
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

WILLIAM F. LUDDY



June 6, 1979
IPN-79-31

GEORGE T. BERRY
GENERAL MANAGER
AND CHIEF ENGINEER

LEWIS R. BENNETT
ASSISTANT GENERAL
MANAGER-GENERAL
COUNSEL

WILBUR L. GRONBERG
ASSISTANT GENERAL
MANAGER-ENGINEERING

JOHN W. BOSTON
DIRECTOR OF
POWER OPERATIONS

THOMAS F. MCCRANN, JR.
CONTROLLER

Director, Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Attention: Mr. Albert Schwencer, Chief
Operating Reactors Branch No. 3
Division of Operating Reactors

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
I&E Bulletin 79-07 Status Report
on Pipe Stress Reanalysis

Dear Sir:

Attached for your information is the weekly status report as of June 4, 1979 on United Engineers & Constructors piping reanalysis efforts for the critical lines committed for reanalysis to the NRC by July 1, 1979.

Very truly yours,


P. J. Early
Assistant Chief Engineer-Projects

Att.

2284 044

A001

S 1/1

7906120266

Q

Indian Point 3 Nuclear Power Plant
 Pipe Stress Reanalysis
Status of Work as of June 4, 1979

A. Piping⁽¹⁾

Total No. of Lines for Reanalysis	Total No. Reanalyzed	No. of Lines Within Allowables	No. of Lines Over Allowable
64	17	17	0

B. Piping Supports, Hangers, Snubbers & Nozzles (1) (2)

Total No. of Components to Reanalyze	Total No. Reanalyzed	No. of Components Within Original Design Loads and/or Allowables	No. of Components Over Design Loads and/or Allowables
768	204	204	0

Notes:

- (1) Critical lines due by July 1, 1979. Remainder being developed.
- (2) Estimated. Field verification will determine actual number.

2284 045: