MAINE YANKEE ATOMIC POWER COMPANY •
ENGINEERING OFFICE
TURNPIKE ROAD (RT. 9)
WESTBORO, MASSACHUSETTS 01581
617-366-9011

B.3.2.1
WMY 79-134

November 20, 1979

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

References: (a) License No. DPR-36 (Docket No. 50-309)
(b) USNRC Letter from R. W. Reid to R. H. Groce dated April 24, 1978, Subject: Amendment No. 37 to Facility Operating License
(c) MYNPC Letter WMY 79-116 dated October 16, 1979, Subject: Submittal of Fire Protection Systems Design Information

Dear Sir:

Subject: Submittal of Fire Protection System Design Information

After staff review of Reference (c) above, it appeared that several further questions needed to be answered. The information required to answer those questions is included in this letter.

1. Drawings

Copies of the drawings for the detection system modifications and the Protected Cable Vault Suppression System are attached here.

2. System Specific details

3.1.1 - Fire Detection Systems

1. The Fire Detection System Modifications are being designed and installed in accordance with appropriate NFPA codes.

3.1.2 - Hose Stations

1. Several hose stations were inadvertently left out of the previous letter. This letter confirms that existing hose stations have been fitted with additional hose lengths or new hose stations are being installed such that hose from an interior hose station will reach all the areas listed under Section 3.1.2, page 3-3 of the SER.

1381 299

7911210407

3.1.7 - Fire Doors

1. The door opening in the northeast corner of the Turbine Building has been blocked up, and meets the rating of the existing wall.

If there are any further questions or comments on the fire protection system modifications, please contact us.

Very truly yours,

MAINE YANKEE ATOMIC ELECTRIC COMPANY

D. E. Moody
Manager of Operations

EAS/dmp

Attachment

1381 300