

Central Files

TEXAS UTILITIES GENERATING COMPANY

P. O. BOX 1002 · GLEN ROSE, TEXAS 76043

September 20, 1979
TXX-3048

Mr. K.V. Seyfrit, Director
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

RECEIVED THE COPY

COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
OMISSION OF SHEAR TIE REINFORCING STEEL
UNIT NO. 2 - REACTOR CONTAINMENT BUILDING
FILE NO. 10110

Dear Mr. Seyfrit:

This letter supplements our report concerning the inadvertent omission of shear tie reinforcing steel from the 32nd lift of the Comanche Peak, Unit No. 2 Reactor Containment Building (RCB) exterior wall just below the springline.

This supplemental report incorporates the expanded engineering analysis referenced in paragraph three of the "Detailed Engineering Analysis (Safety Implications)" on page two of our September 17, 1979 TXX-3044.

The attached Gibbs and Hill, Inc. letter GTN-40006 and calculation sheets and sketches supersedes the calculation package submitted previously under GTN-39821.

If you have any further questions, please advise.

Very truly yours,

R. J. Gary
R. J. Gary

RJG:pew
cc: L. F. Fikar

1466 091

A 7912030 040

Gibbs & Hill, Inc.

ENGINEERS DESIGNERS CONSTRUCTORS

DIRECT DIAL EXTENSION

(212) 760- 4450

September 19, 1979

GTN-40006

Texas Utilities Generating Company
Post Office Box 1002
Glen Rose, Texas 76043

Attention: Mr. J. T. Merritt
Manager of Construction and Engineering

Gentlemen:

TEXAS UTILITIES GENERATING COMPANY
COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 - 2300 MW INSTALLATION
G&H PROJECT NO. 2323
UNIT 2 CONTAINMENT WALL REINFORCEMENT
REF: GTN-39821

Subsequent to the NRC meeting of September 14, 1979, CPSES Engineering (New York) has prepared additional calculations to support the conclusions reached in the referenced letter. These calculations are attached for your information.

In addition, we are providing copies of reference documents consisting of correspondence among CPSES Site, TUSI and G&H.

If we can be of further assistance please advise.

Very truly yours,

GIBBS & HILL, Inc.

R. E. Ballard

Harvey R. Rock
Manager of Projects

HRR-REBa:lc

1 Letter + Attachment

CC: ARMS (B&R Site) OL + 1A
H. C. Schmidt (TUSI Dallas) 2L 2A
R. Heim (G&H Site) 1L
J. B. George (TUSI Site) 1L 1A

1466 092

REV. 2

Date SEPT... 1979...

Calc By P. K. Barjor

Chk'd/Apprd. By C. Z. 9/11/79

Subject TWSI... CONTAINMENT... WALL

Gibbs & Hill, Inc. ENGINEERS, DESIGNERS, CONSTRUCTORS NEW YORK

SC 4/13/79 c.z. 9/13/79 Filing Code SRB-122C Sheet No. 1 of 18 G & H Job No. 2323-001

Checkers Comments Accepted By Safety Related: YES [checked] NO []

Materials: CONC.: fc = 4 KSI REBAR: fy = 60 KSI

Ref. Codes: ASME - ACI 359

Ref. FSAR: SEC. 3.8

Other Ref.: FIELD DCA # 5.536 REV. 1 DATED SEPT. 10, 1979 (COPY ENCLOSED)

Assumptions: FIELD TWX-11384 DATED AUG. 28, 1979 (COPY ENCLOSED)

RESULTS

OBJECT:

3 Rows of Addl. # 6 shear bars as shown in drg. # 2323-S2-0505 REV. 5 bet. EL. 993'-1 1/2" and 996'-9 1/2" were omitted in the field.

This became known after concrete was poured up to EL. 997'-6" (Refer TWX-11384). Add'l. # 6 shear bars at closer spacings were added above EL. 997'-6". This is shown in detail on enclosed Field DCA # 5.536 REV. 1 dated Sept. 10, 1979.

The object is to determine if this as-built condition without additional shear ties between EL. 993'-1 1/2" and 996'-9 1/2" is acceptable.

POOR ORIGINAL

CONCLUSION:

As-built condition is acceptable without additional shear ties between EL. 993'-1 1/2" and EL. 996'-9 1/2"

See detail calculations on pages 3/2 to 3/16

Handwritten note: 4/2 to 4/23

REV. 2 PKB 9-17-79 c.z. 9/18/79

1466 093

Date ... SEPT. 1979

Calc By ... PKB

Chk'd/Appro. By C.Z. 9/11/79

Subject TUSI: CONT. WALL - UNIT 2

REV. 2
Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

SC 9/13/79
C2 9/13/79
4/2
2

Filing Code SRB-122C

Sheet No. 2 Of

G & H Job No. 2323-001

Checkers Comments Accepted By Safety Related: YES NO


Materials:

Ref. Codes: SEE PAGE 3/4/1 4/69-17-79 c.z. 9/17/79

Ref. PSAR:

Other Ref.:

Assumptions: SEE BELOW



PART ELEVATION OF WALL SHOWING AS-BUILT SHEAR REINFORCEMENT

WALL SECTION

DCA # 5536 REV. 1
(REFER ~~30 PDA # 5535~~)
TWX - 11384

POOR ORIGINAL

1466 094

PKB 9-17-79 c.z. 9/17/79

Date... S.E.P.T. 1979

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

REV. 2
3/4
4/4 2
SC 9/13/79
72 5/13/79

Filing Code SRB-1220

Calc By... PKB

Sheet No. 4... Of

Chk'd/Apprd. By C.Z 9/11/79

G & H Job No. 2323-001

Subject T.U.S.I.: CONT. WALL UNIT 2

Checkers Comments Accepted By

Safety Related: YES NO

Materials:

Ref. Codes:

Ref. FSAR:

Other Ref.:

Assumptions:

SEE PAGE # 4/1 PKB 9.17.79 C.Z 9/17/79

SEE BELOW

POOR ORIGINAL

RESULTS

Maximum radial shear acts during accident pressure and temperature condition.

In this case, the magnitudes of axial tensions N_ϕ and N_θ associated moments M_ϕ and M_θ are such that concrete will crack in both vertical and horizontal directions in all Models (Model 1, Model 2 and Model 3).

Therefore, for design purposes, it will be inappropriate to consider maximum values of radial shear for Models 1 and 2. As such, Containment wall section between EL. 993'-1/2" and 996'-9/2" will be checked for maximum values of radial shear occurring in Model 3 only. This will be further confirmed in the following pages by performing calculations to ascertain the validity of completely cracked section in both vertical and horizontal directions. ✓

It is to be noted that below the spring line EL. 1000'-6", radial shear forces 'Q' occur in the containment wall as a result of design loadings, due to discontinuity between the wall and the dome.

REV. 2
PKB 9-17-79 C.Z 9/17/79

Date SEPT. 1979.

Calc By TKB

Chk'd/Apprd. By C.Z. 9/11/79

Subject T.U.S.I. CONTAINMENT WALL UNIT-2

Gibbs & Hill, Inc. ENGINEERS, DESIGNERS, CONSTRUCTORS NEW YORK

REV. 2
Filing Code SRB-122C...
Sheet No. 3... Of...
G & H Job No. 2323-001.
REV. 1
4/3 2
SC 9/13/79
C.Z. 9/13/79

Checkers Comments Accepted By Safety Related: YES NO

Materials:

Ref. Codes: } SEE PAGE 3/F 4/1 2 PKB 9-12-79 C.Z. 9/17/79

Ref. FSAR:

Other Ref:

Assumptions: ... SEE BELOW

POOR ORIGINAL

RESULTS

Three different models are investigated in the analysis of the containment shell. Each model assumes a different degree of concrete cracking. Model 1 assumes a completely uncracked section. Model 2 assumes only vertical cracks throughout structure, so that the stiffness in the direction perpendicular to cracks) is represented by the properties of rebar only, neglecting stiffness of concrete. Model 3 assumes both vertical and horizontal cracks throughout structure; the stiffness of concrete is ignored in both directions, with only properties of rebar considered.

REV. 1
PKB
9-12-79
9/12/79
OUT
REV. 1
PKB
9-12-79
C.Z.
9/12/79

In the original design, the requirement for worst condition occurring in any model was conservatively considered for design of shear reinforcement. However, the requirements for Models 1 and 2 are not relevant for design of shear reinforcement at the location in question. This is explained in the following page. ✓

Date SEPT. 1979

Calc By P.K.B.

Chk'd/Apprd. By C.Z. 9/11/79

Subject TUSI CONT. WALL UNIT-2

REV. 2

Gibbs & Hill, Inc. ENGINEERS, DESIGNERS, CONSTRUCTORS NEW YORK

3/5
4/5 2
SL 9/13/79
CZ 9/12/79

Filing Code SRB-122C...

Sheet No. 5 Of ...

G & H Job No. 2323-001

Checkers Comments Accepted By Safety Related: YES NO

Materials: ...

Ref. Codes: SEE PAGE - 4/1 PKB 9-17-79 C.Z. 9/12/79

Ref. FSAR: ...

Other Ref: ...

Assumptions: SEE BELOW

RADIAL SHEAR Q

RESULTS

The following tables # 1A, 1B & 1C show max^m values of radial shear acting on the cont. between EL. 990'-4 1/2" and 1000'-6". The max^m radial shear Q along with associated axial tensions and moments in meridional and circumferential directions (N_φ, M_φ, N_θ and M_θ) are obtained from computer output Book # SRB-97P and SRB-99P ✓

Furthermore, the tables # 2A, 2B & 2C show the corresponding maximum values of radial shear occurring during condition when ~~the containment is subjected to safe-shutdown earthquake but with no accident pressure and accident temperature~~ ~~accident pressure and temperature inside containment.~~ ^{the containment is subjected to safe-shutdown earthquake but with no accident pressure and accident temperature}

shear reinf. requirements in Models 1 & 2 under this condition is less than that which is required for Model 3 under accident pressure and temperature condition as is evident in the following Tables.

1466 097

POOR ORIGINAL

2

PKB 9/11/79
C.Z. 9/12/79

Date SEPT. 1979

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

Filing Code SRB-122C

Calc By. PKB

Sheet No. 6 of

Chk'd/ Apprd. By. C. Z. 9/11/79

G & H Job No. 2323-001

Subject T.V.S.I.: CONT. WALL: UNIT 2

4/6
2
SL 9/13/79
C. Z. 9/12/79

Checkers Comments Accepted By Safety Related: YES NO

Material: }
Ref. Codes: } SEE PAGE 4/1
Ref. FSAR: }
Other Ref.: }
Assumptions: SEE BELOW

PKB 9-17-79
C. Z. 9/17/79

MAXM. RADIAL SHEAR WITH ACC. PRESS. & TEMP. (Q)

LOADING COMBINATION: CL 410: $U = D + T_s + 1.5 P_a + T_a$ F.S.A.R. ✓

CL 430: $U = D + T_w + 1.5 P_a + T_a$ SEC. 3-8-1-32.2a

TABLE 1A

NOTE: FOR LEGEND OF TERMS, SEE PAGE 4/23

MODEL - 1							
MERIDIAN	POINT	Q (k/in)	Nφ (k/in)	Mφ (k/in)	Nθ (k/in)	Mθ (k/in)	LOADING COMB.
8'	92'	-1.7	44.4	270	67.6	348	CL 430
8'	94'	-2.29	44.5	190	66.6	334	CL 430
8'	95'	-2.9	44.7	86	66.9	316	CL 430
8'	96'	-3.45	44.8	-42	69.4	294	CL 430

TABLE 1B

MODEL - 2							
MERIDIAN	POINT	Q	Nφ	Mφ	Nθ	Mθ	LOADING COMB.
8'	92'	-2.09	36.9	190	57.0	63	CL 430
8'	94'	-2.56	36.7	97	56.8	63	CL 430
8'	95'	-3.02	36.4	-15	57.0	63	CL 430
8'	96'	-3.47	36.2	-146	57.8	63	CL 430

TABLE 1C

REFER PAGE 4/22 FOR LOCATION OF MERIDIANS 6 AND 8

REV. 2
PKB 9-17-79
C. Z. 9/12/79

MODEL - 3							
MERIDIAN	POINT	Q	Nφ	Mφ	Nθ	Mθ	LOADING COMB.
8'	92'	-1.04	32.6	110	55.6	124	CL 430
6'	94'	-1.5	36.7	-109	57.6	-51	CL 410
6'	95'	-2.05	36.3	-181	56.6	-51	CL 410
6'	96'	-2.61	35.9	-275	56.8	-51	CL 410
8'	94'	1.49	32.4	60	53.3	124	CL 430

RESULTS

REV. 2
PKB
9-17-79
C. Z.
9/18/79

EL. 996'-4 1/2"
EL. 993'-9"
EL. 997'-1 1/2"
EL. 1000'-6"
EL. 993'-9"

REV. 2

Date.. SEPT.. 1979..

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

Filing Code SRB-122.C

Calc By... PKB.....

Sheet No. 7.. Of

Chk'd/Apprd. By C.Z. 9/11/79

G & H Job No. 2323-001

Subject TUSI: CONT. WALL: UNIT 2

4/7 2
SC 9/13/79
CZ 9/12/79

Checkers Comments Accepted By Safety Related: YES NO

Materials: REV. 2

Ref. Codes: } SEE PAGE 3/5 4/1 PKB 9-17-79 C.Z. 9/11/79

Ref. FSAR:

Other Ref.: 'Q' DURING SAFE SHUTDOWN EARTHQUAKE

Assumptions: } SEE BELOW AND WITHOUT ACCIDENT PRESSURE & ACC. TEMP.

MAXM. RADIAL SHEAR ~~WITHOUT ACC. PRESS & TEMP.~~

RESULTS

LOADING COMB. CL 713: $U = D + T_{S1} + (E_c - E_v)$

REFER F.S.A.R. SEC. 3.8.1.3.2.2.b2

CL 731: $U = D + T_w + (E'_t + E'_v)$

TABLE 2A

MODEL - 1							
MERIDIAN	POINT	Q (K/in)	Nφ (K/in)	Mφ (K/in)	Nθ (K/in)	Mθ (K/in)	LOADING COMB.
8'	92'	-0.53'	+1.8'	327'	-5.3'	355'	CL 731'
8'	94'	-0.68'	+1.6'	304'	-5.4'	351'	CL 731'
8'	95'	-0.83'	1.5'	276'	-5.2'	346'	CL 731'
5'	96'	-0.95'	1.5'	241'	-4.5'	339'	CL 731'

NOTE: FOR LEGEND OF TERMS, SEE PAGE 4/23

TABLE 2B

MODEL - 2							
MERIDIAN	POINT	Q	Nφ	Mφ	Nθ	Mθ	LOADING COMB.
8'	92'	-0.63	1.8'	217'	-4.0'	62'	CL 731'
8'	94'	-0.71	1.7'	192'	-3.9'	62'	CL 731'
8'	95'	-0.78	1.5'	163'	-3.6'	62'	CL 731'
8'	96'	-0.83	1.4'	132'	-3.0'	61'	CL 731'

TABLE 2C

REFER PAGE 4/22 FOR LOCATION OF MERIDIANS 5 AND 8

REV. 2
PKB 9-17-79 C.Z. 9/11/79

MODEL - 3							
MERIDIAN	POINT	Q	Nφ	Mφ	Nθ	Mθ	LOADING COMB.
8'	92'	0.17'	-7.0'	-51'	4.0'	-51'	CL 713'
8'	94'	0.27'	-6.5'	-43'	4.6'	-51'	CL 713'
8'	95'	0.4'	-6.0'	-31'	5.1'	-51'	CL 713'
8'	96'	0.54'	-5.6'	-13'	5.5'	-51'	CL 713'

1466 099

Date SEPT. 1979

Gibbs & Hill, Inc. ENGINEERS, DESIGNERS, CONSTRUCTORS NEW YORK

Filing Code SRB-122C

Calc By PKB

Sheet No. 8 Of

Chk'd/Aprd. By C.Z. 9/1/79

G & H Job No. 2323-001

Subject TUSI: CONT. WALL - UNIT 2

Handwritten notes: 4/8, 2, SC 9/13/79, C.Z. 9/13/79

Checkers Comments Accepted By Safety Related: YES [checked] NO []

Materials: SEE PAGE 3/4 PKB 9-17-79 C.Z. 9/17/79
Ref. Codes:
Ref. FSAR:
Other Ref.:
Assumptions: SEE BELOW

D) RADIAL SHEAR: (FACTORED LOADING: ULTIMATE STRENGTH)

RESULTS

(A) POINT 96: (EL. 1000'-6")

- Q = -2.61 k/in
Nphi = 35.9 k/in
Mphi = -275 kin/in
Ne = 56.8 k/in
Me = -51 kin/in

MODEL 3 CL410

SEE TABLE 1C on Page 4/6

Q = +/- 0.098 k/in } ROT. PLAT. LOAD
~ +/- 0.1 k/in } COMP. BOOK# SRB-116 P1
LOADING PL2, MOD. 3
MERI. I, POINT 73

Handwritten notes: PKB 9-17-79 C.Z. 9/17/79

Sum Q = -2.61 - 0.1 = (-) 2.71 k/in

CHECK WHETHER ENTIRE SECTION IN TENSION:

Nphi = 35.9 and Mphi = (-)275

∴ Tension acting on Inside face

O/A Min depth of section = 4'-3 5/8" + 3/8" (Liner) = 4'-4" = 52"


(Refer Field Transmittal # CPPA 2793 dated 9-10-79)

∴ Eff. depth = d = 52 - 6 = 46 in

∴ d - t/2 = 46 - 52/2 = 46 - 26 = 20 in

∴ Mus = Mphi - Nphi (d - t/2) = -275 + 35.9 x 20 = (+) 443 Kin/in

Since Mus becomes negative, entire section is in tension in vert. direction.



Mus = Moment acting if axial force Nphi is assumed to act at centroid of tension reinf. PKB 9-17-79 C.Z. 9/18/79

Date . SEPT. 1979...

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

Filing Code SRB-122C


Calc By... PKB...

Sheet No. 9 Of ...

Chk'd/Apprd. By C.Z. 9/11/79

G & H Job No. 2323-001

Subject TUSI CONT. WALL - UNIT 2



Checkers Comments Accepted By ... Safety Related: YES NO

Materials: ...
Ref. Codes: } SEE PAGE 3/4/1 PKB 9-17-79 C.Z. 9/11/79
Ref. FSAR: }
Other Ref.: }
Assumptions: SEE BELOW

RESULTS

Similarly, $N_{\theta} = 56.8$ $M_{\theta} = -51'$
Tension is large compared to moment.
o Entire section in tension in horz. direction.
concrete has cracked in both directions.
o Model 3 applies.

CHECK ALLOWABLE CONCRETE SHEAR STRESS:

Allow. conc. shear stress = v_c

$$v_c = 2 \sqrt{f_c'} \left(1 + \frac{0.002 N_{\theta}}{A_g} \right)$$
 ASME-ACI: 359
SEC. C.C. 3411.4-1.C

o $v_c = 2 \sqrt{4000} \left[1 + 0.002 \frac{(-) 35900}{52 \times 1'} \right]$

o $v_c = 2 \times 63.2 (1 - 1.38)$ Result is negative
o $v_c = 0'$

Similarly, in the other direction, $N_{\theta} = 56.8'$
o $v_c = 0'$

o Concrete has cracked in both directions.

NOTE: o Model 3 applies. PKB 9-17-79 C.Z. 9/11/79
For another approach to determine that the concrete has cracked, see page 4/19

Date SEPT. 1979.

Gibbs & Hill, Inc.

ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

Filing Code SRB-122C

Calc By... PKB

Sheet No. 1.D. Of

Chk'd/Apprd. By C. Z. 9/11/79

G & H Job No. 2323-00

Subject TUSI: CONT. WALL: UNIT 2

4/10
3/10
2
SC 9/13/79
CZ 9/13/79

Checkers Comments Accepted By

Safety Related: YES NO

Materials:

Ref. Codes:

Ref. FSAR:

Other Ref.:

Assumptions:

SEE PAGE 4/1 PKB 9-17-79 C. Z. 9/17/79

SEE BELOW

RESULTS

Shear stress $v_u = \frac{Q}{0.85 bd} = \frac{2.71 \times 1000}{0.85 \times 46} = 69.31$ psi
C.Z. 9/17/79

PKB 9-17-79 DCA # 5536 REV. 1

As per Field ~~DC/DDA # 5536~~

6 [Shear bars provided @ 11" v & h.

$A_v \text{ Req'd.} = \frac{v_u \times s \times h}{f_y} = \frac{69.31 \times 11 \times 11}{60000} = 0.14 \text{ in}^2$

Area provided : 1- # 6 bar (Area = 0.44 in²)
O.K.

ALTERNATE CALCULATION (SEE SKETCH ON PAGE 4/1)

$A_v \text{ Req'd.} = \frac{69.31 \times 1 \times 1}{60000} = 0.0012 \text{ in}^2 / \text{inch in both direc.}$

$A_v \text{ provided} = \frac{0.44}{11 \times 11} = 0.0036$

O.K.

PKB 9-17-79 C.Z. 9/17/79

Date: SEPT. 1979
 Calc. By: PKB
 Chk'd/Apprd. By: C.2 9/1/79
 Project: TUST: CONT WALL: UNIT 2

Gibbs & Hill, Inc.
 ENGINEERS, DESIGNERS, CONSTRUCTORS
 NEW YORK

4/11 2
 SC 9/13/79 C.2

Book No. SRB-1220
 Sheet No. 3/11 (4/11)
 G & H Job No. 2323-001


Checkers Comments Accepted By: Nuclear Safety Related: YES NO
 Materials: }
 Ref. Codes: } SEE PAGE 3/4/1
 Ref. PSAR: }
 Other Ref.: }
 Assumptions: } SEE BELOW

(B) POINT 95 (EL. 997'-1 1/2"):

Q = -2.05
 Nφ = 36.3
 Mφ = -181
 Ne = 56.6
 Me = -51'

MODEL 3
 CL 410
 TABLE 1C
 ON

PAGE 4/6
 PKB 9-11-79
 C.2 9/1/79



RESULTS

Q = ± 0.1 k/in ROT. PLAT. LOAD
 COMP. OUTPUT BOOK SRB-116 P1
 LOADING PL2, MOD. 3, MERT. 1, POINT 71

$$\Sigma Q = -2.05 - 0.1 = -2.15 \text{ K/in}$$

O/A Min^m depth of section = 4'-4" = 52"
 (obtained by interpolation bet. approx. EL 992' and 999'
 from Field Transmittal # CPPA 2793 dated 9-10-79)

Total Radial shear at EL. 997'-8" (obtained by interpolation
 bet. points 95 & 96)

$$Q = 2.15 + \frac{(2.71 - 2.15) \times 6.5}{40.5} = 2.24 \text{ K/in}$$

Total Radial Shear at EL. 995'-10 1/2" (obtained by interpolation
 between points 95 & 94)

[Note: Σ Q at point 94 = -1.58 K/in (see Page 4/14)]

$$Q = 1.58 + \frac{(2.15 - 1.58) \times 25.5}{40.5} = 1.95 \text{ K/in}$$

PKB 9-17-75
 C.2 9/1/79

Date: SEPT. 1979
Calc. By: PKB
Chk'd/Apprd. By: c.z 9/11/79
Subject: TUSI: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

3/12
4/12 2
SC 9/13/79

Book No. SRB-122C
Sheet No. 3/F2 4/12 PKB
G & H Job No. 2323-001
c.z 9/11/79

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: }
Ref. Codes: } SEE PAGE 3-4 PKB 9.17-79 c.z 9/11/79
Ref. FSAR: }
Other Ref.: }
Assumptions: } SEE BELOW

RESULTS

CHECK WHETHER ENTIRE AREA IN TENSION:

$N\phi = 36.3, M\phi = -181'$ ∴ Tension on Inside face
 $d = 52'-6 = 46'' \quad t = 52''$

Since Tension is large compared to moment,
Entire section in tension in Vert. direction.

Similarly $N\theta = 56.6, M\theta = -51'$

- ∴ Entire section in tension in horz. dir.
- ∴ Concrete has cracked in both directions
- ∴ Model 3 applies.

CHECK ALLOWABLE CONCRETE SHEAR STRESSES:

$N\phi = 36.3$
Refer calculations done on page 4/9 PKB 9.17-79 c.z 9/11/79 ∴ $v_c = 0$

$N\theta = 56.6 \quad \therefore v_c = 0$

∴ concrete has cracked in both dir.

- ∴ Model 3 applies.

Rad Shear Q at EL. 997'-8" (See Page 4/11) = 2.24 K/in

∴ Shear Stress = $v_u = \frac{2.24 \times 1000}{0.85 \times 1 \times 46} = 57.29 \text{ psi}$

Date: SEPT. 1979
Calc. By: PKB
Chk'd/Apprd. By: C.2 9/11/79
Project: TUSTI: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

3/13
4/13
2
SC 9/13/79

Book No. SRB-122C
Sheet No. 3/13 (4/13)
G & H Job No. 2323-001

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: SEE PAGE 3/4 4/1
Ref. Codes: 2
Ref. FSAR: 9-17-79
Other Ref.: C.2 9/11/79
Assumptions: SEE BELOW

Refer sketch on Page 4/11 S = 11" and h = 12 3/4"

$$A_{v \text{ reqd.}} = \frac{57.29 \times 11 \times 12.75}{60000} = 0.134 \text{ in}^2$$

Area provided = 1- #6 bar (0.44 in²) O.K.

ALTERNATE CALCULATION (SEE SKETCH ON PAGE 4/2)

$$A_{v \text{ reqd.}} = \frac{57.29 \times 1 \times 1}{60000} = 0.00095 \text{ in}^2/\text{inch in both dir.}$$

$$A_{v \text{ provided}} = \frac{0.44}{11 \times 12.75} = 0.003$$

Radial Shear Q at EL. 995'-10 1/2" (See Page 4/11) = 1.95 k/in

$$v_u = \frac{1.95 \times 1000}{0.85 \times 1 \times 46} = 49.87 \text{ psi}$$

Refer sketch on Page 4/11 S = 22" and h = 21.75

$$A_{v \text{ reqd.}} = \frac{49.87 \times 22 \times 21.75}{60000} = 0.40 \text{ in}^2$$

Area provided: 1- #6 bar (0.44 in²) O.K.

ALTERNATE CALCULATION: (SEE SKETCH ON PAGE 4/2)

$$A_{v \text{ reqd.}} = \frac{49.87 \times 1 \times 1}{60000} = 0.0008 \text{ in}^2/\text{inch in both dir.}$$

$$A_{v \text{ provided}} = \frac{0.44}{22 \times 21.75} = 0.0009$$

Date: SEPT. 1979
 Calc. By: PKB
 Chk'd/Apprd. By: C.Z. 9/11/79
 Project: TUSI: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
 ENGINEERS, DESIGNERS, CONSTRUCTORS
 NEW YORK

4/14
 SC 9/13/79

Book No. SRB-1226
 Sheet No. 3/14
 C & H Job No. 2323-001

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: }
 Ref. Codes: } SEE PAGE 4/11 PKB 9-17-79 c.z. 9/12/79
 Ref. FSAR: }
 Other Ref.: }
 Assumptions: } SEE BELOW

(C) POINT 94 (EL. 993'-9") :

$Q = -1.5$
 $N\phi = 36.7$
 $M\phi = -109$
 $N\theta = 57.6$
 $M\theta = -51$

Mod. 3
 CL 410
 TABLE 1C
 ON PAGE 4/6

$Q = \pm 0.08$ K/in

ROT. PLAT. LOAD
 MOD. 3, MERI. I, POINT 68
 BOOK # SRB-116 P1
 LOADING PL 2

$\therefore \Sigma Q = -1.5 - 0.08 = -1.58$ K/in

1/4 depth of section $t = 4'-4" = 52"$
 (Refer Page 4/11)

Total Radial Shear at EL. 994'-0 1/2" (obtained by interpolation bet. points 95 & 94)

$Q = 1.58 + \frac{(2.15 - 1.58) \times 3.5}{40.5} = 1.63$ K/in

NOTE: Since $N\phi$ and $N\theta$ are approx. same as for point 95, therefore the following conclusions can be drawn:

Concrete has cracked in both dir.
 \therefore Model 3 applies.

Shear stress = $v_u = \frac{1.63 \times 1000}{0.85 \times 1 \times 46} = 41.69$ psi
 ($d = 52 - 6 = 46'$)

Refer sketch on Page 4/2 PKB 9-17-79 c.z. 9/12/79
 $s = 22"$, $h = 22"$

RESULTS

Date: SEPT. 1979

Calc. By: PKB

Chk'd/Apprd. By: c.2 9/11/79

Project: TUSTI: CONT. WALL: UNIT-2

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

4/15-2
SC 9/13/79

Book No. SRB-122C
Sheet No. 3/15 (4/15)
G & H Job No. 2323-001

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: } SEE PAGE 41
Rel. Codes: }
Ref. FSAR: }
Other Ref.: }
Assumptions: SEE BELOW

RESULTS

$$A_{u \text{ Req'd}} = \frac{41.69 \times 22 \times 22}{60000} = 0.336 \text{ in}^2$$

Area provided: 1- #6 bar (Area = 0.44 in²)

ALTERNATE CALCULATION: (SEE SKETCH ON PAGE 4/2) PKB 9-17-79 c.2 9/17/79


$$A_{u \text{ Req'd}} = \frac{41.69 \times 1 \times 1}{60000} = 0.00069 \text{ in}^2/\text{inch in both dir.}$$

$$A_{u \text{ Provided}} = \frac{0.44}{22 \times 22} = 0.0009$$

CHECK POINT 94 FOR MERIDIAN 3:

Q = 1.49
N_φ = 32.4
M_φ = 60
N_θ = 53
M_θ = 124

MOD. 3 REV. 2 c.2 9/17/79
CL 430 PKB 9-17-79 acts on outside face of concrete.
TABLE IC 3 Rebars on outside face:
ON 4/6
PAGE 4/6
2 #18 Diag. @ 12" = 0.333 in²/in.
4 #18 Vert. @ 11" = 0.364 in²/in.



∴ C.G. of rebars from outside face:

$$\frac{1/2 \times 0.333(4 + 6.5) + 0.364 \times 13}{2 \times 1/2 \times 0.333 + 0.364} = \frac{1.75 + 4.73}{0.697} = 9.3 \text{ in.}$$

∑ Q at El. 994' 0 1/2" (See Page 4/14) = 1.63 K/in

∴ Eff. depth = d = 52 - 9.3 = 42.7 in.

∴ Shear stress $v_u = \frac{Q}{0.85bd} = \frac{1.63 \times 1000}{0.85 \times 1 \times 42.7} = 44.90 \text{ psi}$ PKB 9-17-79 c.2 9/17/79

∴ $A_{u \text{ Req'd}} = \frac{44.9 \times 1 \times 1}{60000} = 0.00075 \text{ in}^2/\text{in. in both dir.}$

REV. 2

c2 9/17/79 PKB 9-17-79 2

Date: SEPT. 1979

Calc. By: PKB

Chk'd/Apprd. By: c.2. 9/11/79

Project: TUSI: CONT. WALL: UNIT-2

Checkers Comments Accepted By:

Nuclear Safety Related: YES NO

Materials: SEE PAGE 4/11

Ref. Codes: PKB 9-17-79 c.2 9/17/79

Ref. FSAR:

Other Ref.:

Assumptions: SEE BELOW

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

Book No. SRB-122C
Sheet No. 3/16 4/16
G & H Job No. 2323-001

4/16 2
SC 9/13/79
c2 9/13/79

RESULTS

NOTE:

If concrete does not crack, Model 1 Shear forces are to be used. As the concrete has not cracked, concrete has the full shear capacity of $2\sqrt{f_c'} = 126 \text{ psi}$ ✓

Max^m Radial Shear in Model 1 at point 96
(See Table 1A on Page ~~3/16~~ 4/6) = 3.45 k/in
PKB 9-17-79 c.2 9/17/79

Effective depth = d = 46 in.

(See Page ~~3/16~~ 4/8) 2

Concrete shear stress assuming entire shear is resisted by concrete
PKB 9-17-79 c.2 9/17/79

$$v_u = \frac{Q}{0.85bd} = \frac{3.45 \times 1000}{0.85 \times 1 \times 46} = 88.2 \text{ psi}$$

< 126 ✓

NOTE:

Another approach is to find what would be the shear stress in concrete if the steel was fully stressed even though this is not likely to happen. For details of computation, see page 4/20

O.K.

PKB 9-17-79 c.2 9/18/79

ED BEZKOR/son G&H-NY
STRUCTURAL

COMANCHE PEAK STEAM ELECTRIC STATION
DESIGN CHANGE AUTHORIZATION

(WILL) ~~SHALL~~ BE INCORPORATED
IN DESIGN DOCUMENTS

AUTHORIZATION NO. 5536-REV.1

SAFETY RELATED DOCUMENT YES NO

1. DESCRIPTION:

A. APPLICABLE SPEC/DWG/DOCUMENT 2323-S2-0505 REV. 5

NOTE: THIS DOCUMENT SUPERSEDES AND VOIDS DCA-5536-Rev.0.

B. DETAILS In lieu of shear reinforcement above elevation
997'-6" as shown on the design drawing, additional shear
reinforcement has been placed as follows:

Four rows of #6 [at approximate elevation
997'-8", elevation 998'-0", elevation 998'-11"
and elevation 999'-10" spaced at 0'-11"
horizontally.

SOLUTION: Shear reinforcement as placed above
exceeds the design requirements and is therefore acceptable.

2. SUPPORTING DOCUMENTATION

RECEIVED BY TELECOPIER
8TH FLOOR
DATE 9/14/79 TIME 9:20

3. SIGNATURES: CRH/ss 9-10-79

A. APPROVED BY: CRH G&H Representative 9-10-79 Date

B. APPROVED BY: CRHooton Originating Engineer 9-10-79 Date

4. STANDARD DISTRIBUTION:

- B&R Field (Original) (1)
- G&H New York (1)
- G&H Dallas (1)

1466 109

4/18

SC 9/13/79

2 2 9/13/79

PXB 9/11/79

verified c 2 9/11/79

8-29-79

Slashed

Handwritten signatures and initials

CI ENG NY

TUGCO-GRSE

AUGUST 28, 1979

TWX: 11, 384

ATTN: H. P. FOCK/M.L. BERGMAN

PPE: REACTOR BUILDING, UNIT #2

EXTERIOR GALL REINFORCEMENT

REF: 2327-52-0505

ADDITIONAL #6 SHEAR TIES AT 1'-10" VERTICAL AND 1'-10" APPROXIMATE HORIZONTAL ALTERNATE WITH MAIN SHEAR BARS BEGINNING AT EL. 993'-1 1/2" AND ENDING AT EL. 995'-7 1/2" HAVE NOT BEEN PLACED. MAIN SHEAR REINFORCEMENT HAS BEEN PLACED IN ACCORDANCE WITH THE DESIGN DRAWING. CONCRETE HAS BEEN PLACED IN ACCORDANCE WITH THE DESIGN DRAWING. CONCRETE AS BEEN PLACED TO APPROXIMATE EL. 997'-6".

REQUEST ENGINEERING EVALUATION OF THE THREE OMITTED ROW OF SHEAR TIES AT EL. 993'-1 1/2", 994'-11 1/2" AND 996'-9 1/2" FOR ACCEPTANCE TO USE-AS-IS.

ADDITIONAL SHEAR REINFORCEMENT CAN BE PLACED BETWEEN MAIN REINFORCEMENT STARTING AT AND CONTINUING TO WHATEVER ELEVATION IS REQUIRED.

CONCRETE PLACEMENT TO EL. 1000'-6" IS TENTATIVELY SCHEDULED FOR 8-29-79. PLACEMENT WILL BE HELD UNTIL RESOLUTION OF THIS DEFICIENCY.

R. E. HEIM/C. R. HOOTON
CPSES JOBSITE
REH/CRH/JG

1466 110

CI ENG NY

Date: SEPT. 1979

Calc. By: P. K. B.

Dwg./Apprd. By: C. Z. 9/18/79

Subject: TUSI: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
ENGINEERS, DESIGNERS, CONSTRUCTORS
NEW YORK

4/19

Book No. SRB-122C

Sheet No. 4/19

G & H Job No. 2323-001

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: SEE PAGE 4/1

Ref. Codes: SEE PAGE 4/1

Ref. FSAR: SEE BELOW

Other Ref. SEE BELOW

Assumptions: SEE BELOW

POINT 96: (EL. 1000' - 6") : (CONTINUED FROM PAGE 4/9) :

CHECK WHETHER CONCRETE HAS CRACKED:
(ALTERNATE APPROX. METHOD)

$$\begin{array}{l} M N\phi = 35.9 \text{ K/in} \\ M\phi = -275 \text{ Kin/in} \end{array} \left[\begin{array}{l} \text{MODEL 3 CL 410} \\ \text{Table 1C on Page 4/6} \end{array} \right.$$

Assume a homogeneous concrete section and ignore the effects of reinforcement.

o/a Min. depth of as-built section = 52 in.
(See Page 4/8)

$$f = \frac{P}{A} \pm \frac{My}{I} = \frac{35.9 \times 1000}{52 \times 1} \pm \frac{275 \times 1000 \times \frac{52}{2}}{\frac{1}{12} \times 1 \times (52)^3}$$

$$f = 690 \pm 610$$

$$\therefore f_{\max} = 1300 \text{ psi (Tension)}$$

$$f_{\min} = 80 \text{ psi (Tension)}$$

∴ Entire section in tension and
Concrete has cracked.

RESULTS

1466 111

Date: SEPT. 1979
 Calc. By: PKB
 Chk'd/Apprd. By: c. z 9/18/79

Gibbs & Hill, Inc.
 ENGINEERS, DESIGNERS, CONSTRUCTORS
 NEW YORK

4/20

Book No. SRB-122.G
 Sheet No. 4/20
 G & H Job No. 2323-001

act. TUSI: CONT. WALL: UNIT 2

Checkers Comments Accepted By: Nuclear Safety Related: YES NO

Materials: }
 Ref. Codes: } SEE PAGE 4/1 ✓
 Ref. FSAR: }
 Other Ref.: }
 Assumptions: } SEE BELOW ✓

RESULTS

ALTERNATE APPROX. METHOD (CONTINUED FROM PAGE 4/16)

Another approach is to find what would be the shear stress in concrete if the steel was fully stressed to 60 ksi even though this is not likely to happen: ✓

POINT 95 (EL. 997'-1 1/2') AND POINT 94 (EL. 993'-9"):

$$\left. \begin{array}{l} Q \text{ at } 95 = -3.02 \text{ K/in} \\ Q \text{ at } 94 = -2.56 \text{ K/in} \end{array} \right\} \begin{array}{l} \text{MODEL 2, CL 430} \\ \text{TABLE 1B, PAGE 4/6} \end{array}$$

$Q = \pm 0.07 \text{ K/in}$ for Rot. Plat. Load, Book#SRB-116A
 Loading PL2, Mod. 2, Merit, Points 71 & 68

$$\Sigma Q \text{ at } 95 = 3.02 + 0.07 = 3.09$$

$$\Sigma Q \text{ at } 94 = 2.56 + 0.07 = 2.63$$

Per sketch on Page 4/11,

Total Radial Shear at EL. 995'-10 1/2': (obtained by interpolation bet. 95 & 94)

$$Q = 2.63 + \frac{(3.09 - 2.63) \times 25.5}{40.5} = 2.92 \text{ K/in}$$

Effective depth of section = 46 in
 (See Page 4/12)

1466 112

Date..... SEPT. 1979
 Calc. By..... PKB
 Ckd/Apprd. By..... C. Z 9/18/79
 Subject..... TUST: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
 ENGINEERS, DESIGNERS, CONSTRUCTORS
 NEW YORK

4/21

Book No. SRB-122C
 Sheet No. 4/21
 G & H Job No. 2323-001

Checkers Comments Accepted By..... Nuclear Safety Related: YES NO

Materials.....
 Ref. Codes..... } SEE PAGE 4/1'
 Ref. FSAR.....
 Other Ref.....
 Assumptions..... SEE BELOW'

RESULTS

$$\therefore \text{Shear stress in Section } \tau_u = \frac{2.92 \times 1000}{0.85 \times 1 \times 46}$$

$$\therefore \tau_u = 74.7 \text{ psi}$$

Refer sketch on Page 4/11,

#6 [Shear bars have been provided
 at 22" Horz. and 21½" Vert at EL. 995'-10½"

$$\text{Area of \#6 bar} = 0.44 \text{ in}^2$$

\therefore Max^m Shear stress in Section that can be
 be resisted by shear reinf. stressed to 60 ksi



$$= \frac{60000 \times 0.44}{22 \times 21.75} = 55.2 \text{ psi}$$

\therefore Shear stress to be resisted by concrete

$$= 74.7 - 55.2 = 19.5 \text{ psi}$$

$\ll 126$
 $(2\sqrt{f_c'})$

O.K.



LOCATION OF MERIDIANS
IN CONTAINMENT

1466 114

TUSI-UNIT #2	
COMANCHE PEAK	
LOCATION OF MERIDIANS	
IN CONTAINMENT	
Gibbs & Hill, Inc. ENGINEERS, ARCHITECTS, CONTRACTORS NEW YORK	SCALE N.T.S.
ISSUED FOR	JOB NO 2323

NO	ISSUE	DATE	BY	CHKD	REV	BY	REV	BY	REV	BY	REV	BY	REV	BY	REV	BY	REV	BY	REV	BY

5/76

Date..... SEPT. 1979
 Calc. By..... PKB
 Chk'd/Apprd. By..... C. 2 9/18/79
 Subject..... JUST: CONT. WALL: UNIT 2

Gibbs & Hill, Inc.
 ENGINEERS, DESIGNERS, CONSTRUCTORS
 NEW YORK

4/23

Book No. SPB-122C
 Sheet No. 4/23
 G & H Job No. 2323-001

Checkers Comments Accepted By..... Nuclear Safety Related: YES NO
 Materials.....
 Ref. Codes..... } SEE PAGE 4/1 ✓
 Ref. FSAR.....
 Other Ref.
 Assumptions..... } SEE BELOW ✓

RESULTS

LEGEND OF TERMS:

$$\begin{aligned} \text{COMBINED LOADING CL 410: } U &= \overline{D} + \overline{T}_{S_1} + 1.5 \overline{P}_a + \overline{T}_a \quad \left. \begin{array}{l} \text{SEE} \\ \text{PAGE} \\ 4/6 \end{array} \right\} \\ \text{CL 430: } U &= \overline{D} + \overline{T}_W + 1.5 \overline{P}_a + \overline{T}_a \\ \text{CL 713: } U &= \overline{D} + \overline{T}_{S_1} + (\overline{E}'_c - \overline{E}'_v) \quad \left. \begin{array}{l} \text{SEE} \\ \text{PAGE} \\ 4/7 \end{array} \right\} \\ \text{CL 731: } U &= \overline{D} + \overline{T}_W + (\overline{E}'_t + \overline{E}'_v) \end{aligned}$$

\overline{D} = DEAD LOAD OF CONTAINMENT ✓

\overline{T}_{S_1} = OPERATING THERMAL LOADS IN SUMMER ✓

\overline{T}_W = OPERATING THERMAL LOADS IN WINTER ✓

\overline{P}_a = CONTAINMENT PRESSURE LOAD DURING 'LOCA' CONDITION. ✓

\overline{T}_a = ACCIDENT TEMP LOAD DURING 'LOCA' CONDITION ✓

\overline{E}'_v = VERTICAL COMPONENT OF SAFE SHUTDOWN EARTHQUAKE. ✓

\overline{E}'_c = COMPRESSION DEVELOPED BY HORIZONTAL COMPONENT OF SAFE SHUTDOWN EARTHQUAKE ✓

\overline{E}'_t = TENSION DEVELOPED BY HORIZONTAL COMPONENT OF SAFE SHUTDOWN EARTHQUAKE. ✓

\overline{Q} = RADIAL SHEAR ✓

\overline{N}_ϕ = AXIAL FORCE IN VERT. DIR. ✓

\overline{M}_ϕ = BENDING MOMENT IN VERT. DIR. ✓

\overline{N}_θ = AXIAL FORCE IN HORZ. DIR. ✓

\overline{M}_θ = BENDING MOMENT IN HORZ. DIR. ✓

SEE PAGES

4/6 & 4/7 ✓

1466 115