

TABLE 2.2-1

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. Manual Reactor Trip	Not Applicable	Not Applicable
2. Linear Power Level - High		
a. Four Reactor Coolant Pumps Operating	≤ 123% of RATED THERMAL POWER	≤ 123.712% of RATED THERMAL POWER
b. Three Reactor Coolant Pumps Operating	*	*
c. Two Reactor Coolant Pumps Operating - Same Loop	*	*
d. Two Reactor Coolant Pumps Operating - Opposite Loops	*	*
3. Logarithmic Power Level - High (1)	≤ 0.75% of RATED THERMAL POWER	≤ 0.819% of RATED THERMAL POWER
4. Pressurizer Pressure - High	≤ 2368 psia	≤ 2376.887 psia
5. Pressurizer Pressure - Low	≥ 1740 psia (2)	≥ 1686.75 psia (2)
6. Containment Pressure - High	≤ 18.4 psia	≤ 19.024 psia
7. Steam Generator Pressure - Low	≥ 728 psia (3)	≥ 706.6 psia (3)
8. Steam Generator Level - Low	≥ 49.4% (4)	≥ 48.51% (4)

* These values left blank pending NRC approval of ECCS analyses for operation with less than four reactor coolant pumps operating.

7912070 428

1514 168