

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 0 | H | D | B | S | 1 | 0 | 0 | - | 0 | 0 | N | P | F | - | 0 | 3 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T 0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | - | 0 | 3 | 4 | 6 | 7 | 0 | 1 | 1 | 0 | 8 | 0 | 8 | 0 | 2 | 0 | 6 | 8 | 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | On January 10, 1980 at 1700 hours the Technical Specification late date passed with-
0 3 | out being able to successfully perform the Boric Acid Flowpath Heat Tracing Weekly
0 4 | Surveillance Test ST 5011.01, Section 6.1. The concentrated boric acid storage system
0 5 | was declared inoperable and the unit entered the action statement of Technical Speci-
0 6 | fication 3.1.2.2.a. There was no danger to the health and safety of the public or to
0 7 | station personnel. The flowpath from the Borated Water Storage Tank (BWST) was
0 8 | operable. (NP-33-80-05)

0 9 | SYSTEM CODE | P | C | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

17 | LEAD REPORT NUMBER | 8 | 21 | EVENT YEAR | 8 | 22 | SEQUENTIAL REPORT NO. | 0 | 0 | 5 | 24 | OCCURRENCE CODE | 3 | 28 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 | ACTION TAKEN | X | 33 | FUTURE ACTION | F | 34 | EFFECT ON PLANT | Z | 35 | SHUTDOWN METHOD | Z | 36 | HOURS | 0 | 0 | 0 | 37 | ATTACHMENT SUBMITTED | Y | 41 | NRPD-4 FORM SUB. | N | 42 | PRIME COMP. SUPPLIER | A | 43 | COMPONENT MANUFACTURER | Z | Z | Z | Z | 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | The cause of this occurrence is a known deficiency in the design of this system which
1 1 | makes it difficult to maintain the heat trace minimum temperature during demin water
1 2 | addition which is necessary during a startup. Facility Change Request 78-508 will
1 3 | add a heat exchanger to preheat the water before it reaches the heat traced portion of
1 4 | the pipe.

1 5 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | operator observation | 32

1 6 | ACTIVITY RELEASED | Z | 33 | CONTENT OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45

1951 338

80021 20 718

NRC USE ONLY