

TERA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JANUARY 21 1980

Docket Nos. 50-254  
and 50-265

Mr. D. Louis Peoples  
Director of Nuclear Licensing  
Commonwealth Edison Company  
P. O. Box 767  
Chicago, Illinois 60690

Dear Mr. Peoples:

We have been reviewing your submittals relating to the Quad Cities Units Nos. 1 and 2 containment purge system. To assist us in our review, we request the information identified in the enclosure. Please provide the requested information within 30 days of receipt of this letter.

Sincerely,

Thomas A. Ippolito, Chief  
Operating Reactors Branch #3  
Division of Operating Reactors

Enclosure:  
Request for Additional  
Information

cc w/enclosure:  
see next page

8002140 011

Mr. D. Louis Peoples  
Commonwealth Edison Company

- 2 -

cc:

Mr. D. R. Stichnoth  
President  
Iowa-Illinois Gas and  
Electric Company  
205 East Second Avenue  
Davenport, Iowa 52801

Mr. John W. Rowe  
Isham, Lincoln & Beale  
Counselors at Law  
One First National Plaza, 42nd Floor  
Chicago, Illinois 60603

Mr. Nick Kalivianakas  
Plant Superintendent  
Quad Cities Nuclear Power Station  
22710 - 206th Avenue - North  
Cordova, Illinois 61242

Anthony Z. Roisman  
Natural Resources Defense Council  
917 15th Street, N. W.  
Washington, D. C. 20005

Moline Public Library  
504 - 17th Street  
Moline, Illinois 61265

Susan N. Sekuler  
Assistant Attorney General  
Environmental Control Division  
188 W. Randolph Street  
Suite 2315  
Chicago, Illinois 60601

Mr. N. Chrissotimos, Inspector  
US Nuclear Regulatory Commission  
Box 756  
Bettendorf, Iowa 52722

REQUEST FOR ADDITIONAL INFORMATION  
FOR CONTAINMENT PURGE SYSTEM AND  
CONTAINMENT VENTING SYSTEM FOR  
QUAD CITIES 1 UNITS 1 AND 2  
DOCKET NOS -254/265

1. The docketed information as to the design of Engineered Safety Features (ESF) such as the containment ventilation isolation (CVI) systems does not adequately address the following areas. Please discuss how your design conforms with each:
  - 1 - The overriding\* of one type of safety actuation signal (e.g., radiation) should not cause the blocking of any other type of safety actuation signal (e.g., pressure) to the isolation valves.
  - 2 - Sufficient physical features (e.g., key lock switches) should be provided to facilitate adequate administrative controls.
  - 3 - The system-level annunciation of the overridden status should be provided for every safety system impacted when an override is active.
  - 4 - Diverse signals should be provided to initiate isolation of the containment ventilation system. Specifically, containment high radiation, safety injection actuation, and containment high pressure should automatically initiate Containment Ventilation Isolation (CVI).
  - 5 - The instrumentation and control systems provided to initiate ESF should be designed and qualified as safety-grade equipment.
  - 6 - The overriding or resetting\* of the isolation actuation signal should not cause the automatic motion of any ESF valve.
2. Provide the process and instrumentation (P&ID) and schematic drawings of your purge and vent system.

\*The following definitions are given for clarity of use in this issue:  
Override - the signal is still present, and it is blocked in order to perform a function contrary to the signal; Reset - the signal has come and gone, and the circuit is being cleared to return to the normal condition.