



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

January 29, 1979

TERA

Docket No. 50-245

LICENSEE: Northeast Nuclear Energy Company  
FACILITY: Millstone Nuclear Power Station, Unit 1  
SUBJECT: SUMMARY OF MEETING HELD ON JANUARY 11, 1979

Representatives (attendees list attached) of Northeast Nuclear Energy Company (NNECo) and the Nuclear Regulatory Commission (NRC) met in Bethesda, Maryland, on January 11, 1979, to review the program for inspection of the Feedwater Sparger during the Millstone Unit 1 refueling outage currently scheduled to begin April 28, 1979. NNECo plans to submit the program for NRC review in a few weeks after they have considered the comments made by NRC representatives during the meeting.


NNECo representatives stated that dye penetrant testing of the feedwater sparger and clad removal will be accomplished during the 1980 refueling outage. The duration of the 1980 outage will be nine weeks where as the 1979 outage is planned for five weeks. The core spray piping will also be replaced in 1980. Contingency plans have been made so that both tasks can be completed during an extended 1979 refueling outage if the planned inspections during the 1979 outage reveal degradation that could affect the health and safety of the public.

NRC representatives recommended that the NNECo report to be submitted in a few weeks:

- o state the criteria for satisfactory ultrasonic test results;
- o state follow up actions if indications exceed acceptable levels;
- o include a summary of results and conclusions from the last two inspections;
- o identify the flaw or crack size that might escape detection during ultrasonic testing (i. e. UT sensitivity);

7902150109

u discuss water chemistry and chemical intrusion.

  
James J. Shea, Project Manager  
Operating Reactors Branch #2  
Division of Operating Reactors

Attachment:  
List of Attendees

cc:  
See next page

cc  
William H. Cuddy, Esquire  
Day, Berry & Howard  
Counselors at Law  
One Constitution Plaza  
Hartford, Connecticut 06103

Anthony Z. Roisman  
Natural Resources Defense Council  
917 15th Street, N. W.  
Washington, D. C. 20005

Northeast Nuclear Energy Company  
ATTN: Superintendent  
Millstone Plant  
P. O. Box 128  
Waterford, Connecticut 06385

Mr. James R. Himmelwright  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, Connecticut 06101

Nuclear Regulatory Commission, Region I  
Office of Inspection and Enforcement  
ATTN: John T. Shedlosky  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Waterford Public Library  
Rope Ferry Road, Route 156  
Waterford, Connecticut 06385

M. W. G. Counsil, Vice President  
Nuclear Engineering and Operations  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06101