POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT

JOHN D. LEONARD, JR.
Resident Manager

P.O. BOX 41
Lycoming, New York 13093
315-342-3840

June 15, 1979
JAFP-79-302

Mr. Boyce H. Grier
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Reference: Docket No. 50-333 Licensee Event Report: 79-029/03L-0

Dear Mr. Grier:

We have enclosed the referenced Licensee Event Report in accordance with Section 6.0 of Technical Specifications and USNRC Regulatory Guide 1.16.

If there are any questions concerning this report, please contact Mr. W. Verne Childs at 315-342-3840, Extension 207.

Very truly yours,

John D. Leonard, Jr.

JDL:VC:jjh
Enclosure

John D. Leonard, Jr.
Resident Manager

CC: USNRC Director, Office of Inspection & Enforcement (30 copies)
USNRC Director, Office of Management Information & Program Control (3 copies)
Internal Power Authority Distribution

2307 230

A002
S 1/1

7906190 271

(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| | | |

POWER AUTHORITY OF THE STATE OF NEW YORK
JAMES A. FITZPATRICK NUCLEAR POWER PLANT

DOCKET NO. 50-333

ATTACHMENT TO LER 79-029/03L-0 Page 1 of 1

While in a cold shutdown condition, during the conduct of scheduled Snubber Inspection in accordance with the requirements of Technical Specification Appendix A, Paragraph 4.6.I.1, a number of deficiencies were noted as indicated below:

1) A total of fourteen (14) snubbers required some work.

2) As a result of visual inspection six (6) snubbers were determined to be potentially inoperable and were removed for test. Of these six (6) snubbers, two (2) failed the operability test and were declared inoperable as a result of the visual examination.

Since the plant was in a cold shutdown condition and only two (2) snubbers were found inoperable, the event did not represent a significant hazard to the public health and safety.

As a result of this inspection the next inspection is due in six months (± 25%).

NOTE: LER 77-046/03L-0 and 78-103/03L-0 are related events.

2307 232